

**बिड दस्तावेज / Bid Document**

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	06-02-2026 15:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	06-02-2026 15:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	120 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Education
विभाग का नाम/Department Name	Department Of Higher Education
संगठन का नाम/Organisation Name	Indian Institute Of Technology (iit)
कार्यालय का नाम/Office Name	Indian Institute Of Technology Patna
कुल मात्रा/Total Quantity	4307
वस्तु श्रेणी /Item Category	Modular Piano Type Domestic Electrical Switches as per IS 3854 (Q3) , PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694 (Q2) , XLPE Cable for Working Voltages up to and Including 1.1 KV as per IS 7098 (Part 1) (Q2) , LED Batten (Q2) , LED Luminaire for Road and Street Lights (V2) Conforming to IS 10322 (Part 5 / Section 3) (Q3) , MCB - Miniature Circuit - Breakers for A.C. Operation as per IS / IEC 60898 (Part 1) (Q2) , Molded Case Circuit Breakers (MCCB) as per IS / IEC 60947 (Q3) , PVC Copper Cable Single Core and Multi Core Circular Sheathed Cord with Flexible Conductor (V2) as per IS 694 (Q2) , LED Luminaire for Floodlight (V2) Conforming to IS 10322 (Part 5/Section 5) (Q3)
बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का) /Minimum Average Annual Turnover of the bidder (For 3 Years)	11 Lakh (s)
मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का)/OEM Average Turnover (Last 3 Years)	22 Lakh (s)
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष/Years of Past Experience Required for same/similar service	3 Year (s)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Relaxation for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Relaxation for Years of Experience and Turnover	No

<b>बिड विवरण/Bid Details</b>	
<b>विक्रेता से मांगे गए दस्तावेज़/Document required from seller</b>	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
<b>क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेन् है/Do you want to show documents uploaded by bidders to all bidders participated in bid?</b>	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)
<b>बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension</b>	3
<b>दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended</b>	7
<b>ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count</b>	1
<b>विगत प्रदर्शन /Past Performance</b>	60 %
<b>बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled</b>	No
<b>बिड का प्रकार/Type of Bid</b>	Two Packet Bid
<b>प्राथमिक उत्पाद श्रेणी/Primary product category</b>	Modular Piano Type Domestic Electrical Switches as per IS 3854
<b>तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation</b>	2 Days
<b>निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)</b>	No
<b>अनुमानित बिड मूल्य /Estimated Bid Value</b>	2258564.95
<b>मूल्यांकन पद्धति/Evaluation Method</b>	Item wise evaluation
<b>मध्यस्थता खंड/Arbitration Clause</b>	No
<b>सुलह खंड/Mediation Clause</b>	No

#### ईएमडी विवरण/EMD Detail

<b>आवश्यकता/Required</b>	No
--------------------------	----

**ईपीबीजी विवरण /ePBG Detail**

आवश्यकता/Required	No
-------------------	----

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

**एमआईआई खरीद वरीयता / MII Purchase Preference**

एमआईआई खरीद वरीयता / MII Purchase Preference	Yes
मेक इन इंडिया विक्रेताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में है / Purchase Preference to MII sellers available upto price within L1+X%	20
मेक इन इंडिया खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MII purchase preference	50
सार्वजनिक खरीद (मेक-इन-इंडिया को प्राथमिकता) आदेश 2017 के अनुसार केवल क्लास 1/क्लास 2 के स्थानीय आपूर्तिकर्ताओं को ही भागीदारी की अनुमति है दिनांक 16.09.2020 (समय-समय पर संशोधित एवं लागू) / Allow participation only from Class 1/Class 2 local suppliers as per the Public procurement(Preference to Make-in-india) order 2017 date 16.09.2020(as amended and applicable time to time)	Yes, in compliance with the MII ORDER : DPIIT Order(as amended and applicable time to time)

**एमएसई खरीद वरीयता/MSE Purchase Preference**

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within L1+X%	15
सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference	25

1. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

2. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or

similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

3. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

4. Preference to Make In India products (For bids < 200 Crore): Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

5. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

6. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

7. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 60% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

**मूल्यांकन विधि(मदवार मूल्यांकन विधि) / Evaluation Method ( Item Wise Evaluation Method )**

Contract will be awarded schedulewise and the determination of L1 will be done separately for each schedule.

The details of item-consignee combination covered under each schedule are as under:

मूल्यांकन अनुसूचियां / <b>Evaluation Schedules</b>	अनुमानित मूल्य / <b>Estimated Value</b>	वस्तु/श्रेणी / <b>Item/Category</b>	मात्रा / <b>Quantity</b>
Schedule 1	2150	Modular Piano Type Domestic Electrical Switches As Per Is 3854	50
Schedule 2	36000	Pvc Insulated Copper Cable Single And Multi - Core Circular Sheathed Cable With Flexible Conductor (v2) As Per Is 694	200
Schedule 3	5000	Xlpe Cable For Working Voltages Up To And Including 1.1 Kv As Per Is 7098 (part 1)	500
Schedule 4	1249500	Xlpe Cable For Working Voltages Up To And Including 1.1 Kv As Per Is 7098 (part 1)	500
Schedule 5	23038	Led Batten	200
Schedule 6	17898	Led Batten	100
Schedule 7	97050	Led Luminaire For Road And Street Lights (v2) Conforming To Is 10322 (part 5 / Section 3)	150
Schedule 8	62140	Mcb - Miniature Circuit - Breakers For A.c. Operation As Per Is / lec 60898 (part 1)	400
Schedule 9	20828.8	Mcb - Miniature Circuit - Breakers For A.c. Operation As Per Is / lec 60898 (part 1)	40
Schedule 10	16318.4	Mcb - Miniature Circuit - Breakers For A.c. Operation As Per Is / lec 60898 (part 1)	20
Schedule 11	3625	Mcb - Miniature Circuit - Breakers For A.c. Operation As Per Is / lec 60898 (part 1)	5
Schedule 12	22750.4	Mcb - Miniature Circuit - Breakers For A.c. Operation As Per Is / lec 60898 (part 1)	20
Schedule 13	32125.2	Mcb - Miniature Circuit - Breakers For A.c. Operation As Per Is / lec 60898 (part 1)	20
Schedule 14	32079.6	Mcb - Miniature Circuit - Breakers For A.c. Operation As Per Is / lec 60898 (part 1)	20
Schedule 15	28150	Molded Case Circuit Breakers (mccb) As Per Is / lec 60947	5
Schedule 16	55527.75	Molded Case Circuit Breakers (mccb) As Per Is / lec 60947	5
Schedule 17	39980	Molded Case Circuit Breakers (mccb) As Per Is / lec 60947	2
Schedule 18	125200	Pvc Copper Cable Single Core And Multi Core Circular Sheathed Cord With Flexible Conductor (v2) As Per Is 694	2000
Schedule 19	129000	Led Luminaire For Floodlight (v2) Conforming To Is 10322 (part 5/section 5)	10
Schedule 20	195576	Led Luminaire For Floodlight (v2) Conforming To Is 10322 (part 5/section 5)	30
Schedule 21	64627.8	Led Luminaire For Floodlight (v2) Conforming To Is 10322 (part 5/section 5)	30

**Modular Piano Type Domestic Electrical Switches As Per IS 3854 ( 50 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local

**Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)****तकनीकी विशिष्टियाँ /Technical Specifications**\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	<b>Type of Switch</b>	bell push switch
	<b>Rated current</b>	6A
	<b>Rated voltage</b>	230, 240, 250 <b>(Volt)</b>
Switch classification	<b>No. of poles</b>	Single pole, Double pole
	<b>According to type of terminal</b>	Screw type terminal, Screwless type terminal
	<b>No. of modules</b>	1 module, 2 module, 3 module
Construction	<b>Current carrying material</b>	Brass, Copper
	<b>Color of switch body</b>	White, Off, white, Grey, Black, Brown, Others
Certification & standards	<b>Warranty</b>	1, 2, 3 <b>(year)</b>

**Additional Specification Parameters - Modular Piano Type Domestic Electrical Switches As Per IS 3854 ( 50 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	Ampere rating-6A, Voltage rating-240V, 1 Module, White colour, suitable to ABB Plate

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106,IIT Patna, Kanpa Road, Bihta	50	15

**PVC Insulated Copper Cable Single And Multi - Core Circular Sheathed Cable With Flexible Conductor (V2) As Per IS 694 ( 200 meter )****(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)****तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	<b>Cable Construction Type</b>	Multicore Cords Cable, Multicore Cable, Single Core Cable
	<b>No of core</b>	1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25
	<b>Nominal Cross Sectional Area of Conductor (in Sq mm)</b>	4, 6, 10, 16, 25, 35, 50, 70, 95, 120, 150, 185, 240, 300, 0.5, 0.75, 1, 1.5, 2.5
	<b>Conductor material (Complying with IS:8130:1984 latest)</b>	Annealed Tinned Copper, Annealed bare copper

**Additional Specification Parameters - PVC Insulated Copper Cable Single And Multi - Core Circular Sheathed Cable With Flexible Conductor (V2) As Per IS 694 ( 200 meter )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	4 Core , 4Sqmm, multicore copper conductor,FR, PVC insulated cable, AS per IS As per IS: 694: 2010

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106,IIT Patna, Kanpa Road, Bihta	200	15

**XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 500 meter )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	<b>Conformity of the specification for XLPE cable</b>	as per IS:7098 (Part 1): 1988 latest

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Cables suitable for use in mines	Yes, No
	Cables suitable for use in low temperature applications	Yes, No
GENERIC	Classification of cables for improved fire performance category	01, C1 - FR, C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	1.5, 2.5, 4, 6, 10, 16, 25, 35, 50, 70, 95, 120, 150, 185, 240, 300, 400, 500, 630, 800, 1000
	Number of core (in Nos)	1, 2, 3, 3.5, 4, 5, 6, 7, 8, 9, 10, 11, 12, 18, 24
CONSTRUCTION	Material of conductor	Plain Copper, Aluminium
	Type of inner sheath	Vulcanized rubber, Un-vulcanized rubber, Thermoplastic
ARMOURING	Type of cable	Armoured cable, Un-armoured cable
	Material of armouring	Galvanized round steel wire, Galvanized steel formed wire, Aluminium round wire, Aluminium flat strip, Not applicable for Un-armoured cable
	Type of armouring	Single wire, Double wire, Single strip, Double strip, Not applicable for Un-armoured cable
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

**Additional Specification Parameters - XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 500 meter )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	4 Core 10Sqmm XLPE , Armoured, Stranded, Aluminium conductor cable. as per IS:7098 (Part 1)

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106,IIT Patna, Kanpa Road, Bihta	500	15

**XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (**

**500 meter )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	<b>Conformity of the specification for XLPE cable</b>	as per IS:7098 (Part 1): 1988 latest
	<b>Cables suitable for use in mines</b>	Yes, No
	<b>Cables suitable for use in low temperature applications</b>	Yes, No
GENERIC	<b>Classification of cables for improved fire performance category</b>	01, C1 - FR, C2 - FR-LSH
	<b>Nominal Area of Conductor (in Sq mm)</b>	1.5, 2.5, 4, 6, 10, 16, 25, 35, 50, 70, 95, 120, 150, 185, 240, 300, 400, 500, 630, 800, 1000
	<b>Number of core (in Nos)</b>	1, 2, 3, 3.5, 4, 5, 6, 7, 8, 9, 10, 11, 12, 18, 24
CONSTRUCTION	<b>Material of conductor</b>	Plain Copper, Aluminium
	<b>Type of inner sheath</b>	Vulcanized rubber, Un-vulcanized rubber, Thermoplastic
ARMOURING	<b>Type of cable</b>	Armoured cable, Un-armoured cable
	<b>Material of armouring</b>	Galvanized round steel wire, Galvanized steel formed wire, Aluminium round wire, Aluminium flat strip, Not applicable for Un-armoured cable
	<b>Type of armouring</b>	Single wire, Double wire, Single strip, Double strip, Not applicable for Un-armoured cable
CERTIFICATION	<b>Availability of Optional Test Reports</b>	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

**Additional Specification Parameters - XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 500 meter )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	4 Core 25Sqmm XLPE , Armoured, Stranded, Aluminium conductor cable. as per IS:7098 (Part 1)

\* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106,IIT Patna, Kanpa Road, Bihta	500	15

**LED Batten ( 200 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	<b>LED Batten Rating (in Watts)</b>	5, 10, 12, 18, 20, 22, 24, 36, 40
	<b>Length of LED Batten (Nominal) (in mm)</b>	280, 560, 1150
	<b>Lamp Efficacy (Lumen / Watt), Minimum</b>	100, 110 Or higher
	<b>Warranty for free replacement (in Years)</b>	1, 2, 3 Or higher
CONSTRUCTIONAL	<b>Housing Material</b>	Polycarbonate, Aluminium

**Additional Specification Parameters - LED Batten ( 200 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	LED Batten light, 20Watt, Efficasy->100lm/w, Colour temperature-6500K, CRI >80, 1150mm long.

\* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106,IIT Patna, Kanpa Road, Bihta	200	15

## LED Batten ( 100 pieces )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	LED Batten Rating (in Watts)	5, 10, 12, 18, 20, 22, 24, 36, 40
	Length of LED Batten (Nominal) (in mm)	280, 560, 1150
	Lamp Efficacy (Lumen / Watt), Minimum	100, 110 Or higher
	Warranty for free replacement (in Years)	1, 2, 3 Or higher
CONSTRUCTIONAL	Housing Material	Polycarbonate, Aluminium

### Additional Specification Parameters - LED Batten ( 100 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	LED Batten light, 5Watt, Efficacy->100lm/w, Colour temperature-6500K, CRI >80, 280mm long.

\* Bidders offering must also comply with the additional specification parameters mentioned above.

### परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106,IIT Patna, Kanpa Road, Bihta	100	15

## LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) ( 150 pieces )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	<b>LED Rating (in Watts)/ System Wattage/ Rated Power</b>	18, 24, 30, 36, 40, 45, 48, 60, 70, 72, 90, 100, 110, 120, 140, 150, 180, 200
	<b>LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)</b>	100, 120, 140 Or higher
ELECTRICAL CHARACTERISTIC	<b>Input operating voltage range and frequency</b>	90 to 300 Volts AC at 50 Hz +/-2, 140 to 270 Volts AC at 50 Hz +/-2
CONTROL GEAR	<b>Number of electronic control gear in the luminaire (power supplies)</b>	1, 2 Or higher
LUMINAIRE	<b>Provision of luminaire connecting wire along with the supply of material</b>	40 cm (ISI marked to IS 9968), 50 cm (ISI marked to IS 9968), 100 cm (ISI marked to IS 9968)
REPORTS AND CERTIFICATIONS	<b>Warranty for free replacement (in years)</b>	2, 3, 4, 5 Or higher

**Additional Specification Parameters - LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) ( 150 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	LED street light, 45Watt, Efficacy->100lm/w, IP 66, Colour temperature-5700K, CRI >70.

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106,IIT Patna, Kanpa Road, Bihta	150	15

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 400 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local

**Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)****तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	<b>Conformity of the specification</b>	as per IS/IEC 60898 : PART 1:2015 latest
RATING	<b>No. of pole (hint: "P" - Pole, "PP" Protected Pole)</b>	1 P, 2 P with 1 PP, 2 P with 2 PP, 3 P with 3 PP, 4 P with 3 PP, 4 P with 4 PP
	<b>Rated voltage (in Volts)</b>	240 V, AC, 415 V, AC, 230 / 415 V, AC, 240 / 415 V, AC
	<b>Rated Current (in Ampere)</b>	0.5, 1, 2, 2.5, 3, 4, 5, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63, 80, 100, 125
	<b>Instantaneous tripping current type</b>	B, C, D
	<b>Rated Short circuit capacity (in Ampere)</b>	1500, 3000, 6000, 7500, 10000, 15000
CONSTRUCTION	<b>Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs</b>	Without enclosure, Yes with 1.2 mm thick

**Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 400 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	20A MCB, C-Curve, 1Pole, 240Volt,10KA, without enclosure, IS marked

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106,IIT Patna, Kanpa Road, Bihta	400	15

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 40 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	<b>Conformity of the specification</b>	as per IS/IEC 60898 : PART 1:2015 latest
RATING	<b>No. of pole (hint: "P" - Pole, "PP" Protected Pole)</b>	1 P, 2 P with 1 PP, 2 P with 2 PP, 3 P with 3 PP, 4 P with 3 PP, 4 P with 4 PP
	<b>Rated voltage (in Volts)</b>	240 V, AC, 415 V, AC, 230 / 415 V, AC, 240 / 415 V, AC
	<b>Rated Current (in Ampere)</b>	0.5, 1, 2, 2.5, 3, 4, 5, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63, 80, 100, 125
	<b>Instantaneous tripping current type</b>	B, C, D
	<b>Rated Short circuit capacity (in Ampere)</b>	1500, 3000, 6000, 7500, 10000, 15000
CONSTRUCTION	<b>Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs</b>	Without enclosure, Yes with 1.2 mm thick

**Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 40 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	32A MCB, C-Curve, 2Pole 2PP, 240Volt, 10KA, without enclosure, IS marked

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106, IIT Patna, Kanpa Road, Bihta	40	15

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 20 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	<b>Conformity of the specification</b>	as per IS/IEC 60898 : PART 1:2015 latest
RATING	<b>No. of pole (hint: "P" - Pole, "PP" Protected Pole)</b>	1 P, 2 P with 1 PP, 2 P with 2 PP, 3 P with 3 PP, 4 P with 3 PP, 4 P with 4 PP
	<b>Rated voltage (in Volts)</b>	240 V, AC, 415 V, AC, 230 / 415 V, AC, 240 / 415 V, AC
	<b>Rated Current (in Ampere)</b>	0.5, 1, 2, 2.5, 3, 4, 5, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63, 80, 100, 125
	<b>Instantaneous tripping current type</b>	B, C, D
	<b>Rated Short circuit capacity (in Ampere)</b>	1500, 3000, 6000, 7500, 10000, 15000
CONSTRUCTION	<b>Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs</b>	Without enclosure, Yes with 1.2 mm thick

**Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 20 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	63A MCB, C-Curve, 2Pole 2PP, 240Volt, 10KA, without enclosure, IS marked

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106,IIT Patna, Kanpa Road, Bihta	20	15

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 5 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	<b>Conformity of the specification</b>	as per IS/IEC 60898 : PART 1:2015 latest
RATING	<b>No. of pole (hint: "P" - Pole, "PP" Protected Pole)</b>	1 P, 2 P with 1 PP, 2 P with 2 PP, 3 P with 3 PP, 4 P with 3 PP, 4 P with 4 PP
	<b>Rated voltage (in Volts)</b>	240 V, AC, 415 V, AC, 230 / 415 V, AC, 240 / 415 V, AC
	<b>Rated Current (in Ampere)</b>	0.5, 1, 2, 2.5, 3, 4, 5, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63, 80, 100, 125
	<b>Instantaneous tripping current type</b>	B, C, D
	<b>Rated Short circuit capacity (in Ampere)</b>	1500, 3000, 6000, 7500, 10000, 15000
CONSTRUCTION	<b>Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs</b>	Without enclosure, Yes with 1.2 mm thick

**Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 5 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	32A MCB, C-Curve, 3Pole 3PP, 415Volt, 10KA, without enclosure, IS marked

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106,IIT Patna, Kanpa Road, Bihta	5	15

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 20 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	<b>Conformity of the specification</b>	as per IS/IEC 60898 : PART 1:2015 latest
RATING	<b>No. of pole (hint: "P" - Pole, "PP" Protected Pole)</b>	1 P, 2 P with 1 PP, 2 P with 2 PP, 3 P with 3 PP, 4 P with 3 PP, 4 P with 4 PP
	<b>Rated voltage (in Volts)</b>	240 V, AC, 415 V, AC, 230 / 415 V, AC, 240 / 415 V, AC
	<b>Rated Current (in Ampere)</b>	0.5, 1, 2, 2.5, 3, 4, 5, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63, 80, 100, 125
	<b>Instantaneous tripping current type</b>	B, C, D
	<b>Rated Short circuit capacity (in Ampere)</b>	1500, 3000, 6000, 7500, 10000, 15000
CONSTRUCTION	<b>Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs</b>	Without enclosure, Yes with 1.2 mm thick

**Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 20 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	32A MCB, C-Curve, 4Pole 4PP, 415Volt, 10KA, without enclosure, IS marked

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106,IIT Patna, Kanpa Road, Bihta	20	15

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 20 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	<b>Conformity of the specification</b>	as per IS/IEC 60898 : PART 1:2015 latest
RATING	<b>No. of pole (hint: "P" - Pole, "PP" Protected Pole)</b>	1 P, 2 P with 1 PP, 2 P with 2 PP, 3 P with 3 PP, 4 P with 3 PP, 4 P with 4 PP
	<b>Rated voltage (in Volts)</b>	240 V, AC, 415 V, AC, 230 / 415 V, AC, 240 / 415 V, AC
	<b>Rated Current (in Ampere)</b>	0.5, 1, 2, 2.5, 3, 4, 5, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63, 80, 100, 125
	<b>Instantaneous tripping current type</b>	B, C, D
	<b>Rated Short circuit capacity (in Ampere)</b>	1500, 3000, 6000, 7500, 10000, 15000
CONSTRUCTION	<b>Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs</b>	Without enclosure, Yes with 1.2 mm thick

**Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 20 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specificaition	40A MCB, C-Curve, 4Pole 4PP, 415Volt, 10KA, without enclosure, IS marked

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106,IIT Patna, Kanpa Road, Bihta	20	15

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 20 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	<b>Conformity of the specification</b>	as per IS/IEC 60898 : PART 1:2015 latest
RATING	<b>No. of pole (hint: "P" - Pole, "PP" Protected Pole)</b>	1 P, 2 P with 1 PP, 2 P with 2 PP, 3 P with 3 PP, 4 P with 3 PP, 4 P with 4 PP
	<b>Rated voltage (in Volts)</b>	240 V, AC, 415 V, AC, 230 / 415 V, AC, 240 / 415 V, AC
	<b>Rated Current (in Ampere)</b>	0.5, 1, 2, 2.5, 3, 4, 5, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63, 80, 100, 125
	<b>Instantaneous tripping current type</b>	B, C, D
	<b>Rated Short circuit capacity (in Ampere)</b>	1500, 3000, 6000, 7500, 10000, 15000
CONSTRUCTION	<b>Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs</b>	Without enclosure, Yes with 1.2 mm thick

**Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 20 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	63A MCB, C-Curve, 4Pole 4PP, 415Volt, 10KA, without enclosure, IS marked

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106,IIT Patna, Kanpa Road, Bihta	20	15

**Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 ( 5 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	YES, NO
	Rated Current (in Ampere)	32A, 50A, 63A, 80A, 100A, 125A, 160A, 200A, 225A, 250A, 320A, 400A, 500A, 630A, 16A, 20A, 25A, 1000 A, 800 A, 1250 A, 1300 A
	No of poles/Protected poles(PP)	1 Pole, 2 Pole, 3 Pole, 4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity 10/16 KA tripping range, MCCB with RSCB capacity of 10/16/25/35 KA tripping range, 35 KA, MCCB with RSCB capacity of 10/16/25/35/50/65 KA tripping range
	Breaking current (in KA)	10 KA, 16 KA, 25 KA, 35 KA, 50 KA, 60 KA, 100 KA, 18 KA, 36 KA, 20 ka, 65 KA, 56 KA, 70 KA
	Rated Voltage	240 Volt 50 Hz AC, 240/415 Volt 50 Hz AC, 415 volt 50 Hz, 220VDC

**Additional Specification Parameters - Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 ( 5 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	100A MCCB, C-Curve, 4Pole 4PP, 415Volt, 16KA, without enclosure, IS marked

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106,IIT Patna, Kanpa Road, Bihta	5	15

**Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 ( 5 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	YES, NO
	Rated Current (in Ampere)	32A, 50A, 63A, 80A, 100A, 125A, 160A, 200A, 225A, 250A, 320A, 400A, 500A, 630A, 16A, 20A, 25A, 1000 A, 800 A, 1250 A, 1300 A
	No of poles/Protected poles(PP)	1 Pole, 2 Pole, 3 Pole, 4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity 10/16 KA tripping range, MCCB with RSCB capacity of 10/16/25/35 KA tripping range, 35 KA, MCCB with RSCB capacity of 10/16/25/35/50/65 KA tripping range
	Breaking current (in KA)	10 KA, 16 KA, 25 KA, 35 KA, 50 KA, 60 KA, 100 KA, 18 KA, 36 KA, 20 ka, 65 KA, 56 KA, 70 KA
	Rated Voltage	240 Volt 50 Hz AC, 240/415 Volt 50 Hz AC, 415 volt 50 Hz, 220VDC

**Additional Specification Parameters - Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 ( 5 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	160A MCCB, C-Curve, 4Pole 4PP, 415Volt, 25KA, without enclosure, IS marked

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106,IIT Patna, Kanpa Road, Bihta	5	15

**Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 ( 2 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	YES, NO
	Rated Current (in Ampere)	32A, 50A, 63A, 80A, 100A, 125A, 160A, 200A, 225A, 250A, 320A, 400A, 500A, 630A, 16A, 20A, 25A, 1000 A, 800 A, 1250 A, 1300 A
	No of poles/Protected poles(PP)	1 Pole, 2 Pole, 3 Pole, 4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity 10/16 KA tripping range, MCCB with RSCB capacity of 10/16/25/35 KA tripping range, 35 KA, MCCB with RSCB capacity of 10/16/25/35/50/65 KA tripping range
	Breaking current (in KA)	10 KA, 16 KA, 25 KA, 35 KA, 50 KA, 60 KA, 100 KA, 18 KA, 36 KA, 20 ka, 65 KA, 56 KA, 70 KA
	Rated Voltage	240 Volt 50 Hz AC, 240/415 Volt 50 Hz AC, 415 volt 50 Hz, 220VDC

**Additional Specification Parameters - Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 ( 2 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	250A MCCB, C-Curve, 4Pole 4PP, 415Volt, 25KA, without enclosure, IS marked

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106,IIT Patna, Kanpa Road, Bihta	2	15

**PVC Copper Cable Single Core And Multi Core Circular Sheathed Cord With Flexible Conductor (V2) As Per IS 694 ( 2000 meter )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	<b>Category of Cable (As per Cl 1.1 of IS 694)</b>	01, 02, FR, FR-LSH
	<b>Conductor material (shall conforming to IS:8130 )</b>	Annealed Tinned Copper, Annealed Bare Copper
	<b>Nominal Cross Sectional Area of Conductor (in Sq mm)</b>	0.5, 0.75, 1.0, 1.5, 2.5
	<b>Type of Insulation (shall conforming to IS:5831)</b>	Type D, Type C (HR)
	<b>No of core</b>	1 Core, 2 Core, 3 Core, 4 Core, 5 Core
	<b>Sheath type</b>	Type ST3, Type ST2 (HR)
CERTIFICATIONS	<b>Availability of Test Certificates from any OEM, Govt Lab, NABL Accredited Lab</b>	Yes, No
	<b>Agree to provide all relevant documents including Test Report/supporting document / reports / BIS certificate etc to the buyer at the time of bidding or on demand</b>	Yes, No

**Additional Specification Parameters - PVC Copper Cable Single Core And Multi Core Circular Sheathed Cord With Flexible Conductor (V2) As Per IS 694 ( 2000 meter )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	2.5SQMM, Copper conductor, multi stranded, PVC Insulated, FRLSH, Single core cable. ISI Marked, IS 694.

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106,IIT Patna, Kanpa Road, Bihta	2000	15

**LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) ( 10 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	<b>LED Rating/System Wattage/Rated Power (in Watts)</b>	30, 40, 50, 60, 70, 80, 90, 100, 120, 150, 175, 180, 200, 250, 300, 350, 400, 450, 500, 600, 700, 750, 800, 900, 1000

**Additional Specification Parameters - LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) ( 10 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	400W, LED Flood light, 6000K Temperature, efficacy >100lm/w, IP66, CRI >70, 50000Hrs life.

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106, IIT Patna, Kanpa Road, Bihta	10	15

**LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) ( 30 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	<b>LED Rating/System Wattage/Rated Power (in Watts)</b>	30, 40, 50, 60, 70, 80, 90, 100, 120, 150, 175, 180, 200, 250, 300, 350, 400, 450, 500, 600, 700, 750, 800, 900, 1000

**Additional Specification Parameters - LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) ( 30 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	200W, LED Flood light, 6000K Temperature, efficacy >100lm/w, IP66, CRI >70, 50000Hrs life.

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106,IIT Patna, Kanpa Road, Bihta	30	15

**LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) ( 30 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	<b>LED Rating/System Wattage/Rated Power (in Watts)</b>	30, 40, 50, 60, 70, 80, 90, 100, 120, 150, 175, 180, 200, 250, 300, 350, 400, 450, 500, 600, 700, 750, 800, 900, 1000

**Additional Specification Parameters - LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) ( 30 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	60W, LED Flood light, 6000K Temperature, efficacy >100lm/w, IP66, CRI >70, 50000Hrs life.

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajvardhan Jaideva	801106,IIT Patna, Kanpa Road, Bihta	30	15

## क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

### 1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be  $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$ , subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

### 2. Generic

While generating invoice in GeM portal, the seller must upload scanned copy of GST invoice and the screenshot of GST portal confirming payment of GST.

### 3. Scope of Supply

Scope of supply (Bid price to include all cost components) : Only supply of Goods

### 4. Turnover

Bidder Turn Over Criteria: The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

### 5. Turnover

OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria. In case of bunch bids, the OEM of CATEGORY RELATED TO primary product having highest bid value should meet this criterion.

### 6. Service & Support

Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.

## 7. Service & Support

Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.

## 8. Service & Support

Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.

## अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

**All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.**

**For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.**

**The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:**

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

**All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.**

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्यवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

**---धन्यवाद/Thank You---**