

**बिड दस्तावेज़ / Bid Document**

| बिड विवरण/Bid Details   |   |
|---|---|
| बिड बंद होने की तारीख/समय /Bid End Date/Time  | 08-05-2026 14:00:00   |
| बिड खुलने की तारीख/समय /Bid Opening Date/Time   | 08-05-2026 14:30:00   |
| बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)   | 180 (Days)  |
| मंत्रालय/राज्य का नाम/Ministry/State Name   | Ministry Of Power   |
| विभाग का नाम/Department Name  | Bhakra Beas Managemet Board   |
| संगठन का नाम/Organisation Name  | Bhakra Beas Management Board  |
| कार्यालय का नाम/Office Name   | Bhakra Beas Management Board, Chandigarh  |
| कुल मात्रा/Total Quantity   | 62  |
| वस्तु श्रेणी /Item Category   | Cable Joint Kit Suitable for Cables Up to and Including 33 kV (V2) (Q3) , Cable Termination Kit Suitable for Cables Up to and Including 33 kV (V2) (Q3)   |
| वर्षों के अनुभव एवं टर्नओवर से एमएसई को छूट प्राप्त है / MSE Relaxation for Years Of Experience and Turnover  | Yes   Complete  |
| स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / Startup Relaxation for Years Of Experience and Turnover  | Yes   Complete  |
| विक्रेता से मांगे गए दस्तावेज़/Document required from seller  | OEM Authorization Certificate<br>*In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer |
| क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/Do you want to show documents uploaded by bidders to all bidders participated in bid? | Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)  |
| बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या   / Minimum number of bids required to disable automatic bid extension  | 3   |

| बिड विवरण/Bid Details  |  |
|--|--|
| दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended  | 7  |
| ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count  | 2  |
| बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled   | No   |
| बिड का प्रकार/Type of Bid  | Two Packet Bid   |
| प्राथमिक उत्पाद श्रेणी/Primary product category  | Cable Joint Kit Suitable for Cables Up to and Including 33 kV (V2) |
| तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation  | 3 Days   |
| निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM) | No   |
| मूल्यांकन पद्धति/Evaluation Method   | Total value wise evaluation  |
| मध्यस्थता खंड/Arbitration Clause   | No   |
| सुलह खंड/Mediation Clause  | No   |

#### ईएमडी विवरण/EMD Detail

|                   |    |
|-------------------|----|
| आवश्यकता/Required | No |
|-------------------|----|

#### ईपीबीजी विवरण /ePBG Detail

|                   |    |
|-------------------|----|
| आवश्यकता/Required | No |
|-------------------|----|

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

#### एमआईआई खरीद वरीयता / MII Purchase Preference

|  |     |
|--|-----|
| एमआईआई खरीद वरीयता / MII Purchase Preference   | Yes |
| मेक इन इंडिया विक्रेताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में है / Purchase Preference to MII sellers available upto price within L1+X% | 20  |
| मेक इन इंडिया खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MII purchase preference                      | 50  |

## एमएसई खरीद वरीयता/MSE Purchase Preference

|  |     |
|--|-----|
| एमएसई खरीद वरीयता/MSE Purchase Preference  | Yes |
| सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within L1+X% | 15  |
| सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference                          | 25  |

1. If the bidder is a Micro or Small Enterprise as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Experience Criteria" as defined above subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Experience Criteria, shall upload the supporting documents to prove his eligibility for Relaxation.
2. If the bidder is a Micro or Small Enterprise (MSE) as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Bidder Turnover" as defined above subject to meeting of quality and technical specifications. If the bidder itself is MSE OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover, shall upload the supporting documents to prove his eligibility for Relaxation.
3. If the bidder is a DPIIT registered Startup, the bidder shall be relaxed from the the eligibility criteria of "Experience Criteria" as defined above subject to their meeting of quality and technical specifications. The bidder seeking Relaxation from Experience Criteria, shall upload the supporting documents to prove his eligibility for Relaxation.
4. If the bidder is a DPIIT registered Startup, the bidder shall be relaxed from the the eligibility criteria of "Bidder Turnover" as defined above subject to their meeting of quality and technical specifications. If the bidder is DPIIT Registered OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover shall upload the supporting documents to prove his eligibility for Relaxation.
5. Preference to Make In India products (For bids < 200 Crore):Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate.The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.
6. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of

purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

### **Cable Joint Kit Suitable For Cables Up To And Including 33 KV (V2) ( 5 set )**

**(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)**

#### **तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

| <b>विवरण/Specification</b> | <b>विशिष्टि का नाम /Specification Name</b>  | <b>बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)</b>   |
|----------------------------|---|--|
| STANDARD                   | <b>Conformity of the specification</b>  | As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV   |
|                            | <b>Type of joint kit</b>  | Non Rigid - Straight Joint - Heat Shrink   |
| GENERIC                    | <b>Applicable conductors for using the joint kits</b>   | Copper   |
|                            | <b>The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]</b>                      | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                            | <b>Applicable cable core for using the joint kits (in Nos)</b>  | 3  |
|                            | <b>Applicable cable size for using the joint kits (in sq mm)</b>  | 300  |
|                            | <b>Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet |

**प्रेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 5                | 30                           |

### Cable Termination Kit Suitable For Cables Up To And Including 33 KV (V2) ( 4 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV   |
|                     | <b>Type of termination kit</b>  | Outdoor Termination - Heat Shrink  |
| GENERIC             | <b>Applicable conductors for using the termination kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]</b>                    | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the termination kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the termination kits (in sq mm)</b>  | 300  |
|                     | <b>Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Anti Tracking Tubing, Heat Shrink Cable Breakout, Heat Shrink Lug Sealing Tubing, Copper Earthing Tinned Braid With Crimped Lug, Copper Tinned Earthing Braid, Solder, Flux, Jubilee Clamp, Backup Ring, Mastic Tapes, Connector (Lugs), PVC (A) Tape, Amalgamating Insulation Tape for Lug Sealing, Core Cleaning Solvent, Semiconductor Paint, Silicon Grease, Nylon String, Aloxite Tape, Tinned Copper Binding Wire, Mopping Cloth, , Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 4                | 30                           |

### Cable Joint Kit Suitable For Cables Up To And Including 33 KV (V2) ( 4 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV   |
|                     | <b>Type of joint kit</b>  | Non Rigid - Straight Joint - Heat Shrink   |
| GENERIC             | <b>Applicable conductors for using the joint kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]</b>                      | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the joint kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the joint kits (in sq mm)</b>  | 95   |
|                     | <b>Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 4                | 30                           |

### Cable Joint Kit Suitable For Cables Up To And Including 33 KV (V2) ( 2 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV   |
|                     | <b>Type of joint kit</b>  | Non Rigid - Straight Joint - Heat Shrink   |
| GENERIC             | <b>Applicable conductors for using the joint kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]</b>                      | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the joint kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the joint kits (in sq mm)</b>  | 25   |
|                     | <b>Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 2                | 30                           |

### Cable Termination Kit Suitable For Cables Up To And Including 33 KV (V2) ( 2 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV   |
|                     | <b>Type of termination kit</b>  | Indoor Termination - Heat Shrink   |
| GENERIC             | <b>Applicable conductors for using the termination kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]</b>                    | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the termination kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the termination kits (in sq mm)</b>  | 25   |
|                     | <b>Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Anti Tracking Tubing, Heat Shrink Cable Breakout, Heat Shrink Lug Sealing Tubing, Copper Earthing Tinned Braid With Crimped Lug, Copper Tinned Earthing Braid, Solder, Flux, Jubilee Clamp, Backup Ring, Mastic Tapes, Connector (Lugs), PVC (A) Tape, Amalgamating Insulation Tape for Lug Sealing, Core Cleaning Solvent, Semiconductor Paint, Silicon Grease, Nylon String, Aloxite Tape, Tinned Copper Binding Wire, Mopping Cloth, , Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 2                | 30                           |

### Cable Joint Kit Suitable For Cables Up To And Including 33 KV (V2) ( 2 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 1) Working Voltages from 1.1 kV up to and including 3.3 kV   |
|                     | <b>Type of joint kit</b>  | Non Rigid - Straight Joint - Heat Shrink   |
| GENERIC             | <b>Applicable conductors for using the joint kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]</b>                      | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the joint kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the joint kits (in sq mm)</b>  | 50   |
|                     | <b>Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 2                | 30                           |

### Cable Termination Kit Suitable For Cables Up To And Including 33 KV (V2) ( 1 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV   |
|                     | <b>Type of termination kit</b>  | Indoor Termination - Heat Shrink   |
| GENERIC             | <b>Applicable conductors for using the termination kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]</b>                    | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the termination kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the termination kits (in sq mm)</b>  | 50   |
|                     | <b>Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Anti Tracking Tubing, Heat Shrink Cable Breakout, Heat Shrink Lug Sealing Tubing, Copper Earthing Tinned Braid With Crimped Lug, Copper Tinned Earthing Braid, Solder, Flux, Jubilee Clamp, Backup Ring, Mastic Tapes, Connector (Lugs), PVC (A) Tape, Amalgamating Insulation Tape for Lug Sealing, Core Cleaning Solvent, Semiconductor Paint, Silicon Grease, Nylon String, Aloxite Tape, Tinned Copper Binding Wire, Mopping Cloth, , Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 1                | 30                           |

### Cable Joint Kit Suitable For Cables Up To And Including 33 KV (V2) ( 3 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV   |
|                     | <b>Type of joint kit</b>  | Non Rigid - Straight Joint - Heat Shrink   |
| GENERIC             | <b>Applicable conductors for using the joint kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]</b>                      | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the joint kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the joint kits (in sq mm)</b>  | 185  |
|                     | <b>Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 3                | 30                           |

### Cable Termination Kit Suitable For Cables Up To And Including 33 KV (V2) ( 3 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV   |
|                     | <b>Type of termination kit</b>  | Indoor Termination - Heat Shrink   |
| GENERIC             | <b>Applicable conductors for using the termination kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]</b>                    | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the termination kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the termination kits (in sq mm)</b>  | 185  |
|                     | <b>Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Anti Tracking Tubing, Heat Shrink Cable Breakout, Heat Shrink Lug Sealing Tubing, Copper Earthing Tinned Braid With Crimped Lug, Copper Tinned Earthing Braid, Solder, Flux, Jubilee Clamp, Backup Ring, Mastic Tapes, Connector (Lugs), PVC (A) Tape, Amalgamating Insulation Tape for Lug Sealing, Core Cleaning Solvent, Semiconductor Paint, Silicon Grease, Nylon String, Aloxite Tape, Tinned Copper Binding Wire, Mopping Cloth, , Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 3                | 30                           |

### Cable Termination Kit Suitable For Cables Up To And Including 33 KV (V2) ( 1 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV   |
|                     | <b>Type of termination kit</b>  | Outdoor Termination - Heat Shrink  |
| GENERIC             | <b>Applicable conductors for using the termination kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]</b>                    | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the termination kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the termination kits (in sq mm)</b>  | 185  |
|                     | <b>Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Anti Tracking Tubing, Heat Shrink Cable Breakout, Heat Shrink Lug Sealing Tubing, Copper Earthing Tinned Braid With Crimped Lug, Copper Tinned Earthing Braid, Solder, Flux, Jubilee Clamp, Backup Ring, Mastic Tapes, Connector (Lugs), PVC (A) Tape, Amalgamating Insulation Tape for Lug Sealing, Core Cleaning Solvent, Semiconductor Paint, Silicon Grease, Nylon String, Aloxite Tape, Tinned Copper Binding Wire, Mopping Cloth, , Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 1                | 30                           |

### Cable Joint Kit Suitable For Cables Up To And Including 33 KV (V2) ( 2 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 1) Working Voltages from 1.1 kV up to and including 3.3 kV   |
|                     | <b>Type of joint kit</b>  | Non Rigid - Straight Joint - Heat Shrink   |
| GENERIC             | <b>Applicable conductors for using the joint kits</b>   | Aluminium  |
|                     | <b>The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]</b>                      | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the joint kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the joint kits (in sq mm)</b>  | 185  |
|                     | <b>Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 2                | 30                           |

### Cable Termination Kit Suitable For Cables Up To And Including 33 KV (V2) ( 2 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 1) Working Voltages from 1.1 kV up to and including 3.3 kV   |
|                     | <b>Type of termination kit</b>  | Indoor Termination - Heat Shrink   |
| GENERIC             | <b>Applicable conductors for using the termination kits</b>   | Aluminium  |
|                     | <b>The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]</b>                    | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the termination kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the termination kits (in sq mm)</b>  | 185  |
|                     | <b>Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Anti Tracking Tubing, Heat Shrink Cable Breakout, Heat Shrink Lug Sealing Tubing, Copper Earthing Tinned Braid With Crimped Lug, Copper Tinned Earthing Braid, Solder, Flux, Jubilee Clamp, Backup Ring, Mastic Tapes, Connector (Lugs), PVC (A) Tape, Amalgamating Insulation Tape for Lug Sealing, Core Cleaning Solvent, Semiconductor Paint, Silicon Grease, Nylon String, Aloxite Tape, Tinned Copper Binding Wire, Mopping Cloth, , Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 2                | 30                           |

### Cable Joint Kit Suitable For Cables Up To And Including 33 KV (V2) ( 4 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 1) Working Voltages from 1.1 kV up to and including 3.3 kV   |
|                     | <b>Type of joint kit</b>  | Non Rigid - Straight Joint - Heat Shrink   |
| GENERIC             | <b>Applicable conductors for using the joint kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]</b>                      | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the joint kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the joint kits (in sq mm)</b>  | 300  |
|                     | <b>Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 4                | 30                           |

### Cable Termination Kit Suitable For Cables Up To And Including 33 KV (V2) ( 2 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV   |
|                     | <b>Type of termination kit</b>  | Indoor Termination - Heat Shrink   |
| GENERIC             | <b>Applicable conductors for using the termination kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]</b>                    | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the termination kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the termination kits (in sq mm)</b>  | 300  |
|                     | <b>Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Anti Tracking Tubing, Heat Shrink Cable Breakout, Heat Shrink Lug Sealing Tubing, Copper Earthing Tinned Braid With Crimped Lug, Copper Tinned Earthing Braid, Solder, Flux, Jubilee Clamp, Backup Ring, Mastic Tapes, Connector (Lugs), PVC (A) Tape, Amalgamating Insulation Tape for Lug Sealing, Core Cleaning Solvent, Semiconductor Paint, Silicon Grease, Nylon String, Aloxite Tape, Tinned Copper Binding Wire, Mopping Cloth, , Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 2                | 30                           |

### Cable Joint Kit Suitable For Cables Up To And Including 33 KV (V2) ( 1 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV   |
|                     | <b>Type of joint kit</b>  | Non Rigid - Straight Joint - Heat Shrink   |
| GENERIC             | <b>Applicable conductors for using the joint kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]</b>                      | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the joint kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the joint kits (in sq mm)</b>  | 150  |
|                     | <b>Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 1                | 30                           |

### Cable Termination Kit Suitable For Cables Up To And Including 33 KV (V2) ( 1 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV   |
|                     | <b>Type of termination kit</b>  | Indoor Termination - Heat Shrink   |
| GENERIC             | <b>Applicable conductors for using the termination kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]</b>                    | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the termination kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the termination kits (in sq mm)</b>  | 150  |
|                     | <b>Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Anti Tracking Tubing, Heat Shrink Cable Breakout, Heat Shrink Lug Sealing Tubing, Copper Earthing Tinned Braid With Crimped Lug, Copper Tinned Earthing Braid, Solder, Flux, Jubilee Clamp, Backup Ring, Mastic Tapes, Connector (Lugs), PVC (A) Tape, Amalgamating Insulation Tape for Lug Sealing, Core Cleaning Solvent, Semiconductor Paint, Silicon Grease, Nylon String, Aloxite Tape, Tinned Copper Binding Wire, Mopping Cloth, , Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 1                | 30                           |

### Cable Termination Kit Suitable For Cables Up To And Including 33 KV (V2) ( 1 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 1) Working Voltages from 1.1 kV up to and including 3.3 kV   |
|                     | <b>Type of termination kit</b>  | Outdoor Termination - Heat Shrink  |
| GENERIC             | <b>Applicable conductors for using the termination kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]</b>                    | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the termination kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the termination kits (in sq mm)</b>  | 150  |
|                     | <b>Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Anti Tracking Tubing, Heat Shrink Cable Breakout, Heat Shrink Lug Sealing Tubing, Copper Earthing Tinned Braid With Crimped Lug, Copper Tinned Earthing Braid, Solder, Flux, Jubilee Clamp, Backup Ring, Mastic Tapes, Connector (Lugs), PVC (A) Tape, Amalgamating Insulation Tape for Lug Sealing, Core Cleaning Solvent, Semiconductor Paint, Silicon Grease, Nylon String, Aloxite Tape, Tinned Copper Binding Wire, Mopping Cloth, , Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 1                | 30                           |

### Cable Joint Kit Suitable For Cables Up To And Including 33 KV (V2) ( 6 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 1) Working Voltages from 1.1 kV up to and including 3.3 kV   |
|                     | <b>Type of joint kit</b>  | Non Rigid - Straight Joint - Heat Shrink   |
| GENERIC             | <b>Applicable conductors for using the joint kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]</b>                      | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the joint kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the joint kits (in sq mm)</b>  | 120  |
|                     | <b>Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 6                | 30                           |

### Cable Termination Kit Suitable For Cables Up To And Including 33 KV (V2) ( 4 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV   |
|                     | <b>Type of termination kit</b>  | Indoor Termination - Heat Shrink   |
| GENERIC             | <b>Applicable conductors for using the termination kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]</b>                    | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the termination kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the termination kits (in sq mm)</b>  | 120  |
|                     | <b>Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Anti Tracking Tubing, Heat Shrink Cable Breakout, Heat Shrink Lug Sealing Tubing, Copper Earthing Tinned Braid With Crimped Lug, Copper Tinned Earthing Braid, Solder, Flux, Jubilee Clamp, Backup Ring, Mastic Tapes, Connector (Lugs), PVC (A) Tape, Amalgamating Insulation Tape for Lug Sealing, Core Cleaning Solvent, Semiconductor Paint, Silicon Grease, Nylon String, Aloxite Tape, Tinned Copper Binding Wire, Mopping Cloth, , Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 4                | 30                           |

### Cable Termination Kit Suitable For Cables Up To And Including 33 KV (V2) ( 2 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV   |
|                     | <b>Type of termination kit</b>  | Outdoor Termination - Heat Shrink  |
| GENERIC             | <b>Applicable conductors for using the termination kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]</b>                    | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the termination kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the termination kits (in sq mm)</b>  | 120  |
|                     | <b>Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Anti Tracking Tubing, Heat Shrink Cable Breakout, Heat Shrink Lug Sealing Tubing, Copper Earthing Tinned Braid With Crimped Lug, Copper Tinned Earthing Braid, Solder, Flux, Jubilee Clamp, Backup Ring, Mastic Tapes, Connector (Lugs), PVC (A) Tape, Amalgamating Insulation Tape for Lug Sealing, Core Cleaning Solvent, Semiconductor Paint, Silicon Grease, Nylon String, Aloxite Tape, Tinned Copper Binding Wire, Mopping Cloth, , Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 2                | 30                           |

### Cable Joint Kit Suitable For Cables Up To And Including 33 KV (V2) ( 3 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV   |
|                     | <b>Type of joint kit</b>  | Non Rigid - Straight Joint - Heat Shrink   |
| GENERIC             | <b>Applicable conductors for using the joint kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]</b>                      | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the joint kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the joint kits (in sq mm)</b>  | 35   |
|                     | <b>Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 3                | 30                           |

### Cable Termination Kit Suitable For Cables Up To And Including 33 KV (V2) ( 1 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV   |
|                     | <b>Type of termination kit</b>  | Indoor Termination - Heat Shrink   |
| GENERIC             | <b>Applicable conductors for using the termination kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]</b>                    | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the termination kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the termination kits (in sq mm)</b>  | 35   |
|                     | <b>Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Anti Tracking Tubing, Heat Shrink Cable Breakout, Heat Shrink Lug Sealing Tubing, Copper Earthing Tinned Braid With Crimped Lug, Copper Tinned Earthing Braid, Solder, Flux, Jubilee Clamp, Backup Ring, Mastic Tapes, Connector (Lugs), PVC (A) Tape, Amalgamating Insulation Tape for Lug Sealing, Core Cleaning Solvent, Semiconductor Paint, Silicon Grease, Nylon String, Aloxite Tape, Tinned Copper Binding Wire, Mopping Cloth, , Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 1                | 30                           |

### Cable Termination Kit Suitable For Cables Up To And Including 33 KV (V2) ( 1 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV   |
|                     | <b>Type of termination kit</b>  | Outdoor Termination - Heat Shrink  |
| GENERIC             | <b>Applicable conductors for using the termination kits</b>   | Copper   |
|                     | <b>The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]</b>                    | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the termination kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the termination kits (in sq mm)</b>  | 35   |
|                     | <b>Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Anti Tracking Tubing, Heat Shrink Cable Breakout, Heat Shrink Lug Sealing Tubing, Copper Earthing Tinned Braid With Crimped Lug, Copper Tinned Earthing Braid, Solder, Flux, Jubilee Clamp, Backup Ring, Mastic Tapes, Connector (Lugs), PVC (A) Tape, Amalgamating Insulation Tape for Lug Sealing, Core Cleaning Solvent, Semiconductor Paint, Silicon Grease, Nylon String, Aloxite Tape, Tinned Copper Binding Wire, Mopping Cloth, , Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 1                | 30                           |

### Cable Joint Kit Suitable For Cables Up To And Including 33 KV (V2) ( 3 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 1) Working Voltages from 1.1 kV up to and including 3.3 kV   |
|                     | <b>Type of joint kit</b>  | Non Rigid - Straight Joint - Heat Shrink   |
| GENERIC             | <b>Applicable conductors for using the joint kits</b>   | Aluminium  |
|                     | <b>The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]</b>                      | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the joint kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the joint kits (in sq mm)</b>  | 240  |
|                     | <b>Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1             | Kaushal Kumar Prajapat                                  | 140124,Bhakra Beas Management Board, XEN STORE POWER WING NANGAL | 3                | 30                           |

### Cable Termination Kit Suitable For Cables Up To And Including 33 KV (V2) ( 2 set )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|---|--|
| STANDARD            | <b>Conformity of the specification</b>  | As per IS 13573 (Part 1) Working Voltages from 1.1 kV up to and including 3.3 kV   |
|                     | <b>Type of termination kit</b>  | Indoor Termination - Heat Shrink   |
| GENERIC             | <b>Applicable conductors for using the termination kits</b>   | Aluminium  |
|                     | <b>The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]</b>                    | XLPE (Range of approval: XLPE, EPR, HEPR, PVC)   |
|                     | <b>Applicable cable core for using the termination kits (in Nos)</b>  | 3  |
|                     | <b>Applicable cable size for using the termination kits (in sq mm)</b>  | 240  |
|                     | <b>Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)</b> | Heat Shrink Stress Control Tubing, Heat Shrink Anti Tracking Tubing, Heat Shrink Cable Breakout, Heat Shrink Lug Sealing Tubing, Copper Earthing Tinned Braid With Crimped Lug, Copper Tinned Earthing Braid, Solder, Flux, Jubilee Clamp, Backup Ring, Mastic Tapes, Connector (Lugs), PVC (A) Tape, Amalgamating Insulation Tape for Lug Sealing, Core Cleaning Solvent, Semiconductor Paint, Silicon Grease, Nylon String, Aloxite Tape, Tinned Copper Binding Wire, Mopping Cloth, , Instruction Sheet |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.N<br>o. | परेषिती/रिपोर्टिंग<br>अधिकारी /Consignee<br>Reporting/Officer | पता/Address  | मात्रा /Quantity | डिलीवरी के दिन/Delivery<br>Days |
|-------------------|---|--|------------------|---------------------------------|
| 1                 | Kaushal Kumar<br>Prajapat                                     | 140124,Bhakra Beas<br>Management Board, XEN<br>STORE POWER WING NANGAL | 2                | 30                              |

## क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

### 1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be  $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$ , subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

### 2. Scope of Supply

Scope of supply (Bid price to include all cost components) : Only supply of Goods

### 3. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

## अस्वीकरण/Disclaimer

The Additional Terms and Conditions (ATC) have been incorporated by the Buyer after approval of their Competent Authority. The Buyer ,is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any restriction arising in the bidding process due to these ATCs and including the modification of technical specifications and / or terms and conditions governing the bid.All representations / grievances pertaining to the ATC clauses shall be raised with the buyer organization directly and not with GeM.If any of the clause(s) is/are incorporated by the Buyer regarding the following, the bid & resultant contract shall be treated as null & void. Further, GeM reserves the right, at its sole discretion, to cancel the bid forthwith, without issuance of any prior notice or intimation :-

1. Publishing Custom / BOQ bids for items for which regular GeM categories are available (unless such Custom / BOQ item is bunched with the major regular product Category Item).
2. Mandating procurement of / from specific Brand / Make / Model / Manufacturer / Dealer except in case of Single Bid / Proprietary Article Certificate (PAC) Buying.
3. Inclusion of disqualification criteria related to suspension of seller / service provider, where such suspension period has already expired.
4. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
5. Publishing bids on GeM for procurement of works.
6. Procurement of Goods by creating a Service bid on GeM & vice-versa.
7. Seeking sample with bid or approval of samples during bid evaluation process. However, trial / sample, as the case may be, shall be permitted in cases where trial / sample are allowed as per approved and published procurement policy of the Buyers' controlling Ministry / Department / State / Public Sector Enterprises Headquarters. If there is any violation of trial / sample clause with regard to approved policy

of the Buyers' Ministry / Department / State / Public Sector Enterprises Headquarters, then this is to be determined and redressed by the concerned Buyer Organisation only.

8. Seeking experience from specific organization / department / institute only or from foreign / export experience.
9. Creating bid for items from incorrect categories.
10. Reference of conditions published on any external site or reference to external documents/clauses.
11. Asking for any Tender fee / Bid Participation fee, as the case may be.
12. Buyer added ATC Clauses which are in contravention of clauses defined in bid detail section, including specifications, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by the applicable GeM GTC.
13. Any ATC clause in contravention with GeM GTC Clause 4 (xiii) (h) will be invalid. In case of multiple L1 bidders against a service bid, the buyer shall place the Contract by selection of a bidder amongst the L-1 bidders through a Random Algorithm executed by GeM system.
14. In a category based bid, adding additional items, through buyer added, additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogues or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

**All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.**

**For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.**

**The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:**

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

**All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.**

**This Bid is governed by the General Terms and Conditions, conditions stipulated in Bid and Service Level Agreement specific to the Service, as the case may be, as provided in the Marketplace.**

**However, in case of Service, if any condition specified in General Terms and Conditions is contradicted by the conditions stipulated in Service Level Agreement specific to said Service, then it will over-ride the conditions in the General Terms and Conditions.**

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने

व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

**---धन्यवाद/Thank You---**