

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	18-05-2026 17:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	18-05-2026 17:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	180 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Agriculture And Farmers Welfare
विभाग का नाम/Department Name	Department Of Agricultural Research And Education (dare)
संगठन का नाम/Organisation Name	Indian Council Of Agricultural Research (icar)
कार्यालय का नाम/Office Name	Central Institute Of Brakishwater Aquaculture
कुल मात्रा/Total Quantity	56
वस्तु श्रेणी /Item Category	Split Air Conditioner, Wall Mount Type (V3) ISI Marked to IS 1391 (Part 2) (Q2) , Automatic Line Voltage Correctors (Step Type) For Domestic Use (Stabilizer) Conforming To IS 8448 (Q2)
बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का) /Minimum Average Annual Turnover of the bidder (For 3 Years)	8 Lakh (s)
मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का)/OEM Average Turnover (Last 3 Years)	40 Lakh (s)
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष/Years of Past Experience Required for same/similar service	3 Year (s)
वर्षों के अनुभव एवं टर्नओवर से एमएसई को छूट प्राप्त है / MSE Relaxation for Years Of Experience and Turnover	Yes Complete
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / Startup Relaxation for Years Of Experience and Turnover	Yes Complete
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover,Additional Doc 1 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer

बिड विवरण/Bid Details	
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेन् है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	1
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	3
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	1
विगत प्रदर्शन /Past Performance	50 %
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	No
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	Split Air Conditioner, Wall Mount Type (V3) ISI Marked to IS 1391 (Part 2)
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	3 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation

ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईएमडी राशि/EMD Amount	45000

ईपीबीजी विवरण /ePBG Detail

आवश्यकता/Required	No
-------------------	----

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित कटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने है। एमएसई कटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document

for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

लाभार्थी /Beneficiary :

The Director

Central Institute Of Brakishwater Aquaculture, Department of Agricultural Research and Education (DARE), Indian Council of Agricultural Research (ICAR), Ministry of Agriculture and Farmers Welfare
(Icar Unit Ciba)

बोली विभाजन लागू नहीं किया गया/Bid splitting not applied.

1. If the bidder is a Micro or Small Enterprise as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Experience Criteria" as defined above subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Experience Criteria, shall upload the supporting documents to prove his eligibility for Relaxation.
2. If the bidder is a Micro or Small Enterprise (MSE) as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Bidder Turnover" as defined above subject to meeting of quality and technical specifications. If the bidder itself is MSE OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover, shall upload the supporting documents to prove his eligibility for Relaxation.
3. If the bidder is a DPIIT registered Startup, the bidder shall be relaxed from the the eligibility criteria of "Experience Criteria" as defined above subject to their meeting of quality and technical specifications. The bidder seeking Relaxation from Experience Criteria, shall upload the supporting documents to prove his eligibility for Relaxation.
4. If the bidder is a DPIIT registered Startup, the bidder shall be relaxed from the the eligibility criteria of "Bidder Turnover" as defined above subject to their meeting of quality and technical specifications. If the bidder is DPIIT Registered OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover shall upload the supporting documents to prove his eligibility for Relaxation.
5. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
6. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.
7. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
8. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 50% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

Split Air Conditioner, Wall Mount Type (V3) ISI Marked To IS 1391 (Part 2) (9 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Description of Stores	Wall Mount Type Split Air Conditioner with copper evaporator and condenser, reusable air filter and standard accessories [3 meter Refrigerant Interconnecting Copper Pipe, 1 meter PVC insulated sheathed power cable(as per IS 694), Drain pipe, Remote]
	Size of Air Conditioner	Medium [suitable for room area between 130-180 sq. ft.]
	Compressor Type as per BEE Star Rating Label	Inverter - Variable Speed
	Nominal Capacity of Air Conditioner (in Ton)	1.3 Ton - 1.7 Ton
	Classification By Function	Cooling Only
	BEE Star Rating	3 Star, 4 Star, 5 Star
Warranty and Test Reports	Minimum Standard Warranty on Air Conditioner (in years)	1.0 (year)
	Warranty on Compressor	10.0 Or higher (year)
	Warranty on PCB	1, 5 Or higher (year)

Additional Specification Parameters - Split Air Conditioner, Wall Mount Type (V3) ISI Marked To IS 1391 (Part 2) (9 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Supply, installation, testing, and commissioning of latest model (2025-2026) wall-mounted split type inverter AC units 1.5 Ton	Supply, installation, testing, and commissioning of latest model (2025-2026) wall-mounted split type inverter AC units of 3/5-star rating with 100% copper condenser and R-32 refrigerant, including outdoor unit brackets, minimum 4m copper piping, 6m drain pipe, heavy-duty rust-proof outdoor stand, and with minimum 1 or 2-year unit warranty, 5-year PCB warranty, and 10-year compressor warranty.
SPECIFICATIONS	As per specification document attached in ATC

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Aravind R	603112,Muttukadu Experimental Station, Kovalam Post, Muttukadu, Chennai-613112	8	15
2	Karthick S	600028,NO.75, SANTHOME HIGH ROAD, RAJA ANNAMALAIPURAM, CHENNAI	1	15

Buyback Detail

Item Name	Air Conditioner
Item Description	Wall Mount Type Split Air Condition
Serial No.	SE140H02531
Model	Wall Mount Type Split Air Conditioner 1.5 Ton
Brand	Vester, Voltas, Bluestar
Year of Manufacturing	2013
Purchase On	2013-04-01
Age	
Size	3
Rating	
Quantity	7
Unit	Numbers
Remark	Site visit is mandatory for all bidders, during which the existing/old AC units may be inspected, and no claims regarding site conditions will be entertained after tender submission
Uploaded Image	View Uploaded Image

अस्वीकरण/Disclaimer

The vendor will be responsible for the un-installation of Buyback items.

Split Air Conditioner, Wall Mount Type (V3) ISI Marked To IS 1391 (Part 2) (7 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Size of Air Conditioner	Large [suitable for room area greater than 190 sq. ft.]
	Compressor Type as per BEE Star Rating Label	Non-Inverter - Fixed Speed
	Nominal Capacity of Air Conditioner (in Ton)	1.8 Ton - 2.2 Ton
	Classification By Function	Cooling Only
	BEE Star Rating	3 Star
Warranty and Test Reports	Minimum Standard Warranty on Air Conditioner (in years)	1.0 (year)

Additional Specification Parameters - Split Air Conditioner, Wall Mount Type (V3) ISI Marked To IS 1391 (Part 2) (7 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Specifications	As per specification document attached in ATC
Supply, installation, testing, and commissioning of latest model (2025-2026) wall-mounted split type Non-inverter AC units of 3-star rating(Industrial type/Heavy Duty)	Supply, installation, testing, and commissioning of latest model (2025-2026) wall-mounted split type Non-inverter AC units (Industrial type/Heavy Duty) of 3-star rating with 100% copper condenser and R-32 refrigerant, including outdoor unit brackets, minimum 4m copper piping, 6m drain pipe, heavyduty rust-proof outdoor stand, and with minimum 1 or 2-year unit warranty, 10-year compressor warranty.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Aravind R	603112,Muttukadu Experimental Station, Kovalam Post, Muttukadu, Chennai-613112	5	15
2	Karthick S	600028,NO.75, SANTHOME HIGH ROAD, RAJA ANNAMALAIPURAM, CHENNAI	2	15

Split Air Conditioner, Wall Mount Type (V3) ISI Marked To IS 1391 (Part 2) (4 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Description of Stores	Wall Mount Type Split Air Conditioner with copper evaporator and condenser, reusable air filter and standard accessories [3 meter Refrigerant Interconnecting Copper Pipe, 1 meter PVC insulated sheathed power cable(as per IS 694), Drain pipe, Remote]
	Size of Air Conditioner	Medium [suitable for room area between 130-180 sq. ft.]
	Compressor Type as per BEE Star Rating Label	Non-Inverter - Fixed Speed
	Nominal Capacity of Air Conditioner (in Ton)	1.3 Ton - 1.7 Ton
	Classification By Function	Cooling Only
	BEE Star Rating	3 Star
Warranty and Test Reports	Minimum Standard Warranty on Air Conditioner (in years)	1.0 (year)

Additional Specification Parameters - Split Air Conditioner, Wall Mount Type (V3) ISI Marked To IS 1391 (Part 2) (4 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	As per specification document attached in ATC
Supply, installation, testing, and commissioning of latest model (2025-2026) wall-mounted split type Non-inverter AC units (Industrial type/Heavy Duty) of 3-star rating with 100% copper condenser and R-32 refrigerant	Supply, installation, testing, and commissioning of latest model (2025-2026) wall-mounted split type Non-inverter AC units (Industrial type/Heavy Duty) of 3-star rating with 100% copper condenser and R-32 refrigerant, including outdoor unit brackets, minimum 4m copper piping, 6m drain pipe, heavy duty rust-proof outdoor stand, and with minimum 1 or 2-year unit warranty, 10-year compressor warranty.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Aravind R	603112,Muttukadu Experimental Station, Kovalam Post, Muttukadu, Chennai-613112	4	15

**Automatic Line Voltage Correctors (Step Type) For Domestic Use (Stabilizer)
Conforming To IS 8448 (6 pieces)**

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Construction	Rating (in KVA)	4.0
	Provision of Power Supply Cord	Yes, Minimum 1.5 meter cord Provided
	Provision of Plug and Socket	Yes, (3-pin plug on input side and socket on output side of 15 A rating) Provided

Additional Specification Parameters - Automatic Line Voltage Correctors (Step Type) For Domestic Use (Stabilizer) Conforming To IS 8448 (6 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	As per specification document attached in ATC
A 4 kVA voltage stabilizer (approx. 3.2 kW) with an input range of 130V-280V (preferably 90V-300V) and output of 200V-240V (±5%), suitable for 1.5 Ton ACs, Minimum 2year warranty.	A 4 kVA voltage stabilizer (approx. 3.2 kW) with an input range of 130V-280V (preferably 90V-300V) and output of 200V-240V (±5%), suitable for up to 1.5 Ton ACs, digital/relay-based type, with high/low voltage cut-off, overload and thermal protection, 2-3 minute time delay, wall-mounted design, and LED/digital display.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Aravind R	603112,Muttukadu Experimental Station, Kovalam Post, Muttukadu, Chennai-613112	6	15

**Automatic Line Voltage Correctors (Step Type) For Domestic Use (Stabilizer)
Conforming To IS 8448 (12 pieces)**

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Construction	Rating (in KVA)	5.0
	Provision of Power Supply Cord	Yes, Minimum 1.5 meter cord Provided
	Provision of Plug and Socket	Yes, (3-pin plug on input side and socket on output side of 15 A rating) Provided
	Availability of Terminals for Both Input and Output	Yes
	Compliance to Eco-Mark	Yes, No

Additional Specification Parameters - Automatic Line Voltage Correctors (Step Type) For Domestic Use (Stabilizer) Conforming To IS 8448 (12 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Specification	As per specification document attached in ATC
The 5 kVA voltage stabilizer shall have a capacity of 5 kVA with an input voltage range of 130V-300V (wide range preferred) and a stabilized output of 200V-240V ($\pm 5\%$). It shall be suitable for up to 2 Ton air conditioners, Minimum 2 year warranty.	The 5 kVA voltage stabilizer shall have a capacity of 5 kVA (?4 kW), input voltage range of 130V-300V, and output of 200V-240V ($\pm 5\%$). It shall be suitable for up to 2 Ton AC, be digital or servo-controlled, and include high/low voltage cut-off, overload, short circuit, thermal protection, and compressor time delay. It should be wall-mountable and preferably have copper winding for better efficiency and durability.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Aravind R	603112,Muttukadu Experimental Station, Kovalam Post, Muttukadu, Chennai-613112	10	15
2	Karthick S	600028,NO.75, SANTHOME HIGH ROAD, RAJA ANNAMALAI PURAM, CHENNAI	2	15

Split Air Conditioner, Wall Mount Type (V3) ISI Marked To IS 1391 (Part 2) (18 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Description of Stores	Wall Mount Type Split Air Conditioner with copper evaporator and condenser, reusable air filter and standard accessories [3 meter Refrigerant Interconnecting Copper Pipe, 1 meter PVC insulated sheathed power cable(as per IS 694), Drain pipe, Remote]
	Size of Air Conditioner	Large [suitable for room area greater than 190 sq. ft.]
	Compressor Type as per BEE Star Rating Label	Inverter - Variable Speed
	Nominal Capacity of Air Conditioner (in Ton)	1.8 Ton - 2.2 Ton
	Classification By Function	Cooling Only
	BEE Star Rating	3 Star, 4 Star, 5 Star
Warranty and Test Reports	Minimum Standard Warranty on Air Conditioner (in years)	1.0 (year)
	Warranty on Compressor	10.0 Or higher (year)
	Warranty on PCB	1, 5 Or higher (year)

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Aravind R	603112,Muttukadu Experimental Station, Kovalam Post, Muttukadu, Chennai-613112	5	15
2	Karthick S	600028,NO.75, SANTHOME HIGH ROAD, RAJA ANNAMALAIPURAM, CHENNAI	13	15

Buyback Detail

Item Name	Air Conditioner
Item Description	Wall Mount Type Split Air Conditioner
Serial No.	SE140H02475
Model	Wall Mount Type Split Air Conditioner 2.0 Ton
Brand	Hitachi, Voltas, Bluestar , TOSHIBA

Year of Manufacturing	2013
Purchase On	2013-04-01
Age	
Size	3
Rating	
Quantity	17
Unit	Numbers
Remark	Site visit is mandatory for all bidders, during which the existing/old AC units may be inspected, and no claims regarding site conditions will be entertained after tender submission.
Uploaded Image	View Uploaded Image
<p>अस्वीकरण/Disclaimer</p> <p>The vendor will be responsible for the un-installation of Buyback items.</p>	

Special terms and conditions-Version:1 effective from 02-12-2025 for category Split Air Conditioner, Wall Mount Type (V3) ISI Marked to IS 1391 (Part 2)

1. Scope of standard installation and commissioning for Wall Mount Split AC consist of follows:

- a)** Installation/Commissioning is mandatory for all types of purchases (Direct/L1/Bid). For cases where Installation/Commissioning is not required, the buyer may indicate the details in the bid document.
- b)** The Switches/ Sockets/ Plug Tops/ Voltage Stabilizer/stand for ODU/ Chiselling/ Ducting/ Grooving for concealing the refrigerant piping/cabing/ core cutting of the wall are not included in the scope of standard installation and commissioning, unless otherwise mentioned in the contract.

Special terms and conditions-Version:1 effective from 10-10-2025 for category Automatic Line Voltage Correctors (Step Type) For Domestic Use (Stabilizer) Conforming To IS 8448

1. **1.** The marking, construction, safety requirements, terminal marking of Automatic Line Voltage Correctors shall conform to the IS 8448.
- 2.** Presently, the products under this category are not covered under mandatory BIS licensing scheme. Hence, both ISI Marked and non-ISI Marked products may be available in this category. However, if a buyer intends to procure ISI Marked products, buyer may, at his discretion, opt for the same by indicating the requirement in the bid, after taking into account the number of valid licenses issued under the standard. In such cases, buyer shall verify valid BIS License as per the applicable governing standard at the time of evaluation of bid and check the ISI marking on the products at the time of receipt of material before issuing of CRAC.
- The valid BIS license status of sellers may be viewed by buyer from the below link.

<https://www.manakonline.in/MANAK/ApplicationLicenceRelatedrpt>

or

https://www.services.bis.gov.in/php/BIS_2.0/bisconnect/knowyourstandards/indian_standards/isdetails

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. **Generic**

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. **Generic**

Experience Criteria: The Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for 3 years before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the primary product having highest value should meet this criterion.

3. **Generic**

End User Certificate: Wherever Bidders are insisting for End User Certificate from the Buyer, same shall be provided in Buyer's standard format only.

4. **Generic**

Installation, Commissioning, Testing, Configuration, Training (if any - which ever is applicable as per scope of supply) is to be carried out by OEM / OEM Certified resource or OEM authorised Reseller.

5. **Certificates**

The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

6. **Certificates**

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

7. **Service & Support**

Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.

8. **OEM**

IMPORTED PRODUCTS: In case of imported products, OEM or Authorized Seller of OEM should have a registered office in India to provide after sales service support in India. The certificate to this effect should be submitted.

9. **Turnover**

OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria. In case of bunch bids, the OEM of

CATEGORY RELATED TO primary product having highest bid value should meet this criterion.

10. Service & Support

Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.

11. Service & Support

Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.

12. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

13. Forms of EMD and PBG

Bidders can also submit the EMD with Banker's Cheque in favour of

ICAR UNIT CIBA
payable at
CHENNAI

Bidder has to upload scanned copy / proof of the BC along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

14. Forms of EMD and PBG

Bidders can also submit the EMD with Account Payee Demand Draft in favour of

ICAR UNIT CIBA
payable at
CHENNAI

Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

अस्वीकरण/Disclaimer

The Additional Terms and Conditions (ATC) have been incorporated by the Buyer after approval of their Competent Authority. The Buyer ,is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any restriction arising in the bidding process due to these ATCs and including the modification of technical specifications and / or terms and conditions governing the bid.All representations / grievances pertaining to the ATC clauses shall be raised with the buyer organization directly and not with GeM.If any of the clause(s) is/are incorporated by the Buyer regarding the following, the bid & resultant contract shall be treated as null & void. Further, GeM reserves the right, at its sole discretion, to cancel the bid forthwith, without issuance of any prior notice or intimation :-

1. Publishing Custom / BOQ bids for items for which regular GeM categories are available (unless such Custom / BOQ item is bunched with the major regular product Category Item).
2. Mandating procurement of / from specific Brand / Make / Model / Manufacturer / Dealer except in case of Single Bid / Proprietary Article Certificate (PAC) Buying.
3. Inclusion of disqualification criteria related to suspension of seller / service provider, where such suspension period has already expired.
4. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
5. Publishing bids on GeM for procurement of works.
6. Procurement of Goods by creating a Service bid on GeM & vice-versa.
7. Seeking sample with bid or approval of samples during bid evaluation process. However, trial / sample, as the case may be, shall be permitted in cases where trial / sample are allowed as per approved and

published procurement policy of the Buyers' controlling Ministry / Department / State / Public Sector Enterprises Headquarters. If there is any violation of trial / sample clause with regard to approved policy of the Buyers' Ministry / Department / State / Public Sector Enterprises Headquarters, then this is to be determined and redressed by the concerned Buyer Organisation only.

8. Seeking experience from specific organization / department / institute only or from foreign / export experience.
9. Creating bid for items from incorrect categories.
10. Reference of conditions published on any external site or reference to external documents/clauses.
11. Asking for any Tender fee / Bid Participation fee, as the case may be.
12. Buyer added ATC Clauses which are in contravention of clauses defined in bid detail section, including specifications, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by the applicable GeM GTC.
13. Any ATC clause in contravention with GeM GTC Clause 4 (xiii) (h) will be invalid. In case of multiple L1 bidders against a service bid, the buyer shall place the Contract by selection of a bidder amongst the L-1 bidders through a Random Algorithm executed by GeM system.
14. In a category based bid, adding additional items, through buyer added, additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogues or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

This Bid is governed by the General Terms and Conditions, conditions stipulated in Bid and Service Level Agreement specific to the Service, as the case may be, as provided in the Marketplace.

However, in case of Service, if any condition specified in General Terms and Conditions is contradicted by the conditions stipulated in Service Level Agreement specific to said Service, then it will over-ride the conditions in the General Terms and Conditions.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला

सक्षम प्राधिकारी के पास पंजीकृत हो।बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---