

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	10-02-2026 18:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	10-02-2026 18:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	180 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Uttar Pradesh
विभाग का नाम/Department Name	Energy Department Uttar Pradesh
संगठन का नाम/Organisation Name	N/a
कार्यालय का नाम/Office Name	Kesco
कुल मात्रा/Total Quantity	374
वस्तु श्रेणी /Item Category	Cable Termination Kit (V2) (Q3) , Cable Joint Kit (V2) (Q3)
बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का) /Minimum Average Annual Turnover of the bidder (For 3 Years)	26 Lakh (s)
मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का)/OEM Average Turnover (Last 3 Years)	200 Lakh (s)
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष/Years of Past Experience Required for same/similar service	3 Year (s)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Relaxation for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Relaxation for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover,Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC),Additional Doc 3 (Requested in ATC),Additional Doc 4 (Requested in ATC),Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer

बिड विवरण/Bid Details	
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेन् है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	5
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	7
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	3
विगत प्रदर्शन /Past Performance	80 %
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	No
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	Cable Termination Kit (V2)
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
अनुमानित बिड मूल्य /Estimated Bid Value	5219475
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	IDBI Bank
ईएमडी राशि/EMD Amount	52195

ईपीबीजी विवरण /ePBG Detail

एडवाइजरी बैंक/Advisory Bank	IDBI Bank
ईपीबीजी प्रतिशत (%) /ePBG Percentage(%)	5.00

ईपीबीजी की आवश्यक अवधि (माह) /Duration of ePBG required (Months).

48

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित कटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने है। एमएसई कटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

लाभार्थी /Beneficiary :

EE PP
KESCO, Energy Department Uttar Pradesh, N/A,
(Kesco Kanpur)

विभाजन/Splitting

विभाजन/Splitting Applied	Yes
बोलीदाताओं की अधिकतम संख्या, जिनके बीच ऑर्डर विभाजित किया जा सकता है। / Maximum No. Of Bidders Amongst Which Order May Be Split	3
विभाजन मानदंड इस बात पर आधारित है कि कौन सी क्वांटिटी को वितरित किया जाएगा / Split Criteria based on which quantity will be distributed	AS PER MD KESCO

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	No
---	----

एमआईआई खरीद वरीयता/MII Purchase Preference

एमआईआई खरीद वरीयता/MII Purchase Preference	No
--	----

1. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

2. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value

should meet this criterion.

3. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

4. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

5. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 80% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

Cable Termination Kit (V2) (65 set)

तकनीकी विशिष्टियाँ / Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Conformity of the specification	As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV
	Type of termination kit	Outdoor Termination - Heat Shrink
GENERIC	Applicable conductors for using the termination kits	Copper, Aluminium
	The appropriate cable for using the termination kits	Armoured Cable
	The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]	XLPE (Range of approval: XLPE, EPR, HEPR, PVC)
	Applicable cable core for using the termination kits (in Nos)	3, 1
	Applicable cable size for using the termination kits (in sq mm)	70, 500
	Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)	Heat Shrink Stress Control Tubing, Heat Shrink Anti Tracking Tubing, Heat Shrink Cable Breakout, Heat Shrink Lug Sealing Tubing, Copper Earthing Tinned Braid With Crimped Lug, Copper Tinned Earthing Braid, Solder, Flux, Jubilee Clamp, Backup Ring, Mastic Tapes, Connector (Lugs), PVC (A) Tape, Amalgamating Insulation Tape for Lug Sealing, Core Cleaning Solvent, Semiconductor Paint, Silicon Grease, Nylon String, Aloxite Tape, Tinned Copper Binding Wire, Mopping Cloth, , Instruction Sheet

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Rain sheds/creepage extender supplied with termination kit	Yes
CERTIFICATION	Availability of type test report from Central Govt lab/NABL accredited/ILAC accredited lab to prove conformity of the specification	Yes, As per IS 13573 (Part 2 and Part 3)

Additional Specification Parameters - Cable Termination Kit (V2) (65 set)

Specification Parameter Name	Bid Requirement (Allowed Values)
CABLE BOX O/D 11 KV 3 X 70 SQMM XLPE PLZ REFER TECHNICAL DOCS.	CABLE BOX O/D 11 KV 3 X 70 SQMM REFER TECHNICAL DOCS.The technical and financial conditions mentioned in the tender documents shall prevail over the GeM technical and financial conditions.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shrikant Singh Rangila	208001,14/71 CIVIL LINE KESCO KANPUR	65	90

Cable Termination Kit (V2) (25 set)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Conformity of the specification	As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV
	Type of termination kit	Indoor Termination - Heat Shrink
GENERIC	Applicable conductors for using the termination kits	Aluminium
	The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]	XLPE (Range of approval: XLPE, EPR, HEPR, PVC)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Applicable cable core for using the termination kits (in Nos)	3
	Applicable cable size for using the termination kits (in sq mm)	185
	Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)	Heat Shrink Stress Control Tubing, Heat Shrink Anti Tracking Tubing, Heat Shrink Cable Breakout, Heat Shrink Lug Sealing Tubing, Copper Earthing Tinned Braid With Crimped Lug, Copper Tinned Earthing Braid, Solder, Flux, Jubilee Clamp, Backup Ring, Mastic Tapes, Connector (Lugs), PVC (A) Tape, Amalgamating Insulation Tape for Lug Sealing, Core Cleaning Solvent, Semiconductor Paint, Silicon Grease, Nylon String, Aloxite Tape, Tinned Copper Binding Wire, Mopping Cloth, , Instruction Sheet

Additional Specification Parameters - Cable Termination Kit (V2) (25 set)

Specification Parameter Name	Bid Requirement (Allowed Values)
CABLE BOX I/D 11 KV 3 X 185 SQMM XLPE	CABLE BOX I/D 11 KV 3 X 185 SQMM XLPE PLZ REFER TECHNICAL DOCS. The technical and financial conditions mentioned in the tender documents shall prevail over the GeM technical and financial conditions.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shrikant Singh Rangila	208001,14/71 CIVIL LINE KESCO KANPUR	25	90

Cable Termination Kit (V2) (125 set)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Conformity of the specification	As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV
	Type of termination kit	Outdoor Termination - Cold Shrink

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Applicable conductors for using the termination kits	Aluminium
	The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]	XLPE (Range of approval: XLPE, EPR, HEPR, PVC)
	Applicable cable core for using the termination kits (in Nos)	3
	Applicable cable size for using the termination kits (in sq mm)	1.5, 2.5, 4, 6, 10, 16, 25, 35, 50, 70, 95, 120, 150, 185, 240, 300, 400, 500, 630, 800, 1000
	Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)	Cold Shrink Terminal Assembly - Breakout, Cold Shrink Tube, Cold Shrink Lug Sealing Tube, Stress Cone, Mastic Tapes, Semiconducting Tape, PVC (A) Tape, Copper Earthing Braid, Aloxite Tape, Silicone Grease, Lug Sealing Mastic, Connectors (Lugs), Copper Binding Wire, Nylon String, Backup Ring, Jubilee Clamp, Cleaning Tissue, Roll Spring, Copper Mesh for screen continuity, Hand Gloves, Instruction Sheet

Additional Specification Parameters - Cable Termination Kit (V2) (125 set)

Specification Parameter Name	Bid Requirement (Allowed Values)
CABLE BOX I/D 11 KV 3 X 185 SQMM XLPE	CABLE BOX I/D 11 KV 3 X 185 SQMM. PLEASE REFER TECHNICAL DOCS. The technical and financial conditions mentioned in the tender documents shall prevail over the GeM technical and financial conditions.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shrikant Singh Rangila	208001,14/71 CIVIL LINE KESCO KANPUR	125	90

Cable Joint Kit (V2) (10 set)

तकनीकी विशिष्टियाँ /Technical Specifications

* [जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Conformity of the specification	As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV
	Type of joint kit	Non Rigid - Straight Joint - Heat Shrink
GENERIC	Applicable conductors for using the joint kits	Aluminium
	The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]	XLPE (Range of approval: XLPE, EPR, HEPR, PVC)
	Applicable cable core for using the joint kits (in Nos)	3
	Applicable cable size for using the joint kits (in sq mm)	185
	Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)	Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet

Additional Specification Parameters - Cable Joint Kit (V2) (10 set)

Specification Parameter Name	Bid Requirement (Allowed Values)
CABLE BOX ST TH 11 KV 3 X 185 SQMM XLPE	CABLE BOX ST TH 11 KV 3 X 185 SQMM XLPE REFER TECHNICAL DOCS. The technical and financial conditions mentioned in the tender documents shall prevail over the GeM technical and financial conditions.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shrikant Singh Rangila	208001,14/71 CIVIL LINE KESCO KANPUR	10	90

Cable Termination Kit (V2) (70 set)

तकनीकी विशिष्टियाँ / Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Conformity of the specification	As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV
	Type of termination kit	Outdoor Termination - Heat Shrink
GENERIC	Applicable conductors for using the termination kits	Aluminium
	The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]	XLPE (Range of approval: XLPE, EPR, HEPR, PVC)
	Applicable cable core for using the termination kits (in Nos)	3
	Applicable cable size for using the termination kits (in sq mm)	300
	Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)	Heat Shrink Stress Control Tubing, Heat Shrink Anti Tracking Tubing, Heat Shrink Cable Breakout, Heat Shrink Lug Sealing Tubing, Copper Earthing Tinned Braid With Crimped Lug, Copper Tinned Earthing Braid, Solder, Flux, Jubilee Clamp, Backup Ring, Mastic Tapes, Connector (Lugs), PVC (A) Tape, Amalgamating Insulation Tape for Lug Sealing, Core Cleaning Solvent, Semiconductor Paint, Silicon Grease, Nylon String, Aloxite Tape, Tinned Copper Binding Wire, Mopping Cloth, , Instruction Sheet

Additional Specification Parameters - Cable Termination Kit (V2) (70 set)

Specification Parameter Name	Bid Requirement (Allowed Values)
CABLE BOX O/D 33 KV 3 X 300 SQMM XLPE	CABLE BOX O/D 33 KV 3 X 300 SQMM XLPE. PLEASE REFER TECHNICAL DOCS. The technical and financial conditions mentioned in the tender documents shall prevail over the GeM technical and financial conditions.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shrikant Singh Rangila	208001,14/71 CIVIL LINE KESCO KANPUR	70	90

Cable Joint Kit (V2) (15 set)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Conformity of the specification	As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV
	Type of joint kit	Non Rigid - Transition Joint - Heat Shrink
GENERIC	Applicable conductors for using the joint kits	Aluminium
	The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]]	XLPE (Range of approval: XLPE, EPR, HEPR, PVC)
	Applicable cable core for using the joint kits (in Nos)	3
	Applicable cable size for using the joint kits (in sq mm)	300
	Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)	Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet

Additional Specification Parameters - Cable Joint Kit (V2) (15 set)

Specification Parameter Name	Bid Requirement (Allowed Values)
CABLE BOX ST.TH. 33 KV 3 X 300 SQMM XLPE.	CABLE BOX ST.TH. 33 KV 3 X 300 SQMM XLPE. PLEASE REFER TECHNICAL DOCS. The technical and financial conditions mentioned in the tender documents shall prevail over the GeM technical and financial conditions.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shrikant Singh Rangila	208001,14/71 CIVIL LINE KESCO KANPUR	15	90

Cable Joint Kit (V2) (16 set)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Conformity of the specification	As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV
	Type of joint kit	Non Rigid - Straight Joint - Heat Shrink
GENERIC	Applicable conductors for using the joint kits	Aluminium
	The appropriate cable for using the joint kits	Armoured Cable
	The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]	XLPE (Range of approval: XLPE, EPR, HEPR, PVC)
	Applicable cable core for using the joint kits (in Nos)	3
	Applicable cable size for using the joint kits (in sq mm)	240
	Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)	Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet
CERTIFICATIONS	Availability of type test report from Central Govt lab/NABL accredited/ILAC accredited lab to prove conformity of the specification	Yes, As per IS 13573 (Part 2 and Part 3)

Additional Specification Parameters - Cable Joint Kit (V2) (16 set)

Specification Parameter Name	Bid Requirement (Allowed Values)
CABLE BOX ST.TH 33 KV 3 X 240 SQMM XLPE.	CABLE BOX ST.TH 33 KV 3 X 240 SQMM XLPE. PLEASE REFER TECHNICAL DOCS. The technical and financial conditions mentioned in the tender documents shall prevail over the GeM technical and financial conditions.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shrikant Singh Rangila	208001,14/71 CIVIL LINE KESCO KANPUR	16	90

Cable Joint Kit (V2) (16 set)**तकनीकी विशिष्टियाँ /Technical Specifications**

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Conformity of the specification	As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV
	Type of joint kit	Non Rigid - Straight Joint - Heat Shrink
GENERIC	Applicable conductors for using the joint kits	Aluminium
	The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]	XLPE (Range of approval: XLPE, EPR, HEPR, PVC)
	Applicable cable core for using the joint kits (in Nos)	3
	Applicable cable size for using the joint kits (in sq mm)	120
	Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)	Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
CERTIFICATIONS	Availability of type test report from Central Govt lab/NABL accredited/ILAC accredited lab to prove conformity of the specification	Yes, As per IS 13573 (Part 2 and Part 3)

Additional Specification Parameters - Cable Joint Kit (V2) (16 set)

Specification Parameter Name	Bid Requirement (Allowed Values)
CABLE BOX ST.TH 33 KV 3 X 120 SQMM XLPE.	CABLE BOX ST.TH 33 KV 3 X 120 SQMM XLPE. PLEASE REFER TECHNICAL DOCS. The technical and financial conditions mentioned in the tender documents shall prevail over the GeM technical and financial conditions.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shrikant Singh Rangila	208001,14/71 CIVIL LINE KESCO KANPUR	16	90

Cable Joint Kit (V2) (32 set)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Conformity of the specification	As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV
	Type of joint kit	Non Rigid - Straight Joint - Heat Shrink
GENERIC	Applicable conductors for using the joint kits	Aluminium
	The appropriate cable for using the joint kits	Armoured Cable
	The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]	XLPE (Range of approval: XLPE, EPR, HEPR, PVC)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Applicable cable core for using the joint kits (in Nos)	3
	Applicable cable size for using the joint kits (in sq mm)	400
	Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)	Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet
CERTIFICATIONS	Availability of type test report from Central Govt lab/NABL accredited/ILAC accredited lab to prove conformity of the specification	Yes, As per IS 13573 (Part 2 and Part 3)

Additional Specification Parameters - Cable Joint Kit (V2) (32 set)

Specification Parameter Name	Bid Requirement (Allowed Values)
CABLE BOX ST.TH 33 KV 3 X 400 SQMM XLPE.	CABLE BOX ST.TH 33 KV 3 X 400 SQMM XLPE. PLEASE REFER TECHNICAL DOCS. The technical and financial conditions mentioned in the tender documents shall prevail over the GeM technical and financial conditions.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shrikant Singh Rangila	208001,14/71 CIVIL LINE KESCO KANPUR	32	90

Buyer added Bid Specific Additional Specification - Drawings

क्र.सं./S.No.	Document Title	Description	रिवर्स प्रभार के अनुसार जीएसटी/Applicable i.r.o. Items

क्र.सं./S.N o.	Document Title	Description	रिवर्स प्रभार के अनुसार जीएसटी/Applicable i.r.o. Items
1	TECHNICAL SPECIFICATION View	ALL TECHNICAL PARAMETERS AND CONDITIONS SHOULD BE FOLLOWED	Cable Termination Kit (V2) (65),Cable Termination Kit (V2) (25),Cable Termination Kit (V2) (125),Cable Joint Kit (V2) (10),Cable Termination Kit (V2) (70),Cable Joint Kit (V2) (15),Cable Joint Kit (V2) (16),Cable Joint Kit (V2) (16),Cable Joint Kit (V2)(32)

The uploaded document only contains Buyer specific Additional Scope of Work and / or Drawings for the bid items added with due approval of Buyer's competent authority. Buyer has certified that these additional scope and drawings are generalized and would not lead to any restrictive bidding.

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. Inspection

Nominated Inspection Agency: On behalf of the Buyer organization, any one of the following Inspection Agency would be conducting inspection of stores before acceptance:

Pre-dispatch Inspection at Seller Premises (applicable only if pre-dispatch inspection clause has been selected in ATC):

KESCO AND THIRD PARTY

Post Receipt Inspection at consignee site before acceptance of stores:
DQC KESCO

3. Inspection

Pre-dispatch inspection at Seller premises (Fee/Charges to be borne by the BUYER): Before dispatch, the goods will be inspected by Buyer / Consignee or their Authorized Representative or by Nominated External Inspection Agency (independently or jointly with Buyer or Consignee as decided by the Buyer) at Seller premises (or at designated place for inspection as declared / communicated by the seller) for their compliance to the contract specifications. Fee/Charges taken by the External inspection Agency and any external laboratories testing charges shall be borne by the Buyer. For in-house testing, the Sellers will provide necessary facilities free of cost. Seller shall notify the Buyer through e-mail about readiness of goods for pre-dispatch inspection and Buyer will notify the Seller about the Authorized Representative/ Nominated External Inspection Agency and the date for testing. The goods would be dispatched to consignee only after clearance in pre-dispatch inspection. Consignee's right of rejection as per GTC in respect of the goods finally received at his location shall in no way be limited or waived by reason of the goods having previously been inspected, tested and passed by Buyer/ Consignee or its Nominated External Inspection Agency prior to the goods' shipment. While bidding, the sellers should take into account 7 days for inspection from the date of email offering the goods for inspection. Any delay in

inspection beyond 7 days shall be on the part of the buyer and shall be regularised without Liquidated Damages.

When there is requirement of submission the advance sample, the seller shall inform the buyer promptly through emails about the date of submission of sample to the buyer nominated Inspection agency.

4. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws,

including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and
- All operative provisions of the erstwhile Labour Laws until their complete substitution.

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---