

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	02-06-2026 13:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	02-06-2026 13:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	120 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Defence
विभाग का नाम/Department Name	Department Of Defence Research & Development
संगठन का नाम/Organisation Name	Office Of Dg (hr)
कार्यालय का नाम/Office Name	*****
कुल मात्रा/Total Quantity	85
वस्तु श्रेणी /Item Category	Portable Fire Extinguishers (V3) ISI Marked to IS 15683 (Q2) , Wheeled Fire Extinguishers (V3) ISI Marked to Is 16018 (Q2)
वर्षों के अनुभव एवं टर्नओवर से एमएसई को छूट प्राप्त है / MSE Relaxation for Years Of Experience and Turnover	Yes Complete
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / Startup Relaxation for Years Of Experience and Turnover	Yes Complete
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Certificate (Requested in ATC),OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या / Minimum number of bids required to disable automatic bid extension	3

बिड विवरण/Bid Details	
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	7
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	1
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	Yes
रिवर्स नीलामी योग्यता नियम/RA Qualification Rule	H1-Highest Priced Bid Elimination
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	Portable Fire Extinguishers (V3) ISI Marked to IS 15683
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईएमडी राशि/EMD Amount	32000

ईपीबीजी विवरण /ePBG Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईपीबीजी प्रतिशत (%) /ePBG Percentage(%)	5.00
ईपीबीजी की आवश्यक अवधि (माह) /Duration of ePBG required (Months).	40

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने है। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b).ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be

in favour of Beneficiary, wherever it is applicable.

लाभार्थी /Beneficiary :

DIRECTOR

DESIDOC, Department of Defence Research & Development, Office of DG (HR), Ministry of Defence
(Director, Desidoc)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई खरीद वरीयता / MII Purchase Preference

एमआईआई खरीद वरीयता / MII Purchase Preference	Yes
मेक इन इंडिया विक्रेताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में है / Purchase Preference to MII sellers available upto price within L1+X%	20
मेक इन इंडिया खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MII purchase preference	50
सार्वजनिक खरीद (मेक-इन-इंडिया को प्राथमिकता) आदेश 2017 के अनुसार केवल क्लास 1/क्लास 2 के स्थानीय आपूर्तिकर्ताओं को ही भागीदारी की अनुमति है दिनांक 16.09.2020 (समय-समय पर संशोधित एवं लागू) / Allow participation only from Class 1/Class 2 local suppliers as per the Public procurement(Preference to Make-in-india) order 2017 date 16.09.2020(as amended and applicable time to time)	Yes, in compliance with the MII ORDER : DPIIT Order(as amended and applicable time to time)

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within L1+X%	15
सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference	25

1. If the bidder is a Micro or Small Enterprise as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Experience Criteria" as defined above subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Experience Criteria, shall upload the supporting documents to prove his eligibility for Relaxation.

2. If the bidder is a Micro or Small Enterprise (MSE) as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Bidder Turnover" as defined above subject to meeting of quality and technical specifications. If the bidder itself is MSE OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder

seeking Relaxation from Turnover, shall upload the supporting documents to prove his eligibility for Relaxation.

3. If the bidder is a DPIIT registered Startup, the bidder shall be relaxed from the the eligibility criteria of "Experience Criteria" as defined above subject to their meeting of quality and technical specifications. The bidder seeking Relaxation from Experience Criteria, shall upload the supporting documents to prove his eligibility for Relaxation.

4. If the bidder is a DPIIT registered Startup, the bidder shall be relaxed from the the eligibility criteria of "Bidder Turnover" as defined above subject to their meeting of quality and technical specifications. If the bidder is DPIIT Registered OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover shall upload the supporting documents to prove his eligibility for Relaxation.

5. Preference to Make In India products (For bids < 200 Crore): Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

6. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

7. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

8. Reverse Auction would be conducted amongst all the technically qualified bidders except the Highest quoting bidder. The technically qualified Highest Quoting bidder will not be allowed to participate in RA. However, H-1 will also be allowed to participate in RA in following cases:

- i. If number of technically qualified bidders are only 2 or 3.
- ii. If Buyer has chosen to split the bid amongst N sellers, and H1 bid is coming within N.
- iii. In case Primary product of only one OEM is left in contention for participation in RA on elimination of H-1.
- iv. If L-1 is non-MSE and H-1 is eligible MSE and H-1 price is coming within price band of 15% of Non-MSE L-1
- v. If L-1 is non-MII and H-1 is eligible MII and H-1 price is coming within price band of 20% of Non-MII L-1

Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (8 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Technical Requirement	Type (Based on Extinguishing medium used)	Foam based
	Type (Based on Method of Discharge of extinguishing medium)	Stored pressure extinguishers
	Propellant use in Extinguishers	Nitrogen
	Capacity of fire Extinguisher	9 litre
	Operating Temperature Range	+ 5°C to + 60°C
	Type (Based on Service pressure of Extinguisher	Low Pressure Extinguisher (Service Pressure ?19 bar)
	Material of Construction	Welded low carbon steel cylinders (as per Clause 9.2.5 of IS 15683)
	Classification of fire for which Fire Extinguisher is suitable	Class A, Class B
	Fire Rating of different class of fires	4A, 233B
Marking & Colour	Marking	As per clause 10.2 of IS 15683
	Colour for extinguisher Body	Red conforming to shade No. 536 or 538 of IS 5.
	Colour coding Band	Yellow

Additional Specification Parameters - Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (8 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
As per attached ATC	As per attached ATC

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****North Delhi	8	45

Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (2 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Technical Requirement	Type (Based on Extinguishing medium used)	Water based
	Type (Based on Method of Discharge of extinguishing medium)	Stored pressure extinguishers
	Propellant use in Extinguishers	Nitrogen
	Capacity of fire Extinguisher	9 litre
	Operating Temperature Range	+ 5°C to + 60°C
	Type (Based on Service pressure of Extinguisher)	Low Pressure Extinguisher (Service Pressure ?19 bar)
	Material of Construction	Welded low carbon steel cylinders (as per Clause 9.2.5 of IS 15683)
	Classification of fire for which Fire Extinguisher is suitable	Class A
	Fire Rating of different class of fires	3A
Marking & Colour	Marking	As per clause 10.2 of IS 15683
	Colour for extinguisher Body	Red conforming to shade No. 536 or 538 of IS 5.
	Colour coding Band	Red

Additional Specification Parameters - Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (2 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
As per attached ATC	As per attached ATC

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****North Delhi	2	45

Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (19 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Technical Requirement	Type (Based on Extinguishing medium used)	Carbon dioxide
	Type (Based on Method of Discharge of extinguishing medium)	Stored pressure extinguishers
	Propellant use in Extinguishers	Carbon dioxide
	Capacity of fire Extinguisher	2 kg
	Operating Temperature Range	? 30°C to + 60°C
	Type (Based on Service pressure of Extinguisher)	High Pressure Extinguisher (Service Pressure >19 bar)
	Material of Construction	Steel body (as per latest IS 7285)
	Classification of fire for which Fire Extinguisher is suitable	Class B, Class C, Class E
	Fire Rating of different class of fires	34B
Marking & Colour	Marking	As per clause 10.2 of IS 15683
	Colour for extinguisher Body	Red conforming to shade No. 536 or 538 of IS 5.
	Colour coding Band	Black

Additional Specification Parameters - Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (19 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
As per attached ATC	As per attached ATC

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****North Delhi	19	45

Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (19 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Technical Requirement	Type (Based on Extinguishing medium used)	Powders — ABC/BC/D Type
	Type (Based on Method of Discharge of extinguishing medium)	Stored pressure extinguishers
	Propellant use in Extinguishers	Nitrogen
	Capacity of fire Extinguisher	9 kg
	Operating Temperature Range	? 30°C to + 60°C
	Type (Based on Service pressure of Extinguisher)	Low Pressure Extinguisher (Service Pressure ?19 bar)
	Material of Construction	Welded low carbon steel cylinders (as per Clause 9.2.5 of IS 15683)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Classification of fire for which Fire Extinguisher is suitable	
	Fire Rating of different class of fires	
Marking & Colour	Marking	As per clause 10.2 of IS 15683
	Colour for extinguisher Body	Red conforming to shade No. 536 or 538 of IS 5.
	Colour coding Band	Blue

Additional Specification Parameters - Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (19 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
As per attached ATC	As per attached ATC

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****North Delhi	19	45

Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (4 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Technical Requirement	Type (Based on Extinguishing medium used)	Water based
	Type (Based on Method of Discharge of extinguishing medium)	Cartridge-operated extinguishers

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Propellant use in Extinguishers	Carbon dioxide
	Capacity of fire Extinguisher	9 litre
	Operating Temperature Range	+ 5°C to + 60°C
	Type (Based on Service pressure of Extinguisher)	Low Pressure Extinguisher (Service Pressure ?19 bar)
	Material of Construction	Welded low carbon steel cylinders (as per Clause 9.2.5 of IS 15683)
	Classification of fire for which Fire Extinguisher is suitable	Class A
	Fire Rating of different class of fires	3A
Marking & Colour	Marking	As per clause 10.2 of IS 15683
	Colour for extinguisher Body	Red conforming to shade No. 536 or 538 of IS 5.
	Colour coding Band	Red

Additional Specification Parameters - Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (4 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
As per attached ATC	As per attached ATC

* Bidders offering must also comply with the additional specification parameters mentioned above.

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****North Delhi	4	45

Wheeled Fire Extinguishers (V3) ISI Marked To Is 16018 (5 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ / Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Technical Requirement	Type (Based on Extinguishing medium used)	Powders — ABC/BC/D Type
	Extinguisher bodies per axle	One cylinder
	Type (Based on Method of Discharge of extinguishing medium)	Cartridge-operated extinguishers
	Propellant use in Extinguishers	Carbon dioxide
	Fill density	As per clause 5.3 of IS 16018
	Charge of fire Extinguisher	25 kg
	Operating Temperature Range	-30°C to +55°C
	Type (Based on Service pressure of Extinguisher)	Low Pressure Extinguisher (service pressure less than 2.5 MPa)
	Material of Construction	Welded Low Carbon Steel as per clause 8.4.1 of IS 16018
	Classification of fire for which Fire Extinguisher is suitable	Class A, Class B, Class C
	Fire Rating of different class of fires	20A, 233B
	Effective Discharge Time	As per clause 6.2.1 of IS 16018
	Discharge Assembly as per Clause 8.11 IS 16018	Hose at least 1.5 m long (for wheeled extinguishers having a charge of extinguishing medium not exceeding 25 kg or 25 litre)
	Safety and Anti-overfill Devices	As per clause 8.8 of IS 16018
Marking & Colour	Marking	As per clause 9.2 of IS 16018
	Colour for wheeled fire extinguisher bodies	Red

Additional Specification Parameters - Wheeled Fire Extinguishers (V3) ISI Marked To Is 16018 (5 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
As per attached ATC	As per attached ATC

* Bidders offering must also comply with the additional specification parameters mentioned above.

परिषदी/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परिषदी/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****North Delhi	5	45

Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (3 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Technical Requirement	Type (Based on Extinguishing medium used)	Powders — ABC/BC/D Type
	Type (Based on Method of Discharge of extinguishing medium)	Stored pressure extinguishers
	Propellant use in Extinguishers	Nitrogen
	Capacity of fire Extinguisher	4 kg
	Operating Temperature Range	? 30°C to + 60°C
	Type (Based on Service pressure of Extinguisher)	Low Pressure Extinguisher (Service Pressure ?19 bar)
	Material of Construction	Welded low carbon steel cylinders (as per Clause 9.2.5 of IS 15683)
	Classification of fire for which Fire Extinguisher is suitable	Class A, Class B, Class C
	Fire Rating of different class of fires	4A, 144B
Marking & Colour	Marking	As per clause 10.2 of IS 15683
	Colour for extinguisher Body	Red conforming to shade No. 536 or 538 of IS 5.
	Colour coding Band	Blue

Additional Specification Parameters - Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (3

pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
As per attached ATC	As per attached ATC

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****North Delhi	3	45

Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (12 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Technical Requirement	Type (Based on Extinguishing medium used)	Carbon dioxide
	Type (Based on Method of Discharge of extinguishing medium)	Stored pressure extinguishers
	Propellant use in Extinguishers	Carbon dioxide
	Capacity of fire Extinguisher	4.5 kg
	Operating Temperature Range	? 30°C to + 60°C
	Type (Based on Service pressure of Extinguisher)	High Pressure Extinguisher (Service Pressure >19 bar)
	Material of Construction	Steel body (as per latest IS 7285)
	Classification of fire for which Fire Extinguisher is suitable	Class B
	Fire Rating of different class of fires	55B
Marking & Colour	Marking	As per clause 10.2 of IS 15683
	Colour for extinguisher Body	Red conforming to shade No. 536 or 538 of IS 5.
	Colour coding Band	Black

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)

Additional Specification Parameters - Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (12 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
As per attached ATC	As per attached ATC

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****North Delhi	12	45

Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (2 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Technical Requirement	Type (Based on Extinguishing medium used)	Powders — ABC/BC/D Type
	Type (Based on Method of Discharge of extinguishing medium)	Stored pressure extinguishers
	Propellant use in Extinguishers	Nitrogen
	Capacity of fire Extinguisher	6 kg
	Operating Temperature Range	? 30°C to + 60°C
	Type (Based on Service pressure of Extinguisher	Low Pressure Extinguisher (Service Pressure ?19 bar)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Material of Construction	Welded low carbon steel cylinders (as per Clause 9.2.5 of IS 15683)
	Classification of fire for which Fire Extinguisher is suitable	Class A, Class B, Class C
	Fire Rating of different class of fires	6A, 183B
Marking & Colour	Marking	As per clause 10.2 of IS 15683
	Colour for extinguisher Body	Red conforming to shade No. 536 or 538 of IS 5.
	Colour coding Band	Blue

Additional Specification Parameters - Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (2 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
As per attached ATC	As per attached ATC

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****North Delhi	2	45

Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (2 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Technical Requirement	Type (Based on Extinguishing medium used)	Carbon dioxide

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Type (Based on Method of Discharge of extinguishing medium)	Stored pressure extinguishers
	Propellant use in Extinguishers	Carbon dioxide
	Capacity of fire Extinguisher	3 kg
	Operating Temperature Range	? 30°C to + 60°C
	Type (Based on Service pressure of Extinguisher)	High Pressure Extinguisher (Service Pressure >19 bar)
	Material of Construction	Steel body (as per latest IS 7285)
	Classification of fire for which Fire Extinguisher is suitable	Class B, Class C
	Fire Rating of different class of fires	34B
Marking & Colour	Marking	As per clause 10.2 of IS 15683
	Colour for extinguisher Body	Red conforming to shade No. 536 or 538 of IS 5.
	Colour coding Band	Black

Additional Specification Parameters - Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (2 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
As per attached ATC	As per attached ATC

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****North Delhi	2	45

Wheeled Fire Extinguishers (V3) ISI Marked To Is 16018 (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ / Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Technical Requirement	Type (Based on Extinguishing medium used)	Carbon dioxide
	Extinguisher bodies per axle	One cylinder
	Type (Based on Method of Discharge of extinguishing medium)	Stored pressure extinguishers
	Propellant use in Extinguishers	Carbon dioxide
	Fill density	As per clause 5.3 of IS 16018
	Charge of fire Extinguisher	22.5 kg
	Operating Temperature Range	-30°C to +55°C
	Type (Based on Service pressure of Extinguisher)	High Pressure Extinguisher (service pressure more than 2.5 MPa)
	Material of Construction	Welded Low Carbon Steel as per clause 8.4.1 of IS 16018
	Classification of fire for which Fire Extinguisher is suitable	Class B
	Fire Rating of different class of fires	89B
	Effective Discharge Time	As per clause 6.2.1 of IS 16018
	Discharge Assembly as per Clause 8.11 IS 16018	Hose at least 1.5 m long (for wheeled extinguishers having a charge of extinguishing medium not exceeding 25 kg or 25 litre)
	Safety and Anti-overfill Devices	As per clause 8.8 of IS 16018
Marking & Colour	Marking	As per clause 9.2 of IS 16018
	Colour for wheeled fire extinguisher bodies	Red

Additional Specification Parameters - Wheeled Fire Extinguishers (V3) ISI Marked To Is 16018 (1 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
As per attached ATC	As per attached ATC

* Bidders offering must also comply with the additional specification parameters mentioned above.

परिषदी/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परिषदी/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****North Delhi	1	45

Wheeled Fire Extinguishers (V3) ISI Marked To Is 16018 (2 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Technical Requirement	Type (Based on Extinguishing medium used)	Carbon dioxide
	Extinguisher bodies per axle	One cylinder
	Type (Based on Method of Discharge of extinguishing medium)	Stored pressure extinguishers
	Propellant use in Extinguishers	Carbon dioxide
	Fill density	As per clause 5.3 of IS 16018
	Charge of fire Extinguisher	6.5 kg
	Operating Temperature Range	+5°C to +55°C, -5°C to +55°C, -10°C to +55°C, -20°C to +55°C, -30°C to +55°C, -40°C to +55°C, -55°C to +55°C
	Type (Based on Service pressure of Extinguisher)	High Pressure Extinguisher (service pressure more than 2.5 MPa)
	Material of Construction	Welded Low Carbon Steel as per clause 8.4.1 of IS 16018
	Classification of fire for which Fire Extinguisher is suitable	Class B, Class C
	Fire Rating of different class of fires	55B
	Effective Discharge Time	As per clause 6.2.1 of IS 16018
	Discharge Assembly as per Clause 8.11 IS 16018	Hose at least 4.0m long
	Safety and Anti-overfill Devices	As per clause 8.8 of IS 16018
Marking & Colour	Marking	As per clause 9.2 of IS 16018

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Colour for wheeled fire extinguisher bodies	Red

Additional Specification Parameters - Wheeled Fire Extinguishers (V3) ISI Marked To Is 16018 (2 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
As per attached ATC	As per attached ATC

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****North Delhi	2	45

Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (6 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Technical Requirement	Type (Based on Extinguishing medium used)	Clean agents
	Type (Based on Method of Discharge of extinguishing medium)	Stored pressure extinguishers
	Propellant use in Extinguishers	Nitrogen
	Capacity of fire Extinguisher	4 kg
	Operating Temperature Range	? 30°C to + 60°C
	Type (Based on Service pressure of Extinguisher	Low Pressure Extinguisher (Service Pressure ?19 bar)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Material of Construction	Welded low carbon steel cylinders (as per Clause 9.2.5 of IS 15683)
	Classification of fire for which Fire Extinguisher is suitable	Class A, Class B
	Fire Rating of different class of fires	2A, 34B
	Marking & Colour	
	Marking	As per clause 10.2 of IS 15683
	Colour for extinguisher Body	Red conforming to shade No. 536 or 538 of IS 5.
	Colour coding Band	Green

Additional Specification Parameters - Portable Fire Extinguishers (V3) ISI Marked To IS 15683 (6 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
As per attached ATC	As per attached ATC

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****North Delhi	6	45

Special terms and conditions-Version:1 effective from 05-12-2025 for category Portable Fire Extinguishers (V3) ISI Marked to IS 15683

1. This category is BIS Scheme - 1 compliant. Catalogs must have valid and active CM/L license number owned by the applicant themselves. In case of non-compliance, appropriate action may be taken against OEM / Brand / Seller as per the GeM IM Policy.

The gas shall be supplied compressed in Cylinder. The design of the Cylinder, pressure of gas in Cylinder, packing, marking, painting, labelling, storage and transport of Cylinder shall be in accordance with the Gas Cylinder Rules , with such modifications as may be ordered from time to time by the CIE, PESO, DPIIT, MoC&I, Gol.

Special terms and conditions-Version:1 effective from 05-12-2025 for category Wheeled Fire Extinguishers (V3) ISI Marked to Is 16018

1. This category is BIS Scheme - 1 compliant. Catalogs must have valid and active CM/L license number

owned by the applicant themselves. In case of non-compliance, appropriate action may be taken against OEM / Brand / Seller as per the GeM IM Policy.

The gas shall be supplied compressed in Cylinder. The design of the Cylinder, pressure of gas in Cylinder, packing, marking, painting, labelling, storage and transport of Cylinder shall be in accordance with the Gas Cylinder Rules , with such modifications as may be ordered from time to time by the CIE, PESO, DPIIT, MoC&I, Gol.

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/**Buyer Added Bid Specific Terms and Conditions**

1. **Generic**

Actual delivery (and Installation & Commissioning (if covered in scope of supply)) is to be done at following address

DESIDOC, DRDO,
MINISTRY OF DEFENCE,
METCALFE HOUSE,
CIVIL LINES,
DELHI-110054

2. **Generic**

Bidder financial standing: The bidder should not be under liquidation, court receivership or similar proceedings, should not be bankrupt. Bidder to upload undertaking to this effect with bid.

3. **Certificates**

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

4. **Generic**

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

5. **Generic**

Bidder shall submit the following documents along with their bid for Vendor Code Creation:

- a. Copy of PAN Card.
- b. Copy of GSTIN.
- c. Copy of Cancelled Cheque.
- d. Copy of EFT Mandate duly certified by Bank.

6. **Rate Contract**

Demurrage charges In case the rejected items are not lifted by the firm within 48 hrs, the demurrage charges at the rate of 0.5% of total contract value will be charged per day. In case the items are not lifted within a month, the same will be destroyed by the station board of officers and no claim will be admitted. Demurrage charges. In case the rejected items are not lifted by the firm within 48 hrs, the demurrage charges at the rate of 0.5% of total contract value will be charged per day. In case the items are not lifted within a month, the same will be destroyed by the station board of officers and no claim will be admitted.

7. **Rate Contract**

Packing Material The items will be supplied by the successful bidder in its original packing material and the packing material will not be returned. Weight of packing material will not be included in quantity supplied and only net weight of the items will be counted. The packing should be of standardized weights of appropriate size. Item will not be accepted in non-standardized weights. Packing Material. The items will be supplied by the successful bidder in its original packing material and the packing material will not be returned. Weight of packing material will not be included in quantity supplied and only net weight of the items will be counted. The packing should be of standardized weights of appropriate size. Item will not be accepted in non-standardized weights.

8. **Warranty**

Warranty period of the supplied products shall be 3 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

9. **Service & Support**

Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.

10. **Generic**

Data Sheet of the product(s) offered in the bid, are to be uploaded along with the bid documents. Buyers can match and verify the Data Sheet with the product specifications offered. In case of any unexplained mismatch of technical parameters, the bid is liable for rejection.

11. **Generic**

For hazardous chemical/item, all precautionary measure as per regulation from the point of transportation/ handling/ storage/ safety/ health/ environment to be undertaken/ specified before dispatch. During dispatch, proper symbol for the hazard/ MSDS/ Batch No./ date of manufacturing/ Gross Weight/ Net Weight/ shelf Life etc are to be written/ printed/ pasted on the body of the packing.

12. **Generic**

Installation, Commissioning, Testing, Configuration, Training (if any - which ever is applicable as per scope of supply) is to be carried out by OEM / OEM Certified resource or OEM authorised Reseller.

13. **Certificates**

Material Test Certificate Should Be Sent Along with The Supply. The Material Will Be Checked by Buyer's Lab & the Results of the Lab will be the Sole Criteria for Acceptance of the Item.

14. **Generic**

Manufacturer Authorization:Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid

15. **Ration Item ATCs**

Shelf Life The supplier shall declare the shelf life/best before use for a minimum period equal to the warranty period as given in the DFS for the item. The item should be of the latest manufacture, conforming to the current production standard and having 100% defined life at the time of delivery.

16. **Certificates**

The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in

the bid document.

17. **Certificates**

To be eligible for award of contract, Bidder / OEM must possess following Certificates / Test Reports on the date of bid opening (to be uploaded with bid):

YES

18. **Ration Item ATCs**

Warranty The following Warranty clause will form part of the contract placed on successful Bidder :-

(a) The Seller warrants that the goods supplied under the contract conform to Defence Food Specification prescribed and shall perform according to the said Defence Food Specification in any climate and under all conditions of storage and movement in India (the warranty period of the item is as given in the Defence Food Specification attached from the date of acceptance of stores).

(b) The Seller warrants for a period of warranty as prescribed (the warranty period of the item is as given in the Defence Food Specification attached) from the date of acceptance of stores, that the goods/ stores supplied under the contract shall be free from all types of defects.

(c) Once the stocks are accepted by the verdict of CFL/ FIU, stocks are dispatched to various depots and stocked/issued to troops for consumption. This does not mean that the responsibility of supplier is over. At any point of time, the DGST or his authorised representative (s) may draw samples from the stocks supplied from locations where they are held at that point of time to confirm that the stocks supplied by the supplier are meeting the concerned DFS. Prior to drawl of such samples, the supplier will be intimated by the fastest means by the supply depot where the stocks are held to make available the authorised representative of the supplier within three working days in whose presence the sample will be drawn. Failing which, the sample will be drawn unilaterally and the decision on the same will be final and no representation in this regard will be accepted later.

(d) If within the period of warranty, after analysis of the samples drawn as per Para (c) above, the goods are reported by the Buyer to have failed to meet the quality parameters as per the Defence Food Specifications, the stock will be declared as "Failed to Perform within Warranty Period". In the event of the supplies or part of it having been declared (during the period of warranty) as "Failed to Perform within Warranty Period" by the Director General of Supplies and Transport, QMG's Branch, IHQ of MoD (Army), in New Delhi or any officer acting on his behalf whose opinion as to whether or not the particular consignment is meeting the quality as per DFS for the item, will be final and the seller will avail any one options as specified in the succeeding paras within a maximum period of 45 days from the date the notification letter is dispatched for such defect by the buyer, failing which, the buyer will take actions as deemed fit to recover from the supplier the price thereof together with all incidental and freight charges incurred from the place of delivery to the place where the supplies were ultimately condemned. The opinion of the BUYER or any officer acting on his behalf in regard to these charges will be final. This opinion shall be regarded as having been made without committing Govt in any way nor will such decision prejudice the Govt rights.

(e) Claims shall be prepared by the supply depots for the cost of affected quantity including GST and all incidental charges including transportation charges if any, and other incidental charges if any through CDP (APO). The stocks shall be segregated at the supply depot. The supplier is given two options in this eventuality. Option 1- Supplier will make good the loss amounting the claim prepared by the concerned supply depot by depositing the money to PCDA (Delhi) within 30 days of intimation sent by APO to the supplier and supplier shall lift the stock (only once supplier has made the payment to PCDA(Delhi)) from locations where they are stored at that time within 45 days of date of issue letter by APO (with copy to all) on his own cost, failing which the stock shall be destroyed by a board of officers. It shall be the sole responsibility of the supplier to lift such stocks declared failed to perform within warranty in the stipulated time. Option 2- the Seller shall replace the same free of charge, within a maximum period of 45 days from the date the notification letter is dispatched for such defect by the buyer, failing which the stores will be destroyed in situ at SELLER's risk and cost by a station board of officers. No DP extensions for the purpose is required and consequently the firm will have to furnish a fresh validity of PBG submitted, at APO. The fresh stock intended to replace with the affected stock, will undergo similar QC procedure as followed during initial acceptance of the stocks. The supplier will transport fit stocks to the supply depot where the affected stocks are held by his own cost and expense.

(f) The seller will intimate the buyer within 10 days of intimation dispatched by APO wrt the defect in such an event, the option he is willing to adopt along with the documents as under :-

(i) If the seller is willing for option 1, the intimation letter will also accompany the proof of the deposition of the claimable amount at PCDA Delhi.

(ii) If the seller is willing for option 2, the intimation letter will include the extension of the PBG for a

corresponding period as per the warranty period mentioned in the DFS.

(g) In case, the seller fails to make good the loss or replace the affected stocks as desired, after the stipulated time period of 45 days, such stocks will be destroyed insitu. Appropriate legal action will be initiated against the supplier there after. Supplier cannot claim on the destruction of such stocks irrespective of the outcome of the legal action.

(h) Such stocks which are stored in forward depots/ units from where it cannot be retrieved for handing over to suppliers shall be destroyed by board of officers.

(j) The declaration by the Buyer or any officer acting on his behalf communicated to the SUPPLIER in writing that a particular consignment has been condemned will be taken by the SUPPLIER as the conclusive evidence of the proper communication of that consignment provided that such communication is issued by the Buyer within 45 days of the expiry of the warranty period. Nothing herein contain shall prejudice any other right of the BUYER in that behalf under this contract or otherwise.

(k) Warranty in case of any preponement of supplies at the request of the supplier will be valid as per the original Delivery Period. A confirmation for the same will be issued in writing by the supplier.

(l) The Supplier will have to refund to the government any claim under the warranty clause and other claim(s) that may arise out or under this agreement as soon as a demand to that effect is made by the Buyer failing which such claims will be recovered by adjustment against the performance security deposits. Should this sum be not sufficient to cover the full amount recoverable, the Supplier shall pay the remaining balance due to the government on demand. In respect of contracts providing for an execution by the Supplier of guarantee regarding maintenance of the wholesomeness of stores supplied, the performance security deposit or such portion thereof as may be decided by the Buyer may be withheld till the expiry of the warranty period relating to final supplies.

19. **Generic**

While generating invoice in GeM portal, the seller must upload scanned copy of GST invoice and the screenshot of GST portal confirming payment of GST.

20. **Buyer Added Bid Specific ATC**

Buyer uploaded ATC document [Click here to view the file.](#)

अस्वीकरण/**Disclaimer**

The Additional Terms and Conditions (ATC) have been incorporated by the Buyer after approval of their Competent Authority. The Buyer, is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any restriction arising in the bidding process due to these ATCs and including the modification of technical specifications and / or terms and conditions governing the bid. All representations / grievances pertaining to the ATC clauses shall be raised with the buyer organization directly and not with GeM. If any of the clause(s) is/are incorporated by the Buyer regarding the following, the bid & resultant contract shall be treated as null & void. Further, GeM reserves the right, at its sole discretion, to cancel the bid forthwith, without issuance of any prior notice or intimation :-

1. Publishing Custom / BOQ bids for items for which regular GeM categories are available (unless such Custom / BOQ item is bunched with the major regular product Category Item).
2. Mandating procurement of / from specific Brand / Make / Model / Manufacturer / Dealer except in case of Single Bid / Proprietary Article Certificate (PAC) Buying.
3. Inclusion of disqualification criteria related to suspension of seller / service provider, where such suspension period has already expired.
4. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
5. Publishing bids on GeM for procurement of works.
6. Procurement of Goods by creating a Service bid on GeM & vice-versa.
7. Seeking sample with bid or approval of samples during bid evaluation process. However, trial / sample, as the case may be, shall be permitted in cases where trial / sample are allowed as per approved and published procurement policy of the Buyers' controlling Ministry / Department / State / Public Sector Enterprises Headquarters. If there is any violation of trial / sample clause with regard to approved policy of the Buyers' Ministry / Department / State / Public Sector Enterprises Headquarters, then this is to be determined and redressed by the concerned Buyer Organisation only.
8. Seeking experience from specific organization / department / institute only or from foreign / export experience.

9. Creating bid for items from incorrect categories.
10. Reference of conditions published on any external site or reference to external documents/clauses.
11. Asking for any Tender fee / Bid Participation fee, as the case may be.
12. Buyer added ATC Clauses which are in contravention of clauses defined in bid detail section, including specifications, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by the applicable GeM GTC.
13. Any ATC clause in contravention with GeM GTC Clause 4 (xiii) (h) will be invalid. In case of multiple L1 bidders against a service bid, the buyer shall place the Contract by selection of a bidder amongst the L-1 bidders through a Random Algorithm executed by GeM system.
14. In a category based bid, adding additional items, through buyer added, additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogues or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

This Bid is governed by the General Terms and Conditions, conditions stipulated in Bid and Service Level Agreement specific to the Service, as the case may be, as provided in the Marketplace.

However, in case of Service, if any condition specified in General Terms and Conditions is contradicted by the conditions stipulated in Service Level Agreement specific to said Service, then it will over-ride the conditions in the General Terms and Conditions.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms

of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---