

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	23-02-2026 10:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	23-02-2026 10:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	30 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Power
विभाग का नाम/Department Name	Na
संगठन का नाम/Organisation Name	Ntpc Limited
कार्यालय का नाम/Office Name	Singrauli Super Thermal Power Station
कुल मात्रा/Total Quantity	13
वस्तु श्रेणी /Item Category	Cable Termination Kit Suitable for Cables Up to and Including 33 kV (V2) (Q3) , Cable Joint Kit Suitable for Cables Up to and Including 33 kV (V2) (Q3)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Relaxation for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Relaxation for Years of Experience and Turnover	No
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	3
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	3
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	2
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	No
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	Cable Joint Kit Suitable for Cables Up to and Including 33 kV (V2)

बिड विवरण/Bid Details

तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

आवश्यकता/Required	No
-------------------	----

ईपीबीजी विवरण /ePBG Detail

आवश्यकता/Required	No
-------------------	----

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई खरीद वरीयता/MII Purchase Preference

एमआईआई खरीद वरीयता/MII Purchase Preference	No
--	----

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य $L1+X\%$ तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within $L1+X\%$	15
सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference	25

1. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are

excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

Cable Termination Kit Suitable For Cables Up To And Including 33 KV (V2) (1 set)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Conformity of the specification	As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV
	Type of termination kit	Indoor Termination - Heat Shrink
GENERIC	Applicable conductors for using the termination kits	Aluminium
	The appropriate cable for using the termination kits	Armoured Cable
	The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]	XLPE (Range of approval: XLPE, EPR, HEPR, PVC)
	Applicable cable core for using the termination kits (in Nos)	3
	Applicable cable size for using the termination kits (in sq mm)	185
	Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)	Heat Shrink Stress Control Tubing, Heat Shrink Anti Tracking Tubing, Heat Shrink Cable Breakout, Heat Shrink Lug Sealing Tubing, Copper Earthing Tinned Braid With Crimped Lug, Copper Tinned Earthing Braid, Solder, Flux, Jubilee Clamp, Backup Ring, Mastic Tapes, Connector (Lugs), PVC (A) Tape, Amalgamating Insulation Tape for Lug Sealing, Core Cleaning Solvent, Semiconductor Paint, Silicon Grease, Nylon String, Aloxite Tape, Tinned Copper Binding Wire, Mopping Cloth, , Instruction Sheet
	Rain sheds/creepage extender supplied with termination kit	No

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
CERTIFICATION	Availability of type test report from Central Govt lab/NABL accredited/ILAC accredited lab to prove conformity of the specification	Yes, As per IS 13573 (Part 2 and Part 3)

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Sukesh Jain	231222,SINGRAULI SUPER THERMAL POWER STATION, NTPC SINGRAULI, P.O. SHAKTINAGAR	1	20

Cable Termination Kit Suitable For Cables Up To And Including 33 KV (V2) (1 set)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Conformity of the specification	As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV
	Type of termination kit	Outdoor Termination - Heat Shrink
GENERIC	Applicable conductors for using the termination kits	Aluminium
	The appropriate cable for using the termination kits	Armoured Cable
	The appropriate cable insulation for using the termination kits [Ref. Cl. Table 2 of IS 13573 (Part 1)]	XLPE (Range of approval: XLPE, EPR, HEPR, PVC)
	Applicable cable core for using the termination kits (in Nos)	3
	Applicable cable size for using the termination kits (in sq mm)	95

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Termination kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)	Heat Shrink Stress Control Tubing, Heat Shrink Anti Tracking Tubing, Heat Shrink Cable Breakout, Heat Shrink Lug Sealing Tubing, Copper Earthing Tinned Braid With Crimped Lug, Copper Tinned Earthing Braid, Solder, Flux, Jubilee Clamp, Backup Ring, Mastic Tapes, Connector (Lugs), PVC (A) Tape, Amalgamating Insulation Tape for Lug Sealing, Core Cleaning Solvent, Semiconductor Paint, Silicon Grease, Nylon String, Aloxite Tape, Tinned Copper Binding Wire, Mopping Cloth, , Instruction Sheet
	Rain sheds/creepage extender supplied with termination kit	Yes

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Sukesh Jain	231222,SINGRAULI SUPER THERMAL POWER STATION, NTPC SINGRAULI, P.O. SHAKTINAGAR	1	20

Cable Joint Kit Suitable For Cables Up To And Including 33 KV (V2) (2 set)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Conformity of the specification	As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV
	Type of joint kit	Non Rigid - Straight Joint - Heat Shrink
GENERIC	Applicable conductors for using the joint kits	Aluminium
	The appropriate cable for using the joint kits	Armoured Cable
	The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]	XLPE (Range of approval: XLPE, EPR, HEPR, PVC), EPR, HEPR (Range of approval: EPR, HEPR, PVC)
	Applicable cable core for using the joint kits (in Nos)	3

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Applicable cable size for using the joint kits (in sq mm)	185
	Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)	Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet
CERTIFICATIONS	Availability of type test report from Central Govt lab/NABL accredited/ILAC accredited lab to prove conformity of the specification	Yes, As per IS 13573 (Part 2 and Part 3)

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Sukesh Jain	231222,SINGRAULI SUPER THERMAL POWER STATION, NTPC SINGRAULI, P.O. SHAKTINAGAR	2	20

Cable Joint Kit Suitable For Cables Up To And Including 33 KV (V2) (2 set)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Conformity of the specification	As per IS 13573 (Part 2 and Part 3) Working Voltages from 3.3 kV up to and including 33 kV
	Type of joint kit	Non Rigid - Straight Joint - Heat Shrink
GENERIC	Applicable conductors for using the joint kits	Aluminium
	The appropriate cable for using the joint kits	Armoured Cable

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]]	XLPE (Range of approval: XLPE, EPR, HEPR, PVC)
	Applicable cable core for using the joint kits (in Nos)	3
	Applicable cable size for using the joint kits (in sq mm)	95
	Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)	Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet
CERTIFICATIONS	Availability of type test report from Central Govt lab/NABL accredited/ILAC accredited lab to prove conformity of the specification	Yes, As per IS 13573 (Part 2 and Part 3)

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Sukesh Jain	231222,SINGRAULI SUPER THERMAL POWER STATION, NTPC SINGRAULI, P.O. SHAKTINAGAR	2	20

Cable Joint Kit Suitable For Cables Up To And Including 33 KV (V2) (2 set)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Conformity of the specification	As per IS 13573 (Part 1) Working Voltages from 1.1 kV up to and including 3.3 kV

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Type of joint kit	Non Rigid - Straight Joint - Heat Shrink
GENERIC	Applicable conductors for using the joint kits	Aluminium
	The appropriate cable for using the joint kits	Armoured Cable
	The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]	XLPE (Range of approval: XLPE, EPR, HEPR, PVC)
	Applicable cable core for using the joint kits (in Nos)	4
	Applicable cable size for using the joint kits (in sq mm)	16
	Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)	Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Sukesh Jain	231222,SINGRAULI SUPER THERMAL POWER STATION, NTPC SINGRAULI, P.O. SHAKTINAGAR	2	20

Cable Joint Kit Suitable For Cables Up To And Including 33 KV (V2) (2 set)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Conformity of the specification	As per IS 13573 (Part 1) Working Voltages from 1.1 kV up to and including 3.3 kV
	Type of joint kit	Non Rigid - Straight Joint - Heat Shrink
GENERIC	Applicable conductors for using the joint kits	Aluminium
	The appropriate cable for using the joint kits	Armoured Cable
	The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]	XLPE (Range of approval: XLPE, EPR, HEPR, PVC)
	Applicable cable core for using the joint kits (in Nos)	3.5
	Applicable cable size for using the joint kits (in sq mm)	35
	Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)	Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Sukesh Jain	231222, SINGRAULI SUPER THERMAL POWER STATION, NTPC SINGRAULI, P.O. SHAKTINAGAR	2	20

Cable Joint Kit Suitable For Cables Up To And Including 33 KV (V2) (2 set)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Conformity of the specification	As per IS 13573 (Part 1) Working Voltages from 1.1 kV up to and including 3.3 kV
	Type of joint kit	Non Rigid - Straight Joint - Heat Shrink
GENERIC	Applicable conductors for using the joint kits	Aluminium
	The appropriate cable for using the joint kits	Armoured Cable
	The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]	XLPE (Range of approval: XLPE, EPR, HEPR, PVC)
	Applicable cable core for using the joint kits (in Nos)	3.5
	Applicable cable size for using the joint kits (in sq mm)	70
	Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)	Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Sukesh Jain	231222,SINGRAULI SUPER THERMAL POWER STATION, NTPC SINGRAULI, P.O. SHAKTINAGAR	2	20

Cable Joint Kit Suitable For Cables Up To And Including 33 KV (V2) (1 set)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	Conformity of the specification	As per IS 13573 (Part 1) Working Voltages from 1.1 kV up to and including 3.3 kV
	Type of joint kit	Non Rigid - Straight Joint - Heat Shrink
GENERIC	Applicable conductors for using the joint kits	Aluminium
	The appropriate cable for using the joint kits	Armoured Cable
	The appropriate cable insulation for using the joint kits [Ref. Cl. Table 2 of IS 13573 Part 1]	XLPE (Range of approval: XLPE, EPR, HEPR, PVC)
	Applicable cable core for using the joint kits (in Nos)	3.5
	Applicable cable size for using the joint kits (in sq mm)	95
	Joint kit contains (Hint: According to the type of cable, the cross sectional area of the cable and number of cores)	Heat Shrink Stress Control Tubing, Heat Shrink Insulating Tubing, Heat Shrink Co-extruded Dual Wall Tubing, Heat Shrink Outer Jacket Tubing, G. I. Mesh Type Metallic Cannister, Tinned Copper Earthing Braid, Jubilee Clamp, Backup Ring, Mastic Tapes, Tinned Copper Binding Wire, Core Cleaning Solvent, Nylon String, Aloxite Tape, PVC (A) Tape, Silicon Grease, Tinned Copper Mesh for screen continuity, Solder, Flux, Mopping Cloth, Connector (ferrules), Instruction Sheet

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Sukesh Jain	231222,SINGRAULI SUPER THERMAL POWER STATION, NTPC SINGRAULI, P.O. SHAKTINAGAR	1	20

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to

increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. **Generic**

Bidder financial standing: The bidder should not be under liquidation, court receivership or similar proceedings, should not be bankrupt. Bidder to upload undertaking to this effect with bid.

3. **Generic**

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

4. **Generic**

Bidder shall submit the following documents along with their bid for Vendor Code Creation:

- a. Copy of PAN Card.
- b. Copy of GSTIN.
- c. Copy of Cancelled Cheque.
- d. Copy of EFT Mandate duly certified by Bank.

5. **Generic**

Experience Criteria: The Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for 1 year before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the primary product having highest value should meet this criterion.

6. **Generic**

Manufacturer Authorization: Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid

7. **Generic**

Products supplied shall be nontoxic and harmless to health. In the case of toxic materials, Material Safety Data Sheet may be furnished along with the material.

8. **Generic**

Supplier shall ensure that the Invoice is raised in the name of Consignee with GSTIN of Consignee only.

9. **Scope of Supply**

Scope of supply (Bid price to include all cost components) : Only supply of Goods

10. **Rate Contract**

Tax and Duties Toll Tax/ Entry Tax/ Octroi Duty & Local Taxes. No separate payment would be made by the Buyer for Toll Taxes, Entry Taxes, Octroi duty and local Taxes, if any. The Seller should cater for these

Taxes/ duties as part of Basic Rate quoted in the Bid.

11. Rate Contract

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

12. Rate Contract

Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.

13. Rate Contract

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---