

बिड दस्तावेज़ / Bid Document

बिड विवरण / Bid Details	
बिड बंद होने की तारीख/समय / Bid End Date/Time	04-03-2026 12:00:00
बिड खुलने की तारीख/समय / Bid Opening Date/Time	04-03-2026 12:30:00
बिड पेशकश वैधता (बंद होने की तारीख से) / Bid Offer Validity (From End Date)	180 (Days)
मंत्रालय/राज्य का नाम / Ministry/State Name	West Bengal
विभाग का नाम / Department Name	Transport Department West Bengal
संगठन का नाम / Organisation Name	West Bengal Transport Corporation Limited
कार्यालय का नाम / Office Name	Kolkata
कुल मात्रा / Total Quantity	2
वस्तु श्रेणी / Item Category	Distribution Transformer, 3 Phase, 11 kV, >200 KVA upto and Including 2500 KVA ISI Marked To IS 1180 (Part 1) (Q3)
बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का) / Minimum Average Annual Turnover of the bidder (For 3 Years)	40 Lakh (s)
मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का) / OEM Average Turnover (Last 3 Years)	100 Lakh (s)
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष / Years of Past Experience Required for same/similar service	3 Year (s)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / MSE Relaxation for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / Startup Relaxation for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़ / Document required from seller	Experience Criteria, Past Performance, Bidder Turnover, Certificate (Requested in ATC), OEM Authorization Certificate, OEM Annual Turnover *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer

बिड विवरण/Bid Details	
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेन् है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	1
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	3
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	1
विगत प्रदर्शन /Past Performance	40 %
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	Yes
रिवर्स नीलामी योग्यता नियम/RA Qualification Rule	H1-Highest Priced Bid Elimination
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	Distribution Transformer, 3 Phase, 11 kV, >200 KVA upto and Including 2500 KVA ISI Marked To IS 1180 (Part 1)
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	3 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Payment Timelines	Payments shall be made to the Seller within 45 days of issue of consignee receipt-cum-acceptance certificate (CRAC) and on-line submission of bills (This is in supersession of 10 days time as provided in clause 12 of GeM GTC)
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

आवश्यकता/Required	No
-------------------	----

ईपीबीजी विवरण /ePBG Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईपीबीजी प्रतिशत (%) / ePBG Percentage (%)	2.00
ईपीबीजी की आवश्यक अवधि (माह) / Duration of ePBG required (Months).	30

(a) ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

लाभार्थी / Beneficiary :

Chief Engineer
KOLKATA, Transport Department West Bengal, West Bengal Transport Corporation Limited,
(Debabrata Guha)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	No
---	----

एमआईआई खरीद वरीयता/MII Purchase Preference

एमआईआई खरीद वरीयता/MII Purchase Preference	No
--	----

1. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

2. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

3. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

4. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 40% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

5. Reverse Auction would be conducted amongst all the technically qualified bidders except the Highest quoting bidder. The technically qualified Highest Quoting bidder will not be allowed to participate in RA. However, H-1

will also be allowed to participate in RA in following cases:

- If number of technically qualified bidders are only 2 or 3.
- If Buyer has chosen to split the bid amongst N sellers, and H1 bid is coming within N.
- In case Primary product of only one OEM is left in contention for participation in RA on elimination of H-1.
- If L-1 is non-MSE and H-1 is eligible MSE and H-1 price is coming within price band of 15% of Non-MSE L-1
- If L-1 is non-MII and H-1 is eligible MII and H-1 price is coming within price band of 20% of Non-MII L-1

Distribution Transformer, 3 Phase, 11 KV, >200 KVA Upto And Including 2500 KVA ISI Marked To IS 1180 (Part 1) (1 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Energy efficiency level	1
	BEE Star Rating	1
RATINGS	Nominal system voltage, HV (in kV)	11
	Nominal system voltage, LV (in Volt)	415
	Standard ratings (in kVA)	1000
CONSTRUCTION	Core material	CRGO (as per IS:3024 latest)
	Conductor (Winding) material	Copper
	Type of Mounting	Ground Mounted

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Debabrata Guha	700001,Paribahan Bhawan, 12 R.N. Mukherjee Road	1	45

Distribution Transformer, 3 Phase, 11 KV, >200 KVA Upto And Including 2500 KVA ISI Marked To IS 1180 (Part 1) (1 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Energy efficiency level	1
	BEE Star Rating	1
RATINGS	Nominal system voltage, HV (in kV)	11
	Nominal system voltage, LV (in Volt)	415
	Standard ratings (in kVA)	800
CONSTRUCTION	Core material	CRGO (as per IS:3024 latest)
	Conductor (Winding) material	Copper
	Type of Mounting	Ground Mounted

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Debabrata Guha	700001,Paribahan Bhawan, 12 R.N. Mukherjee Road	1	45

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. Scope of Supply

Scope of supply (Bid price to include all cost components) : Supply Installation Testing Commissioning of Goods and Training of operators and providing Statutory Clearances required (if any)

3. **Service & Support**

Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.

4. **Service & Support**

Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.

5. **Service & Support**

Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.

6. **Warranty**

Warranty period of the supplied products shall be 2 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

7. **Warranty**

Successful bidder will have to ensure that adequate number of dedicated technical service personals / engineers are designated / deployed for attending to the Service Request in a time bound manner and for ensuring Timely Servicing / rectification of defects during warranty period, as per Service level agreement indicated in the relevant clause of the bid.

8. **Warranty**

Timely Servicing / rectification of defects during warranty period: After having been notified of the defects / service requirement during warranty period, Seller has to complete the required Service / Rectification within 5 days time limit. If the Seller fails to complete service / rectification with defined time limit, a penalty of 0.5% of Unit Price of the product shall be charged as penalty for each week of delay from the seller. Seller can deposit the penalty with the Buyer directly else the Buyer shall have a right to recover all such penalty amount from the Performance Security (PBG).Cumulative Penalty cannot exceed more than 10% of the total contract value after which the Buyer shall have the right to get the service / rectification done from alternate sources at the risk and cost of the Seller besides forfeiture of PBG. Seller shall be liable to re-imburse the cost of such service / rectification to the Buyer.

9. **Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

West Bengal Transport Corporation Limited

800KVA 11kV Outdoor Package Sub-Station :- Reference Standard - IEC 62271-202

Sl	Description	Specifications
----	-------------	----------------

1	HT Switchgear	11 kV, 630A, 21kA/3 sec, 3 Way, indoor, Non-Extensible SF-6 insulated RMU, comprising 2 No. Fixed Motorised Load Break Switch & 1 No. fixed Motorised Vacuum Circuit Breaker in stainless steel tank- with Operating handle , Voltage presence indicator (VPIS) & manometer integrated earthing switch Self powered IDMT Relay. Interconnection between HT switchgear and transformer shall be using 1Cx3x95 sq.mm Al. unarmoured XLPE Cable
2	Protection CT	30-60/1A, 2.5VA, 5P10 - 3 nos
3	Mechanical position indicator. Switch ON/OFF/EARTHED.	1 set
4	Voltage presence Indication	1 set
5	Manometer	1No
6	Operating Handle	1No
7	RMU shall be capable for cable termination of 1C x 1R x 300 sq.mm unarmoured Al XLPE Cable	
8	12 Window Annunciator	1No
9	Hooter	1No
10	Transformer	800 KVA, 11/0.433 kV, Dyn11, 3 Phase,50hz, Mineral oil filled hermetically sealed transformer with copper winding, +5% to 10% @ 2.5% with off Load tap changer having class-A insulation & temperature rise in oil/winding of 40/45 deg. C [Max.] along with standard fittings & accessories as per IS:1180
11	Losses shall be as per 1180 Energy Efficiency Level-1(2021) Amendment no.-4	
11a	Total losses at 50% Load Total losses at 100% Load	2287 Watts (max.) 6403 Watts (max.)
12	Impedance: %Z	5% (IS Tol.)
13	Oil/Winding temperature indicator with alarm & trip contacts	1No
14	LT Panel: 433V LT Indoor panel with 1200 Amps Aluminium Bus bars (100% for Phase and 50% for Neutral), Fabrication using 1.5/2mm CRCA sheet steel, Ingress protection IP2X/4X, complete with internal wiring consisting of following:	
14a	1250A,4P,433V,50 kA Manually fixed type Microprocessor based release ACB with (O/L,S/C + E/F protection)	1 no
14b	Resin Cast CT- 1200/5A,15VA, Accuracy CL-1.0	3 no

14c	RYB, ON-OFF-TRIP Indication	1No
14d	Digital Multifunction Meter CL-1	1No
15	Outgoings	
15a	630A,4P,36 kA fixed Manual type Microprocessor based MCCB with over current, short circuit & earth fault protection	2No
15b	Digital Multifunction meter with RS 485 Port CL-1.0 with CT's	2No
16	APFC Panel 250 kVAR MPP Standard duty type @440 V	1No
17	Outdoor Enclosure:- 2mm thick painted GI	Outdoor type enclosure having construction of Galvanized Sheet Steel. The Enclosure shall have IP54 degree of protection for HT & LT switchgear compartment & IP34 degree of protection for Transformer compartment. The enclosure exterior shall be Powder coated (Color -as per buyer). Each compartment shall be provided with the door and pad locking arrangement. The Compartment illumination lamp with door operated switch shall be provided for MV & LV compartment.
18	Interconnection & Earthing :	Interconnection Between HT switchgear & Transformer using 1Cx3Rx95Sq.mm XLPE Al Single core cable & Interconnection between Transformers to LT switchgear using Aluminium bus bars. Internal earthing connections including Transformer Neutral by using 50x6 mm GI Strips
19	Requirement is for 800 KVA PSS to be compatible for use to supply power to 2 nos 240KW electric vehicle chargers.	
20	Delivery- Delivery at Kolkata, West Bengal	

1000KVA 11kV Outdoor Package Sub-Station :-Reference Standard - IEC 62271-202

SI	Description	Specifications
1	HT Switchgear :-	11 kV, 630A, 21kA/3 sec, 3 Way, indoor, Non-Extensible SF-6 insulated RMU, comprising 2 No. Fixed Motorised Load Break Switch & 1 No. fixed Motorised Vacuum Circuit Breaker in stainless steel tank- with Operating handle , Voltage presence indicator (VPIS) & manometer integrated earthing switch Self powered IDMT Relay. Interconnection between HT switchgear and transformer shall be using 1Cx3x95 sq.mm Al. unarmoured XLPE Cable
2	Protection CT	30-60/1A, 2.5VA, 5P10 - 3 nos
3	Mechanical position indicator. Switch ON/OFF/EARTHED.	1 set
4	Voltage presence Indication	1 set
5	Manometer	1No
6	Operating Handle	1No
7	RMU shall be capable for cable termination of 1C x 1R x 300 sq.mm unarmoured Al XLPE Cable	
8	12 Window Annunciator	1No
9	Hooter	1No
10	Transformer :-	1000 KVA, 11/0.433 kV, Dyn11, 3 Phase,50hz, Mineral oil filled hermetically sealed transformer with copper winding, +5% to 10% @2.5% with off Load tap changer having class-A insulation & temperature rise in oil/winding of 40/45 deg. C [Max.] along with standard fittings & accessories as per IS:1180
11	Losses shall be as per 1180 Energy Efficiency Level-1(2021) Amendment no.-4	
11a	Total losses at 50% Load Total losses at 100% Load	2790 Watts (max.) 7700 Watts (max.)
12	Impedance: %Z	5% (IS Tol.)
13	Oil/Winding temperature indicator with alarm & trip contacts	1No
14	LT Panel:	433V LT Indoor panel with 1600 Amps Aluminium Bus bars (100% for Phase and 50% for Neutral), Fabrication using 1.5/2mm CRCA sheet steel, Ingress protection IP2 X/4X, complete with internal wiring consisting of following
14a	1600A,4P,433V,50 kA Manually fixed type Microprocessor based release ACB with (O/L,S/C + E/F protection)	1 no
14b	Resin Cast CT- 1600/5A,15VA, Accuracy CL-1.0	3 no

14c	RYB, ON-OFF-TRIP Indication	1No
14d	Digital Multifunction Meter CL-1	1No
15	Outgoings	
15a	630A,4P,36 kA fixed Manual type Microprocessor based MCCB with over current, short circuit & earth fault protection	3No
15b	Digital Multifunction meter with RS 485 Port CL-1.0 with CT's	3No
16	APFC Panel 300 kVAR MPP Standard duty type @440 V	1No
17	Outdoor Enclosure:- 2mm thick painted GI	Outdoor type enclosure having construction of Galvanized Sheet Steel. The Enclosure shall have IP54 degree of protection for HT & LT switchgear compartment & IP34 degree of protection for Transformer compartment. The enclosure exterior shall be Powder coated (Color -as per buyer). Each compartment shall be provided with the door and pad locking arrangement. The Compartment illumination lamp with door operated switch shall be provided for MV & LV compartment.
18	Interconnection & Earthing :	Interconnection Between HT switchgear & Transformer using 1Cx3Rx95Sq.mm XLPE Al Single core cable & Interconnection between Transformers to LT switchgear using Aluminium bus bars. Internal earthing connections including Transformer Neutral by using 50x6 mm GI Strips.
19	Requirement is for 1000 KVA PSS to be compatible for use to supply power to 3 nos 240KW electric vehicle chargers.	
20	Delivery- Delivery at Kolkata, West Bengal	

अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---