

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	07-03-2026 17:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	07-03-2026 17:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	30 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Maharashtra
विभाग का नाम/Department Name	Rural Development And Panchayat Raj Department Maharashtra
संगठन का नाम/Organisation Name	Zilla Parishad Ratnagiri
कार्यालय का नाम/Office Name	Ziilla Parishad Ratnagiri
कुल मात्रा/Total Quantity	12
वस्तु श्रेणी /Item Category	Solar Power Plant (Roof Top) for ONGRID System, Single Phase (Q3)
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष/Years of Past Experience Required for same/similar service	3 Year (s)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Relaxation for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Relaxation for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,Additional Doc 1 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेन् है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)

बिड विवरण/Bid Details

बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	1
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	3
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	1
विगत प्रदर्शन / Past Performance	80 %
बिड से रिवर्स नीलामी सक्रिय किया/ Bid to RA enabled	No
बिड का प्रकार/ Type of Bid	Two Packet Bid
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय / Time allowed for Technical Clarifications during technical evaluation	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/ Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
मूल्यांकन पद्धति/ Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/ Arbitration Clause	No
सुलह खंड/ Mediation Clause	No

ईएमडी विवरण/EMD Detail

आवश्यकता/Required	No
-------------------	----

ईपीबीजी विवरण /ePBG Detail

आवश्यकता/Required	No
-------------------	----

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	No
---	----

एमआईआई खरीद वरीयता/MII Purchase Preference

एमआईआई खरीद वरीयता/MII Purchase Preference	No
--	----

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

2. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 80% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

Solar Power Plant (Roof Top) For ONGRID System, Single Phase (12 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	A Grid Tied Photo Voltaic (SPV) power plant consists of	SPV array, Module Mounting Structure, Power Conditioning Unit (PCU) consisting of Maximum Power Point Tracker (MPPT), Inverter, and Controls and Protections, interconnect cables and switches
	PV Array Mounting	Mounted on a suitable structure
	Grid tied SPV system is	Without battery and designed with necessary features to supplement the grid power during day time.
	Installation and testing for complete system	Yes including Civil Work, Designing, Fabrication, Cabling Work with suitable Bolts, Nuts, Clamps, Connectors and testing etc.,
INVERTER	Rated out put power of inverter (Kw)	3
	Switching device	IGBT, MOSFET
	No. of Phase (in Nos.)	1
	Inverter output wave form	Pure sine wave
	No.of MPPT per inverter (in Nos.)	1, 2, 4
	No. of string at input side of inverter (input port +ve and -ve) (hint: 1 sets contains 1 +ve and 1 -ve port)	1 set, 2 set, 3 set, 4 set
	Maximum power point tracker	Integrated in the PCU/inverter to maximize energy drawn from the array

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Operating Voltage Range of Inverter	50 V to 500 V, 80 to 500 V, 100 V to 500 V, 160 V to 850 V, 200 V to 800 V, 200 V to 1000 V, 90 V to 520 V
	Over load support at Input side, DC	15% of Maximum Input Voltage
	Maximum input current for each MPPT (in A)	11, 18, 22, 28.5
	Service condition	Indoor, Outdoor
	Ingress protection rating of inverter	IP 65 (for outdoor use), IP 23 (for indoor use), IP 20 (for indoor use)
	Cooling medium for inverter	Nature air cooled, Constant speed Fan Cooled, Intelligent fan cooling
	Manual switch for disconnecting DC supply	Yes, No
	Inverter mounting type	Wall Mounted, Floor Mounted
INVERTER OUT PUT	Maximum current for single phase inverter (in A)	5.2, 8.1, 10.5, 15.7, 21, 25
	Output voltage (in V)	240 V
	Invert auto trip at output side	Lower : at 160 V, Higher : at 285 V with adjustable
	Overall Efficiency (in %)	>90, >93, >96, >98
PROTECTION FOR INVERTER	Overlod protection	110% for 1 Minute,, 125% for 30 sec.,, 150% for 5 sec.
	Over temperature protection	Yes at 65 Deg. C Cooling Fan will auto switch ON, Yes at 65 Deg. C shutdown
	Surge protection	Metal Oxide Varistor (MOV)
	Insulation Resistance Monitoring	Yes, No
	Grid Monitoring protection	Yes, No
	Power factor at rated out put power	0.8, 0.9
	Inverter body material	Aluminium Casting, M.S. Plate
SERVICE CONDITION	Operating temperature	-25 to +60 deg. C, -20 to +50 deg. C
DISPLAY FEATURES ON INVERTER	Type of display	LCD, LED
	Display parameters	DC Voltage, DC Current, AC Voltage, AC Current, Out put frequency, Power Factor
	Generating power Data storage facility	Yes for 2 Years from the date of commissioning
	Interface facility for transmitting the generating power data for cloud storage	Inbuilt Wifi Enabled, With Wifi Dongle, With GPRS Dongle without SIM card, With RS485

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Net meter	Approved by Government of India/State Government authority concerned for connecting to Grid
Add on items - DC DISTRIBUTION BOARD	DC Distribution panel to receive the DC output from the array field	Yes with surge arrestors
	Ingress protection (Enclosure protection) of DC Distribution Box	IP65
	Material of bus bar and size	Copper, size as per inverter rating
	Circuit Breaker for input side (DC side) for each inverter	MCB 10 A, MCB 15 A
Add on items - CABLE FOR INPUT	ISI Marked Connecting cables according to Inverter rating for each system	PV Module to Inverter DC
	Electric Cable for Input	1C x 6 Sq. mm, Copper Cable (as per IS:694:2010 latest)
	Cable Length for PV Module to Inverter, DC (in m)	5, 10, 15, 20, 25
Add on items - AC DISTRIBUTION BOARD	AC Distribution Panel Board (DPB) for controlling the AC power from PCU/inverter	1 Phase 230 Volt +/- 10%, 50 HZ +/-3%
	Panel construction	Metal clad, totally enclosed, floor mounted, air insulated, cubical type with change over switch
	Ingress protection (Enclosure protection) of AC Distribution Box	IP54 for Indoor, IP65 for outdoor
	All switches and the circuit breakers, connectors should conform to	IS:60947 part I, II and III
	Panels designed for minimum expected ambient temperature	45 deg. C
	Circuit Breaker for output side (AC side) for each inverter	MCB 10 A, MCB 16 A, MCB 20 A, MCB 25 A, MCB 32 A, MCB 40 A, MCB 63 A, MCB 100 A
Add on items - CABLE FOR OUTPUT	ISI Marked Connecting cables according to Inverter rating for each system.	From Inverter to Net Meter, From Inverter to Net Meter and to mains at LT Bus bar while in grid tied mode
	Conformity of the specification for cable	2C x 6 Sq. mm, Copper Cable (as per IS:694:2010 latest), 2C x 10 Sq. mm, Copper Cable (as per IS:694:2010 latest), 2C x 16 Sq. mm, Copper Cable (as per IS:694:2010 latest)
	Cable length for output side (from inverter to Net Meter for each system) (in m)	5, 10, 15, 20, 25, 30, 35, 40

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Other Add on Items	Cabling work at input side for each system	With PVC Conduit pipe with necessary clamps and screws
	Cabling work at Output side for each system	With Cable Tray with fitment accessories
	Danger boards and signages	1 No., 2 No., 3 No.
ARRAY STRUCTURE	Material of mounting structure	Structural Steel, Grade: E300 (as per IS:2062:2011 latest), Structural Steel, Grade: E350 (as per IS:2062:2011 latest), Structural Steel, Grade: E410 (as per IS:2062:2011 latest)
JUNCTION BOX	Material of Junction Box	GRP(Glass reinforced plastic), FRP (Fibre reinforced plastics), Powder Coated Aluminium, cast aluminium alloy
WIND LOAD	The Mounting structure shall be so designed to withstand the speed for the wind zone of the location where a PV system is proposed to be installed	Yes
	Compliance to wind velocity test for the Mounting structure of PV System	as per IS 875:1987 part 3 latest
	Regional wind withstand capacity which the Mounting structure of PV system support is suitable to withstand (in Km/Hour)	180
WARRANTY & GUARANTEE	Minimum guarantee for maintaing of out put peak watt capacity	> / = 90% at the end of 10 years and >/= 80% at the end of 25 years

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Akshay Ashok Bhole	415612,Social Welfare Department, Zilla Parishad Ratnagiri	12	15

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. Scope of Supply

Scope of supply (Bid price to include all cost components) : Supply Installation Testing Commissioning of Goods and Training of operators and providing Statutory Clearances required (if any)

3. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the

same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---