

बिड दस्तावेज़ / Bid Document

बिड विवरण / Bid Details	
बिड बंद होने की तारीख/समय / Bid End Date/Time	09-04-2026 17:00:00
बिड खुलने की तारीख/समय / Bid Opening Date/Time	09-04-2026 17:30:00
बिड पेशकश वैधता (बंद होने की तारीख से) / Bid Offer Validity (From End Date)	120 (Days)
मंत्रालय/राज्य का नाम / Ministry/State Name	Madhya Pradesh
विभाग का नाम / Department Name	Urban Development And Environment Department
संगठन का नाम / Organisation Name	E-nagar Palika Government Of Madhya Pradesh
कार्यालय का नाम / Office Name	Nagar Parishad Shyamgarh
कुल मात्रा / Total Quantity	2
वस्तु श्रेणी / Item Category	Power Transformer, Oil immersed type (Q3)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / MSE Relaxation for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / Startup Relaxation for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़ / Document required from seller	Certificate (Requested in ATC), OEM Annual Turnover, Additional Doc 2 (Requested in ATC), Additional Doc 3 (Requested in ATC), Additional Doc 4 (Requested in ATC), Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है / Do you want to show documents uploaded by bidders to all bidders participated in bid?	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या / Minimum number of bids required to disable automatic bid extension	1

बिड विवरण/Bid Details	
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	3
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	1
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	No
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	Power Transformer, Oil immersed type
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Payment Timelines	Payments shall be made to the Seller within 45 days of issue of consignee receipt-cum-acceptance certificate (CRAC) and on-line submission of bills (This is in supersession of 10 days time as provided in clause 12 of GeM GTC)
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईएमडी राशि/EMD Amount	20000

ईपीबीजी विवरण /ePBG Detail

आवश्यकता/Required	No
-------------------	----

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित कटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने है। एमएसई कटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b).ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

लाभार्थी /Beneficiary :

CMO

nagar parishad shyamgarh, Urban Development and Environment Department, e-Nagar Palika Government of Madhya Pradesh,
(Cmo Nagar Parisha Shyamgarh)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	No
---	----

एमआईआई खरीद वरीयता/MII Purchase Preference

एमआईआई खरीद वरीयता/MII Purchase Preference	No
--	----

1. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

Power Transformer, Oil Immersed Type (1 pieces)**तकनीकी विशिष्टियाँ /Technical Specifications**

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
RATING	Rated Voltage - HV (in KV)	33
	Rated Voltage - LV (in kV)	11
	Maximum system voltage - HV (in kV)	36
	Maximum system voltage - LV (in kV)	12
	Rated power (in MVA)	5, 6.3, 8, 10, 12.5, 16, 20, 32, 40, 6.5, 30, 30.4, 33.3, 42, 50, 63, 66.7, 80, 100, 150, 160, 166.7, 200, 250, 315, 500, 1, 3.15
	No. of Phase	3
GENERIC	Conformity of the specification	IS:2026 (Part 1) : 2011 latest
	Designed for	Outdoor
	Installation, Testing and Demonstration	No

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
INSULATION LEVEL	Insulation Levels, Dielectric Tests and External Clearances in Air	as per IS: 2026 Part 3: 2009 latest
	Standard rated short duration power-frequency withstand voltage, r.m.s value (in kV)	70
	Standard rated lightning impulse withstand voltage (in kV, peak)	170 (for 33 KV)
WINDING	Winding insulation	Class A
	Connection symbol	Dyn 11
	Terminals of all windings	Out of the tank through bushings for external connections
	Material of barrier insulation including spacers	High Density Press board
TAP CHANGER	Type of Tap Changer	Off Circuit
	Winding tapped at	HV
	No. of tappings (in Nos.)	9
	Range of tappings	+5% to-15% in equal seps of 1.25%
CONSTRUCTION	Material of core	CRGO (ColdRolled GrainOriented steel)
	The maximum flux density in any part of the cores and yoke at normal voltage and frequency	< 1.7 Tesla
	Type of cooling	ONAN
	Transformer filled with oil	Yes
	Method of system earthing	LV connections : Star with neutral solidly earthed
	Type of oil preservation system	Conservator type
	Temperature rise limit - Top oil measured by thermometer	< 50 deg. C
	Temperature rise limit - Winding temperature by resistance	< 55 deg. C
	Percentage of impedance voltage on normal tap and MVA base at 75 deg. C corresponding to HV/ LV rating (in %)	6.25
No Load Losses (Fixed Loss) , Maximum (in KW)	4	

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Load losses at 75°C, Maximum (in KW)	23
	Minium Creppage Distance (in mm)	HV-900 mm
TRANSFORMER TANK	Transformer tank construction shall conform in all respect to	Clause 15 of IS 1180(Part1):2014.
	Transformer tank top cover	Detachable with bolted flanged gasket joint
	The surface of the cover	Flat
	The transformer tank	supported on steel structure
ADD ON ITEMS	Oil conservator tank (in Nos.)	1
	Buchholz Relay	1
	Oil Temperature Indicator (OTI) (in Nos.)	1
	Winding Temperature indicator (WTI) (in Nos.)	1
	Pressure Relief Device (in Nos.)	1
	Oil Level Indicator (in Nos.)	1
	Silica Gel Breather with Silica Gel (in Nos.)	1
	Drain Valve on transformer tank (in Nos.)	1
	Filter Valve on transformer tank (in Nos.)	2
	Oil sampling valve on transformer tank (in Nos.)	2
	Air release plug (in Nos.)	15 mm NB 1 no.
	Lifting eyes or lugs for the top cover, core and coils and for the complete transformer	Yes
	Tank earthing terminals with associated nuts and bolts for connections to grounding strip	2 sets
	HV Bushings according to highest system voltage (in Nos.)	3 (Porcelain)
	LV Bushings according to highest system voltage (in Nos.)	3 (Porcelain)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Terminal arrangement: for HV/LV bushings with arcing horns	Yes
	Suitable terminal connector for HV & LV terminal for holding Conductor	No
	Bus Bars	No
	Cable termination box	1 No. at LV side
	Arrangement for Auxilary supply voltage for	For Alarm, For Relays
	Marshalling box with required glands, locks, glass door, terminal Board, heater with switch, illumination lamp with switch etc to accommodate temperature indicators terminal blocks etc	1
	Ingress protection for Marshalling Box	IP 54
	Padlocks and locking key arrangements for	Mrashalling box
	Foundation bolts for wheel locking devices of Transformer	Yes
	Bi-metallic terminal connector/ clamp/ washers suitable for fixing to bushing terminals	No

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Other requirements	Air release plug, 1 No., Rating Plate, 1 No. Neutral Bushing, Metal parts for Bushings, Gaskets for Bushings, Magnetic oil level gauge: 1 No., Magnetic Oil Level Gauge with Low oil level alarm contacts, 1 No. Cooler fan with motor, HV & LV neutral : brought out on separate bushing, 1 No. Dial type thermometer, Thermometer: Maximum reading pointer, Thermometer: adjustable, Thermometer: Potential free contacts for alarm and trip for top oil temperature ., Additional pockets for mercury-in-glass thermometer for measuring oil and winding temperature, Explosion/ relief vent with double diaphragm equalizer connection, Diagram plates, Terminal marking plate, Identification marking plate, Approved Pressure Relief Device for Rapid Release of Pressure, Under carriage with jacking pads, Under carriage with hauling holes / hook, Supervisory alarm for oil temperature indicator, Supervisorytrip contacts for oil temperature indicator, Supervisory alarm for gas operated double float relay, Supervisory trip contacts for gas operated double float relay, Supervisory alarm contacts for oil level indicator, Inspection cover, Oil filling hole and cap, Thermometer for Oil Temp Indicator 150mm, Dial Type.
	Agreed for unloading of transformer at site	Yes
SPECIAL TEST	Agreed to furnish special test reports as per	Cl.10.1.3 of IS:2026 (Part 1) latest
	Test reports for dielectric special tests	No
	Test report for determination of capacitances winding to earth, and between windings	No
	Test report for determination of transient voltage transfer characteristics	No
	Test reports for measurement of zero sequence impedance (s) on three phase transformers	No
	Test report for determination of sound levels	No
	Test report for measurement of harmonics of the no load current	Yes
	Test report for measurement of the power taken by the fan and oil pump motors	No

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Test report for measurement of insulation resistance to earth of the windings and or measurement of dissipation factor of the insulation system capacitances	Yes
CERTIFICATIONS	Agreed for stage inspection as and when required by buyer / consignee	Yes as per buyer requirements
	Agreed to furnish Guaranteed Technical Particulars (GTP) and complete drawings of Power Transformer as and when required by buyer / consignee	Yes
	Agreed to furnish routine test reports to buyer / consignee on demand	as per Cl.10.1.1 of IS:2026 (Part 1) latest
	Availability of Type test report from Central Government/NABL/ILAC accredited laboratory to prove conformity of the specification	Yes
	Agreed to furnish routine and type test reports for porcelain bushings	Yes

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Suresh Kumar Yadav	458883,nagar parishad shyamgarh	1	30

Power Transformer, Oil Immersed Type (1 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
RATING	Rated Voltage - HV (in KV)	33
	Rated Voltage - LV (in kV)	11
	Maximum system voltage - HV (in kV)	36
	Maximum system voltage - LV (in kV)	12
	Rated power (in MVA)	3.15
	No. of Phase	3
GENERIC	Conformity of the specification	IS:2026 (Part 1) : 2011 latest
	Designed for	Outdoor
	Installation, Testing and Demonstration	No
INSULATION LEVEL	Insulation Levels, Dielectric Tests and External Clearances in Air	as per IS: 2026 Part 3: 2009 latest
	Standard rated short duration power-frequency withstand voltage, r.m.s value (in kV)	70
	Standard rated lightning impulse withstand voltage (in kV, peak)	170 (for 33 KV)
WINDING	Winding insulation	Class A
	Connection symbol	Dyn 11
	Terminals of all windings	Out of the tank through bushings for external connections
	Material of barrier insulation including spacers	High Density Press board
TAP CHANGER	Type of Tap Changer	Off Circuit
	Winding tapped at	HV
	No. of tappings (in Nos.)	9
	Range of tappings	+5% to-15% in equal seps of 1.25%
CONSTRUCTION	Material of core	CRGO (ColdRolled GrainOriented steel)
	The maximum flux density in any part of the cores and yoke at normal voltage and frequency	< 1.7 Tesla
	Type of cooling	ONAN
	Transformer filled with oil	Yes
	Method of system earthing	LV connections : Star with neutral solidly earthed

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Type of oil preservation system	Conservator type
	Temperature rise limit - Top oil measured by thermometer	< 50 deg. C
	Temperature rise limit - Winding temperature by resistance	< 55 deg. C
	Percentage of impedance voltage on normal tap and MVA base at 75 deg. C corresponding to HV/ LV rating (in %)	6.25
	No Load Losses (Fixed Loss) , Maximum (in KW)	4
	Load losses at 75°C, Maximum (in KW)	23
	Minium Creppage Distance (in mm)	HV-900 mm
TRANSFORMER TANK	Transformer tank construction shall conform in all respect to	Clause 15 of IS 1180(Part1):2014.
	Transformer tank top cover	Detachable with bolted flanged gasket joint
	The surface of the cover	Flat
	The transformer tank	supported on steel structure
ADD ON ITEMS	Oil conservator tank (in Nos.)	1
	Buchholz Relay	1
	Oil Temperature Indicator (OTI) (in Nos.)	1
	Winding Temperature indicator (WTI) (in Nos.)	1
	Pressure Relief Device (in Nos.)	1
	Oil Level Indicator (in Nos.)	1
	Silica Gel Breather with Silica Gel (in Nos.)	1
	Drain Valve on transformer tank (in Nos.)	1
	Filter Valve on transformer tank (in Nos.)	2
	Oil sampling valve on transformer tank (in Nos.)	2

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Air release plug (in Nos.)	15 mm NB 1 no.
	Lifting eyes or lugs for the top cover, core and coils and for the complete transformer	Yes
	Tank earthing terminals with associated nuts and bolts for connections to grounding strip	2 sets
	HV Bushings according to highest system voltage (in Nos.)	3 (Porcelain)
	LV Bushings according to highest system voltage (in Nos.)	3 (Porcelain)
	Terminal arrangement: for HV/LV bushings with arcing horns	Yes
	Suitable terminal connector for HV & LV terminal for holding Conductor	No
	Bus Bars	No
	Cable termination box	1 No. at LV side
	Arrangement for Auxiliary supply voltage for	For Alarm, For Relays
	Marshalling box with required glands, locks, glass door, terminal Board, heater with switch, illumination lamp with switch etc to accommodate temperature indicators terminal blocks etc	1
	Ingress protection for Marshalling Box	IP 54
	Padlocks and locking key arrangements for	Mrashalling box
	Foundation bolts for wheel locking devices of Transformer	Yes
	Bi-metallic terminal connector/ clamp/ washers suitable for fixing to bushing terminals	No

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Other requirements	Air release plug, 1 No., Rating Plate, 1 No. Neutral Bushing, Metal parts for Bushings, Gaskets for Bushings, Magnetic oil level gauge: 1 No., Magnetic Oil Level Gauge with Low oil level alarm contacts, 1 No. Dial type thermometer, Thermometer: Maximum reading pointer, Thermometer: Potential free contacts for alarm and trip for top oil temperature ., Explosion/ relief vent with double diaphragm equalizer connection, Diagram plates, Terminal marking plate, Identification marking plate, Under carriage with jacking pads, Under carriage with hauling holes / hook, Supervisory alarm for oil temperature indicator, Supervisory trip contacts for oil temperature indicator, Supervisory alarm for gas operated double float relay, Supervisory trip contacts for gas operated double float relay, Supervisory alarm contacts for oil level indicator, Inspection cover, Oil filling hole and cap, Thermometer for Oil Temp Indicator 150mm, Dial Type.
	Agreed for unloading of transformer at site	Yes
SPECIAL TEST	Agreed to furnish special test reports as per	Cl.10.1.3 of IS:2026 (Part 1) latest
	Test reports for dielectric special tests	No
	Test report for determination of capacitances winding to earth, and between windings	No
	Test report for determination of transient voltage transfer characteristics	No
	Test reports for measurement of zero sequence impedance (s) on three phase transformers	No
	Test report for determination of sound levels	No
	Test report for measurement of harmonics of the no load current	Yes
	Test report for measurement of the power taken by the fan and oil pump motors	No

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Test report for measurement of insulation resistance to earth of the windings and or measurement of dissipation factor of the insulation system capacitances	Yes
CERTIFICATIONS	Agreed for stage inspection as and when required by buyer / consignee	Yes as per buyer requirements
	Agreed to furnish Guaranteed Technical Particulars (GTP) and complete drawings of Power Transformer as and when required by buyer / consignee	Yes
	Agreed to furnish routine test reports to buyer / consignee on demand	as per Cl.10.1.1 of IS:2026 (Part 1) latest
	Availability of Type test report from Central Government/NABL/ILAC accredited laboratory to prove conformity of the specification	Yes
	Agreed to furnish routine and type test reports for porcelain bushings	Yes

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Suresh Kumar Yadav	458883,nagar parishad shyamgarh	1	30

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at

the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. Certificates

ISO 9001: The bidder or the OEM of the offered products must have ISO 9001 certification.

अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---