

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	12-02-2026 16:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	12-02-2026 16:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	60 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Defence
विभाग का नाम/Department Name	Department Of Military Affairs
संगठन का नाम/Organisation Name	Indian Army
कार्यालय का नाम/Office Name	*****
कुल मात्रा/Total Quantity	1625
वस्तु श्रेणी /Item Category	Molded Case Circuit Breakers (MCCB) as per IS / IEC 60947 (Q3) , MCB - Miniature Circuit - Breakers for A.C. Operation as per IS / IEC 60898 (Part 1) (Q2) , LED Batten (Q2) , LED Luminaire for Road and Street Lights (V2) Conforming to IS 10322 (Part 5 / Section 3) (Q3) , LED Luminaire for Floodlight (V2) Conforming to IS 10322 (Part 5/Section 5) (Q3) , XLPE Cable for Working Voltages up to and Including 1.1 KV as per IS 7098 (Part 1) (Q2) , LED Garden Light (V2) (Q2) , LED Bulkhead Light (Q3) , LED 9 W Coloured Spike warm lights , Cable jointing kit for 11 KV straight through cold shrink 3C X 95 Sqmm , LED 2x2 ceiling light 36Watt , Cable jointing kit for 11 KV outdoor termination cold shrink 3C X 95 Sqmm , LED surface fitting round type 12 W , Cable jointing kit for 11 KV straight through cold shrink 3C X 120 Sqmm , LED surface fitting round type 9W , Lamp 9 watt LED , Lamp 12 watt LED , LED surface fitting round type 18W , LED surface fitting round type 15W , Lamp 7 watt LED , Lamp 5 watt LED , 10 Watt Emergency LED Bulb , Cable PVC Alum conductor sheathed 2 point 5 Sqmm 3 Core , Manual changeover switches 100A FP MCOS , LED Driver 60 Watt IP 66

बिड विवरण/Bid Details

GeMARPTS में खोजी गई स्ट्रिंग्स / Searched Strings used in GeMARPTS

LED 9 W Coloured Spike warm lights, Cable jointing kit for 11 KV straight through cold shrink 3C X 95 Sqmm, LED 2x2 ceiling light 36Watt, Cable jointing kit for 11 KV outdoor termination cold shrink 3C X 95 Sqmm, LED surface fitting round type 12 W, Cable jointing kit for 11 KV straight through cold shrink 3C X 120 Sqmm, LED surface fitting round type 9W, Lamp 9 watt LED, Lamp 12 watt LED, LED surface fitting round type 18W, LED surface fitting round type 15W, Lamp 7 watt LED, Lamp 5 watt LED, 10 Watt Emergency LED Bulb, Cable PVC Alum conductor sheathed 2 point 5 Sqmm 3 Core, Manual changeover switches 100A FP MCOS, LED Driver 60 Watt IP 66

Searched String: LED 9 W Coloured Spike warm lights

LED Luminaire (for Flood Light) as per IS 10322, IS 16107, High Mast Lighting Octagonal Tower for Small area with LED Flood Lighting System (V2), Self Ballasted LED Lamps for General Lighting Services (V2) Conforming to IS 16102, Self Ballasted LED Lamps for General Lighting Service as per IS 16102, LED Surface Ceiling Light as per IS 10322, LED Luminaire (Recessed Luminaire) (V2), High Mast Lighting Octagonal Tower with Solar Based LED Street Light, Light Weight Running Shoes (V2) (MHA), Track Light, LED Tube Light (Retrofit Type)

Searched String: Cable jointing kit for 11 KV straight through cold shrink 3C X 95 Sqmm

Cable Joint Kit (V2)

Searched String: LED 2x2 ceiling light 36Watt

Ceiling OT Light, LED Luminaire for Road and Street Lights (V2) Conforming to IS 10322 (Part 5 / Section 3), LED Surface Ceiling Light as per IS 10322, Laboratory Desiccator (V2), Ceiling OT Light (V2), LED Flash Light, LED Bulkhead Light, LED Luminaire (for Flood Light) as per IS 10322, IS 16107, Led Flood Light, Bio - Medical Waste Collection Bags (Biohazard Bags)

Searched String: Cable jointing kit for 11 KV outdoor termination cold shrink 3C X 95 Sqmm

Cable Termination Kit (V2), Cable Joint Kit (V2)

Searched String: LED surface fitting round type 12 W

LED Luminaire (Recessed Luminaire) (V2), LED Light Bar (Strobe or warning lights), Control Cable, White LED Based Solar Street Lighting System for Model (I, II, III And IV)

Searched String: Cable jointing kit for 11 KV straight through cold shrink 3C X 120 Sqmm

Cable Joint Kit (V2)

Searched String: LED surface fitting round type 9W

LED Tube Light (Retrofit Type), Overbed Tables, Upright Bike, Recumbent Bikes, Round Steel Short Link Chains (Electric Butt Welded), Grade L 3 (Part 1) (V2) as per IS 2429

Searched String: Lamp 9 watt LED

विड विवरण / Bid Details	LED PL-L Lamp, LED Luminaire for Road and Street Lights (V2) Conforming to IS 10322 (Part 5 / Section 3), LED
<p>GeMARPTS में खोजा गया परिणाम / Searched Result generated in GeMARPTS</p>	<p>Portable Miner's Cap Lamp for use in Underground Mines (LED Lamp), Inspection Lamp, LED PL-L (Plug-in Long) Lamp (V2), LED Luminaire for Floodlight (V2) Conforming to IS 10322 (Part 5/Section 5), LED Portable Miner's Cordless Cap Lamp (V2), Hand Lamp, Self Ballasted LED Lamps (LED Bulb) (V3) Conforming to IS 16102 (Part 2) (Under BIS Scheme - II), Hand Held Search Light</p> <p>Searched String: Lamp 12 watt LED</p> <p>LED PL-L Lamp, LED Luminaire for Road and Street Lights (V2) Conforming to IS 10322 (Part 5 / Section 3), LED Portable Miner's Cap Lamp for use in Underground Mines (LED Lamp), Inspection Lamp, LED PL-L (Plug-in Long) Lamp (V2), LED Luminaire for Floodlight (V2) Conforming to IS 10322 (Part 5/Section 5), LED Portable Miner's Cordless Cap Lamp (V2), Hand Lamp, Self Ballasted LED Lamps (LED Bulb) (V3) Conforming to IS 16102 (Part 2) (Under BIS Scheme - II), Hand Held Search Light</p> <p>Searched String: LED surface fitting round type 18W</p> <p>LED Tube Light (Retrofit Type), Upright Bike, Recumbent Bikes, Steel Clothes Lockers (V3) conforming To Is 3314</p> <p>Searched String: LED surface fitting round type 15W</p> <p>Hand Held Search Light, Upright Bike, Control Cable, Recumbent Bikes</p> <p>Searched String: Lamp 7 watt LED</p> <p>LED PL-L Lamp, LED Luminaire for Road and Street Lights (V2) Conforming to IS 10322 (Part 5 / Section 3), LED Portable Miner's Cap Lamp for use in Underground Mines (LED Lamp), Hand Lamp, LED PL-L (Plug-in Long) Lamp (V2), LED Luminaire for Floodlight (V2) Conforming to IS 10322 (Part 5/Section 5), LED Portable Miner's Cordless Cap Lamp (V2), Machine Light, Self Ballasted LED Lamps (LED Bulb) (V3) Conforming to IS 16102 (Part 2) (Under BIS Scheme - II), Hand Held Search Light</p> <p>Searched String: Lamp 5 watt LED</p> <p>LED PL-L Lamp, LED Luminaire for Road and Street Lights (V2) Conforming to IS 10322 (Part 5 / Section 3), LED Portable Miner's Cap Lamp for use in Underground Mines (LED Lamp), Inspection Lamp, LED PL-L (Plug-in Long) Lamp (V2), LED Luminaire for Floodlight (V2) Conforming to IS 10322 (Part 5/Section 5), Hand Lamp, LED Portable Miner's Cordless Cap Lamp (V2), Hand Held Search Light, Self Ballasted LED Lamps (LED Bulb) (V3) Conforming to IS 16102 (Part 2) (Under BIS Scheme - II)</p> <p>Searched String: 10 Watt Emergency LED Bulb</p> <p>Rechargeable LED Bulb (V2), LED Luminaire for Road and Street Lights (V2) Conforming to IS 10322 (Part 5 / Section 3), T Bulb, Pipe Clamps (V2), Flameproof LED Emergency Light, LED Luminaire for Floodlight (V2) Conforming to IS 10322 (Part 5/Section 5), Self Ballasted LED Lamps (LED Bulb) (V3) Conforming to IS 16102 (Part 2) (Under BIS Scheme - II), LED Bulb with Battery as per IS 16102, Hand Held Search Light, Emergency Light Unit (V2)</p>

बिड विवरण / Bid Details	<p>Searched String: Cable PVC Alum conductor sheathed 2 point 5 Sqmm 3 Core</p>
	<p>PVC Aluminium Cable 1 Core and Multi Core Circular Sheathed Cable with Rigid Conductor as per IS 694, PVC Copper Cable Single Core and Multi Core Circular Sheathed Cable with Rigid Conductor (V2) as per IS 694, PVC Single Core and Multi Core Circular Sheathed Aluminium Cable with Rigid Conductor (V2) as per IS 694, PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694, PVC Copper Cable 1 Core and Multi Core Circular Sheathed Cable with Rigid Conductor as per IS 694, PVC Copper Cable Single Core and Multi Core Circular Sheathed Cord with Flexible Conductor (V2) as per IS 694, PVC Copper Cable Single and Multi Core Circular Sheathed Cable with Flexible Conductor as per IS 694, PVC Copper Cable Multi Core Circular Sheathed Cables with Flexible Conductor as per IS 694, PVC Copper Cable Single and Multi Core Circular Sheathed Cord with Flexible Conductor as per IS 694, PVC Flat Cable, Copper Conductor with PVC Insulation and Sheath as per IS 694</p> <p>Searched String: Manual changeover switches 100A FP MCOS</p> <p>Category not available on GeM for the text string uploaded by the buyer</p> <p>Searched String: LED Driver 60 Watt IP 66</p> <p>LED Luminaire for Road and Street Lights (V2) Conforming to IS 10322 (Part 5 / Section 3), Led post top lantern, Led Flood Light, LED Luminaire for Floodlight (V2) Conforming to IS 10322 (Part 5/Section 5)</p>
<p>अधिसूचना के लिए चयनित प्रासंगिक श्रेणियाँ / Relevant Categories selected for notification</p>	<ul style="list-style-type: none"> LED Luminaire (Recessed Luminaire) (V3) Conforming to IS 10322 (Part 5/Section 2)
<p>बीओक्यू शीर्षक / BOQ Title</p>	<p>MISC Item</p>
<p>बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का) / Minimum Average Annual Turnover of the bidder (For 3 Years)</p>	<p>10 Lakh (s)</p>
<p>मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का) / OEM Average Turnover (Last 3 Years)</p>	<p>80 Lakh (s)</p>
<p>उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष / Years of Past Experience Required for same/similar service</p>	<p>3 Year (s)</p>
<p>वर्षों के अनुभव एवं टर्नओवर से एमएसई को छूट प्राप्त है / MSE Relaxation for Years Of Experience and Turnover</p>	<p>Yes Complete</p>
<p>स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / Startup Relaxation for Years Of Experience and Turnover</p>	<p>Yes Complete</p>

बिड विवरण/Bid Details	
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover,Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	No
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	3
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	3
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	3
विगत प्रदर्शन /Past Performance	50 %
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	Yes
रिवर्स नीलामी योग्यता नियम/RA Qualification Rule	H1-Highest Priced Bid Elimination
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	LED Batten
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईएमडी राशि/EMD Amount	20000

ईपीबीजी विवरण /ePBG Detail

आवश्यकता/Required	No
-------------------	----

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने है। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b).ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

लाभार्थी /Beneficiary :

GARRISON ENGINEER
MILITARY ENGINEER SERVICES
(Ge)

UIN Number NCTGC2415P

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई खरीद वरीयता / MII Purchase Preference

एमआईआई खरीद वरीयता / MII Purchase Preference	Yes
मेक इन इंडिया विक्रेताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में है / Purchase Preference to MII sellers available upto price within L1+X%	20
मेक इन इंडिया खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MII purchase preference	50
सार्वजनिक खरीद (मेक-इन-इंडिया को प्राथमिकता) आदेश 2017 के अनुसार केवल क्लास 1/क्लास 2 के स्थानीय आपूर्तिकर्ताओं को ही भागीदारी की अनुमति है दिनांक 16.09.2020 (समय-समय पर संशोधित एवं लागू) / Allow participation only from Class 1/Class 2 local suppliers as per the Public procurement(Preference to Make-in-india) order 2017 date 16.09.2020(as amended and applicable time to time)	Yes, in compliance with the MII ORDER : DPIIT Order(as amended and applicable time to time)

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
---	-----

सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within L1+X%	15
सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference	25

1. If the bidder is a Micro or Small Enterprise as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Experience Criteria" as defined above subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Experience Criteria, shall upload the supporting documents to prove his eligibility for Relaxation.
2. If the bidder is a Micro or Small Enterprise (MSE) as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Bidder Turnover" as defined above subject to meeting of quality and technical specifications. If the bidder itself is MSE OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover, shall upload the supporting documents to prove his eligibility for Relaxation.
3. If the bidder is a DPIIT registered Startup, the bidder shall be relaxed from the the eligibility criteria of "Experience Criteria" as defined above subject to their meeting of quality and technical specifications. The bidder seeking Relaxation from Experience Criteria, shall upload the supporting documents to prove his eligibility for Relaxation.
4. If the bidder is a DPIIT registered Startup, the bidder shall be relaxed from the the eligibility criteria of "Bidder Turnover" as defined above subject to their meeting of quality and technical specifications. If the bidder is DPIIT Registered OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover shall upload the supporting documents to prove his eligibility for Relaxation.
5. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
6. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.
7. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
8. Preference to Make In India products (For bids < 200 Crore):Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The

buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

9. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

10. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

11. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 50% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

12. Reverse Auction would be conducted amongst all the technically qualified bidders except the Highest quoting bidder. The technically qualified Highest Quoting bidder will not be allowed to participate in RA. However, H-1 will also be allowed to participate in RA in following cases:

- i. If number of technically qualified bidders are only 2 or 3.
- ii. If Buyer has chosen to split the bid amongst N sellers, and H1 bid is coming within N.
- iii. In case Primary product of only one OEM is left in contention for participation in RA on elimination of H-1.
- iv. If L-1 is non-MSE and H-1 is eligible MSE and H-1 price is coming within price band of 15% of Non-MSE L-1
- v. If L-1 is non-MII and H-1 is eligible MII and H-1 price is coming within price band of 20% of Non-MII L-1

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (2 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	YES
	Rated Current (in Ampere)	200A
	No of poles/Protected poles(PP)	4 Pole

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35/50/65 KA tripping range
	Breaking current (in KA)	36 KA
	Rated Voltage	240/415 Volt 50 Hz AC

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	2	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (2 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	YES
	Rated Current (in Ampere)	250A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35/50/65 KA tripping range
	Breaking current (in KA)	36 KA
	Rated Voltage	240/415 Volt 50 Hz AC

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	2	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	YES
	Rated Current (in Ampere)	400A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	35 KA
	Breaking current (in KA)	35 KA
	Rated Voltage	415 volt 50 Hz

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	1	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (2 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	YES

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Rated Current (in Ampere)	160A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	35 KA
	Rated Voltage	240 Volt 50 Hz AC, 240/415 Volt 50 Hz AC

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	2	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	YES
	Rated Current (in Ampere)	200A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	25 KA
	Rated Voltage	415 volt 50 Hz

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	1	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (2 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	YES
	Rated Current (in Ampere)	125A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity 10/16 KA tripping range
	Breaking current (in KA)	16 KA
	Rated Voltage	240/415 Volt 50 Hz AC

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	2	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	YES

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Rated Current (in Ampere)	400A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	25 KA
	Rated Voltage	240/415 Volt 50 Hz AC

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	1	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	YES
	Rated Current (in Ampere)	160A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	25 KA
	Rated Voltage	240/415 Volt 50 Hz AC

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	1	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	YES
	Rated Current (in Ampere)	63A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	16 KA
	Rated Voltage	240 Volt 50 Hz AC

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	1	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	YES

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Rated Current (in Ampere)	100A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	36 KA
	Rated Voltage	240/415 Volt 50 Hz AC

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	1	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	YES
	Rated Current (in Ampere)	100A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35/50/65 KA tripping range
	Breaking current (in KA)	25 KA
	Rated Voltage	220VDC

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	1	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (14 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	4 P with 3 PP
	Rated voltage (in Volts)	230 / 415 V, AC
	Rated Current (in Ampere)	63
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Yes with 1.2 mm thick

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	14	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (15 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local

Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 2 PP
	Rated voltage (in Volts)	415 V, AC
	Rated Current (in Ampere)	63
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	7500
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	15	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (14 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 2 PP
	Rated voltage (in Volts)	230 / 415 V, AC
	Rated Current (in Ampere)	40
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	15000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	14	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (8 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 2 PP
	Rated voltage (in Volts)	230 / 415 V, AC

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Rated Current (in Ampere)	32
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	7500
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	8	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (3 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 2 PP
	Rated voltage (in Volts)	240 V, AC
	Rated Current (in Ampere)	20
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	6000

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	3	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (2 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 1 PP
	Rated voltage (in Volts)	240 / 415 V, AC
	Rated Current (in Ampere)	40
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	2	30

LED Batten (566 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	LED Batten Rating (in Watts)	20.0
	Length of LED Batten (Nominal) (in mm)	1150.0
	Lamp Efficacy (Lumen / Watt), Minimum	110 Or higher
	Warranty for free replacement (in Years)	3 Or higher
CONSTRUCTIONAL	Housing Material	Polycarbonate
	Colour Rendering Index (CRI) - Minimum	70, 80 Or higher
	Total Harmonics (%), Maximum	15, 20 Or lower
	Operating Voltage range (in Volts)	100 to 300

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	566	30

LED Batten (46 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	LED Batten Rating (in Watts)	10.0
	Length of LED Batten (Nominal) (in mm)	560.0
	Lamp Efficacy (Lumen / Watt), Minimum	110 Or higher
	Warranty for free replacement (in Years)	3 Or higher
CONSTRUCTIONAL	Housing Material	Polycarbonate

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	46	30

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (25 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	90

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	140 to 270 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	1, 2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	50 cm (ISI marked to IS 9968)
MARKING	LED Make	Other than OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND/APT
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	5 Or higher

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	25	30

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (26 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	45
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	140 to 270 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	50 cm (ISI marked to IS 9968)
MARKING	LED Make	Other than OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND/APT
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	3, 4, 5 Or higher

परिषेती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N O.	परिषेती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	26	30

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (14 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* [जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	60
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	100, 120, 140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	90 to 300 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	50 cm (ISI marked to IS 9968)
MARKING	LED Make	Other than OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND/APT
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	4, 5 Or higher

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N O.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	14	30

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (11 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	24
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	100, 120, 140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	140 to 270 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	1, 2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	50 cm (ISI marked to IS 9968)
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	3, 4, 5 Or higher

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	11	30

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (3 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	18
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	100, 120, 140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	90 to 300 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	1, 2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	50 cm (ISI marked to IS 9968)
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	5 Or higher

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	3	30

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (6 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	36
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	140 to 270 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	1, 2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	50 cm (ISI marked to IS 9968)
MARKING	LED Make	Other than OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND/APT
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	3, 4, 5 Or higher

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N O.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	6	30

LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (8 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating/System Wattage/Rated Power (in Watts)	100
	Colour Temperature (in K) (+/- 500K)	3000
CONSTRUCTION	Length of ISI marked 3 core cable (shall be provided along with supply of material) (in m)	0.5
MARKING	LED Make	Other than OSRAM / NICHIA/CREE / SAMSUNG / SEOUL / LUMILED / PHILIPS / EDISON / SYSKA / LUMENMAX / EVERLIGHT / BRIDGELUX / NATIONSTAR / REFOND/APT

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	8	30

LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (9 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating/System Wattage/Rated Power (in Watts)	50
	Colour Temperature (in K) (+/- 500K)	3000
CONSTRUCTION	Length of ISI marked 3 core cable (shall be provided along with supply of material) (in m)	0.5

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
MARKING	LED Make	Other than OSRAM / NICHIA/CREE / SAMSUNG / SEOUL / LUMILED / PHILIPS / EDISON / SYSKA / LUMENMAX / EVERLIGHT / BRIDGELUX / NATIONSTAR / REFOND/APT

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	9	30

LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (9 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating/System Wattage/Rated Power (in Watts)	30
	Colour Temperature (in K) (+/- 500K)	3000
CONSTRUCTION	Length of ISI marked 3 core cable (shall be provided along with supply of material) (in m)	0.5
MARKING	LED Make	Other than OSRAM / NICHIA/CREE / SAMSUNG / SEOUL / LUMILED / PHILIPS / EDISON / SYSKA / LUMENMAX / EVERLIGHT / BRIDGELUX / NATIONSTAR / REFOND/APT

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	9	30

LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (4 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating/System Wattage/Rated Power (in Watts)	80
	Colour Temperature (in K) (+/- 500K)	3000
CONSTRUCTION	Length of ISI marked 3 core cable (shall be provided along with supply of material) (in m)	0.5
MARKING	LED Make	Other than OSRAM / NICHIA/CREE / SAMSUNG / SEOUL / LUMILED / PHILIPS / EDISON / SYSKA / LUMENMAX / EVERLIGHT / BRIDGELUX / NATIONSTAR / REFOND/APT

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	4	30

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (30 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	Yes
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	70
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Un-vulcanized rubber
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized round steel wire
	Type of armouring	Double wire
CERTIFICATION	Availability of Optional Test Reports	Not applicable

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	30	30

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (70 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	10
	Number of core (in Nos)	2
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized round steel wire
	Type of armouring	Double wire, Double strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	70	30

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (45 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	25
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized round steel wire
	Type of armouring	Double wire
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	45	30

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (51 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	Yes
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	10
	Number of core (in Nos)	4
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Aluminium round wire
	Type of armouring	Double wire
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	51	30

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (21 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	16
	Number of core (in Nos)	4
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Double wire
CERTIFICATION	Availability of Optional Test Reports	Not applicable

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	21	30

LED Garden Light (V2) (4 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
---------------------	-------------------------------------	---

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Type of Garden Light	Bollard type with Pole and LED lantern/luminaire, Architectural design with pole and LED lantern/luminaire, LED post top lantern/luminaire with pole
	Material of Garden Lighting pole including lighting system (lantern/luminaire) (Note: Wherever GI, MS, CI materials used, materials shall be ISI Marked)	Aluminium casting, Galvanised Iron, Mild steel, Cast iron, LED post top with out pole. Hence not applicable
	Pole height including lantern/luminaire (in m)	0.5, 1, 1.5, 3, 4, 5, 6, 7, 8, without pole
	No.of lantern/luminaire with each pole (in m)	1, 2, 3, 4, 5, LED post top with out pole. Hence not applicable
LIGHT SOURCE	Type of light source - BEE star rating of LED Bulb	LED Bulb - 3 Star
	LED Rating in each lantern/luminaire/lighting system (in Watts)	20.0
	LED Lamp/System efficacy in each lantern / luminaire (in lumen / watt)	? 105 and < 120
	In case of LED bulb - Cap designation of each lamp and holder in each lantern / luminaire	B22d
PROTECTION	Automatic Lower / Higher Cut off voltage	Yes. Lower cut off 120 V, Higher cut off 300 V
	Protection against surges and transients - External	> / = 10 KV Or higher
THERMAL MANAGEMENT	Minimum Operating Temperature (in deg. C)	-10
	Maximum Operating Temperature (in deg. C)	50
LANTERN/LUMINAIRE - CONSTRUCTION	Impact resistance on diffuser material (in IK)	7
	Protection of the entire housing (in IP) Protection of the entire housing as per IS:10322 (Part 1):1982 latest	65
	Length of ISI marked three core connecting wire (Provided along with each lantern/luminiare) - (in m)	0.5

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
CERTIFICATIONS	Warranty for free replacement of lighting systems including lightsource (in years)	1
ADVANCE SAMPLE	Agreed to provide Advance Sample(s) for buyer's approval before commencement of supply. (hint: Applicable in case of orders placed against bid and not applicable in case of Direct Buying)	Yes

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	4	30

LED Garden Light (V2) (3 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Type of Garden Light	Bollard type with Pole and LED lantern/luminaire, Architectural design with pole and LED lantern/luminaire, LED post top lantern/luminaire with pole
	Material of Garden Lighting pole including lighting system (lantern/luminaire) (Note: Wherever GI, MS, CI materials used, materials shall be ISI Marked)	Aluminium casting, Galvanised Iron, Mild steel, Cast iron, LED post top with out pole. Hence not applicable
	Pole height including lantern/luminaire (in m)	0.5, 1, 1.5, 3, 4, 5, 6, 7, 8, without pole
	No.of lantern/luminaire with each pole (in m)	1, 2, 3, 4, 5, LED post top with out pole. Hence not applicable

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LIGHT SOURCE	Type of light source - BEE star rating of LED Bulb	SMD LED Chip
	LED Rating in each lantern/luminaire/lighting system (in Watts)	30.0
	LED Lamp/System efficacy in each lantern / luminaire (in lumen / watt)	? 120 and < 135
	In case of LED bulb - Cap designation of each lamp and holder in each lantern / luminaire	Not applicable (for SMP LED Chip)
PROTECTION	Automatic Lower / Higher Cut off voltage	Yes. Lower cut off 120 V, Higher cut off 300 V
	Protection against surges and transients - External	> / = 10 KV Or higher
THERMAL MANAGEMENT	Minimum Operating Temperature (in deg. C)	-10
	Maximum Operating Temperature (in deg. C)	55
LANTERN/LUMINAIRE - CONSTRUCTION	Impact resistance on diffuser material (in IK)	8
	Protection of the entire housing (in IP) Protection of the entire housing as per IS:10322 (Part 1):1982 latest	66
	Length of ISI marked three core connecting wire (Provided along with each lantern/luminiare) - (in m)	0.5
CERTIFICATIONS	Warranty for free replacement of lighting systems including lightsource (in years)	1
ADVANCE SAMPLE	Agreed to provide Advance Sample(s) for buyer's approval before commencement of supply. (hint: Applicable in case of orders placed against bid and not applicable in case of Direct Buying)	No

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	3	30

LED Bulkhead Light (16 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Material	Plastic
	Protection	IP44, IP55, IP65, IP66
	Driver included	Yes
	Beam Angle of Light Source	100.0 (degree)
Power Requirements	Power	9.0 (Watt)
Performance Parameters	Life Time	50000.0 (hour)
	Protection class IEC	NA
	Luminous flux (system flux)	720.0 (lumen)
Dimensions and Size	Depth	75.0 (millimeter)
	Length	230.0 (millimeter)
	Width	100.0 (millimeter)
Warranty	Warranty	2 Or higher (year)

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	16	30

LED 9 W Coloured Spike Warm Lights

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	20	30

Cable Jointing Kit For 11 KV Straight Through Cold Shrink 3C X 95 Sqmm

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	4	30

LED 2x2 Ceiling Light 36Watt

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	30	30

Cable Jointing Kit For 11 KV Outdoor Termination Cold Shrink 3C X 95 Sqmm

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	1	30

LED Surface Fitting Round Type 12 W

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	20	30

Cable Jointing Kit For 11 KV Straight Through Cold Shrink 3C X 120 Sqmm

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	1	30

LED Surface Fitting Round Type 9W

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
-------------------------------	---------------------------

BOQ Detail Document[View File](#)

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	40	30

Lamp 9 Watt LED

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document[View File](#)**BOQ Detail Document**[View File](#)

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	125	30

Lamp 12 Watt LED

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document[View File](#)**BOQ Detail Document**[View File](#)

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	60	30

LED Surface Fitting Round Type 18W

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	15	30

LED Surface Fitting Round Type 15W

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	10	30

Lamp 7 Watt LED

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	100	30

Lamp 5 Watt LED

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	75	30

10 Watt Emergency LED Bulb

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	10	30

Cable PVC Alum Conductor Sheathed 2 Point 5 Sqmm 3 Core

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	70	30

Manual Changeover Switches 100A FP MCOS

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	2	30

LED Driver 60 Watt IP 66

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****EAST DISTRICT	4	30

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. **Generic**

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. **Generic**

Bidder financial standing: The bidder should not be under liquidation, court receivership or similar proceedings, should not be bankrupt. Bidder to upload undertaking to this effect with bid.

3. **Generic**

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

4. **Generic**

Bidder shall submit the following documents along with their bid for Vendor Code Creation:

- Copy of PAN Card.
- Copy of GSTIN.
- Copy of Cancelled Cheque.
- Copy of EFT Mandate duly certified by Bank.

5. **Generic**

Data Sheet of the product(s) offered in the bid, are to be uploaded along with the bid documents. Buyers can match and verify the Data Sheet with the product specifications offered. In case of any unexplained mismatch of technical parameters, the bid is liable for rejection.

6. **Scope of Supply**

Scope of supply (Bid price to include all cost components) : Only supply of Goods

7. **Turnover**

Bidder Turn Over Criteria: The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

8. **Turnover**

OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria. In case of bunch bids, the OEM of CATEGORY RELATED TO primary product having highest bid value should meet this criterion.

9. **Certificates**

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

10. **Certificates**

ISO 9001: The bidder or the OEM of the offered products must have ISO 9001 certification.

11. **Certificates**

The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

12. **Buyer Added Bid Specific ATC**

Buyer uploaded ATC document [Click here to view the file.](#)

13. **Generic**

Experience Criteria: The Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for 3 years before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the primary product having highest value should meet this criterion.

14. **Generic**

Manufacturer Authorization: Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid

अस्वीकरण/**Disclaimer**

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---