

बिड दस्तावेज़ / Bid Document

| बिड विवरण / Bid Details | |
|---|--|
| बिड बंद होने की तारीख/समय / Bid End Date/Time | 10-04-2026 13:00:00 |
| बिड खुलने की तारीख/समय / Bid Opening Date/Time | 10-04-2026 13:30:00 |
| बिड पेशकश वैधता (बंद होने की तारीख से) / Bid Offer Validity (From End Date) | 90 (Days) |
| मंत्रालय/राज्य का नाम / Ministry/State Name | Ministry Of Railways |
| विभाग का नाम / Department Name | Indian Railways |
| संगठन का नाम / Organisation Name | North Western Railway |
| कार्यालय का नाम / Office Name | North Western Railway |
| कुल मात्रा / Total Quantity | 1 |
| वस्तु श्रेणी / Item Category | Diesel Power Generator (up to 900 KVA) (Q2) |
| उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष / Years of Past Experience Required for same/similar service | 3 Year (s) |
| एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / MSE Relaxation for Years of Experience and Turnover | No |
| स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / Startup Relaxation for Years of Experience and Turnover | No |
| विक्रेता से मांगे गए दस्तावेज़ / Document required from seller | Experience Criteria, Past Performance, Certificate (Requested in ATC), OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer |
| क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेन् है / Do you want to show documents uploaded by bidders to all bidders participated in bid? | No |
| बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या / Minimum number of bids required to disable automatic bid extension | 1 |

| बिड विवरण/Bid Details | |
|--|-----------------------------|
| दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended | 3 |
| ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count | 1 |
| विगत प्रदर्शन / Past Performance | 50 % |
| बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled | No |
| बिड का प्रकार/ Type of Bid | Single Packet Bid |
| तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय / Time allowed for Technical Clarifications during technical evaluation | 2 Days |
| निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/ Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM) | No |
| अनुमानित बिड मूल्य / Estimated Bid Value | 1533204 |
| मूल्यांकन पद्धति/ Evaluation Method | Total value wise evaluation |
| मध्यस्थता खंड/ Arbitration Clause | No |
| सुलह खंड/ Mediation Clause | No |

ईएमडी विवरण/EMD Detail

| | |
|-----------------------------|---------------------|
| एडवाइजरी बैंक/Advisory Bank | State Bank of India |
| ईएमडी राशि/EMD Amount | 30670 |

ईपीबीजी विवरण /ePBG Detail

| | |
|-------------------|----|
| आवश्यकता/Required | No |
|-------------------|----|

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने है। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b).ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

लाभार्थी /Beneficiary :

Dy.FA&CAO/W&S/All

Dy CMM, General Stores Depot, Nagra, Ajmer-305001

(Dy.fa And Cao/ W And S / Aii)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई खरीद वरीयता / MII Purchase Preference

| | |
|---|---|
| एमआईआई खरीद वरीयता / MII Purchase Preference | Yes |
| मेक इन इंडिया विक्रेताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में है / Purchase Preference to MII sellers available upto price within L1+X% | 20 |
| मेक इन इंडिया खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MII purchase preference | 50 |
| सार्वजनिक खरीद (मेक-इन-इंडिया को प्राथमिकता) आदेश 2017 के अनुसार केवल क्लास 1/क्लास 2 के स्थानीय आपूर्तिकर्ताओं को ही भागीदारी की अनुमति है दिनांक 16.09.2020 (समय-समय पर संशोधित एवं लागू) / Allow participation only from Class 1/Class 2 local suppliers as per the Public procurement(Preference to Make-in-india) order 2017 date 16.09.2020(as amended and applicable time to time) | Yes, in compliance with the MII ORDER : DPIIT Order(as amended and applicable time to time) |

एमएसई खरीद वरीयता/MSE Purchase Preference

| | |
|--|-----|
| एमएसई खरीद वरीयता/MSE Purchase Preference | Yes |
| सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within L1+X% | 15 |
| सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference | 25 |

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

2. Preference to Make In India products (For bids < 200 Crore):Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which

no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

3. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

4. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

5. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 50% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

Diesel Power Generator (up To 900 KVA) (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

| विवरण/Specification | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|----------------------------|--|--|
| Installation Configuration | Power Generator Installation Configurations as per CPWD General Specifications for Electrical Works - Part VII (DG Set) | Fixed (Power Generators are permanently installed)" |
| Ratings | Nominal Rated Capacity (in kVA) | 82.5 |
| | Number of Phase | Three Phase |

| विवरण/Specification | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|---------------------|--|--|
| Engine | Rated Engine Power (kWm) | 100 % of the required powered at STP(Standard Temperature Pressure) i.e equal to (Nominal Rated Capacity (KVA) of power generator + Any Auxiliary power Consumption by the Power generator) x Power factor(0.8) / Alternator efficiency, 110 % of the required powered at STP(Standard Temperature Pressure) i.e equal to (Nominal Rated Capacity (KVA) of power generator Any Auxiliary power Consumption by the Power generator) x Power factor(0.8) / Alternator efficiency Or higher |
| | Type of Engine Cooling | Liquid Cooled |
| | Type of Governor | Electronic Or higher |
| | Number of Cylinders | 4 |
| | Rated Engine Speed (in RPM) | 1500 |
| | Type of Fuel | High Speed Diesel (HSD) |
| | Starting Voltage (in volt) | 12 |
| | Salient Features of Engine [Hint: Products matching all selected values will be displayed; For example, if both 'Turbo Charged Engine' and 'Direct injection Fuel System' are selected, product that include both options will be shown] | Turbo Charged Engine, Direct injection Fuel System, CRDi Fuel System |
| Alternator | Alternator Voltage Rating | 415.0 (Volt) |
| | Conformity to Indian Standard For Alternator | Generally conforming to IS:13364 (Part-2) latest (Above 20 KVA) |
| | Voltage Regulation Grade | VG 3 Or higher |
| | Alternator IP (Ingress Protection) Rating | IP 23 Or higher |
| | Salient Features of Alternator [Hint: Products matching all selected values will be displayed; For example, if both 'space heater' and 'Bearing Temperature Detectors (BTD)' are selected, product that include both options will be shown] | NA |
| Control Panel | Type of Control Panel | AMF Control Panel |
| | Control Panel Location | Outside the Canopy |
| | IP (Ingress Protection) Rating of Control Panel | IP 53, IP 54, IP 55 Or higher |

| विवरण/Specification | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|---------------------|---|---|
| | Display Meters in Control Panel (with Appropriate Rating and Accuracy Class) - Included in Scope of Supply | Multifunctional Digital display meter (displaying Voltage, Current, Frequency, Power Factor) |
| | Other Devices in Control Panel (with Appropriate Rating) - Included in Scope of Supply | Required switches and cutout, MCB, Contactor, Battery charger, remote monitoring over internet with GSM modem. |
| | Display Parameters/Features [Hint:Products matching all selected values will be displayed; For example, if both 'Engine Speed' and 'Lube oil pressure' are selected, product that include both options will be shown] | Engine Speed, Lube oil pressure, Coolant/cylinder head Temperature, Engine running hours, Engine battery voltage, Engine Running status, Generator Voltage (Ph-Ph), Generator Voltage (Ph-N), Generator Current (R, Y, B), Generator apparent Power (kVA), Generator active Power (kW), Powerfactor, Frequency, Fuel level, Event log, Control supply Voltage |
| | Indicators [Hint:Products matching all selected values will be displayed; For example, if both 'Over speed' and 'Low fuel level' are selected, product that include both options will be shown] | Low Lube oil pressure, High water / coolant / cylinder head temperature, Low fuel level, Over speed |
| Acoustic Enclosure | Sheet Thickness (in mm) | 1.6, 1.8, 2 Or higher |
| Fuel Tank | Fuel Tank Capacity | 200.0 (liter) |
| | Number of Fuel Tank | 1 |
| | Fuel Tank Sheet Material Thickness (in mm) | 2, 3 Or higher |
| Battery | Battery Type | "Low Maintenance free to IS: 14257 for high cranking performance" |
| | Number of Batteries | 1 |
| Salient Features | Salient Features of Power Generator | Glass window on Accoustic Enclosure in front of the Control Panel, Emergency Stop outside the Accoustic Enclosure |
| Trailer | Availability of Trailer | NA for Fixed/Skid Mounted Power Generator |
| | Number of Wheels | 'NA' for without trailer |
| | Brake Mechanism | NA for Fixed/Skid Mounted Power Generator, Hydraulic, Electrical Or higher |
| | Salient Features of Trailer | NA |

| विवरण/Specification | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|--------------------------|--|--|
| Installation Requirement | Scope of installation for diesel generating set when offered by the vendor - inclusive in the scope of supply (Part-1) | a) Installation of Power Generator when offered by the vendor is inclusive in the scope of supply and shall be done by the seller. The installation work of Power Generator and its constituent parts shall be generally conforming to CPWD General Specification for Electrical Works, Part - VII - latest. b) Foundation shall be constructed by the seller. Foundation shall be of PCC type with the ratio of 4:2:1. The length and breadth of the foundation shall be 300 mm more from the respective length and breadth of the Power Generator. The height of the foundation shall be 400 mm, i.e., 200 mm below and 200 mm above the ground level. All the materials / labour required for foundation work shall be supplied by the seller. |
| | Scope of installation for diesel generating set when offered by the vendor - inclusive in the scope of supply (Part-2) | c) Supply, laying and termination of interconnecting power and control cable shall be done by the seller. The cable supplied shall be ISI marked heavy duty PVC insulated, armoured cable, with PVC outer Sheath of Type ST-2 (FR Grade, Category C1), with aluminium conductor having insulation of PVC compound type -C, suitable for rated voltage upto and including 1100 volts and conforming to IS: 1554 (Part-1) latest. For 3-Phase Power Generators, 3.5 core or higher core cables shall be used. Total length of the cable supplied by the seller shall be within 30 meters for each Power Generator with manual control panel and within 60 metres for each Power Generator with AMF control panel. The current rating of the cables shall be as indicated below: 2C, 6 Sq mm for Single Phase, 3.5 & 5.0 KVA 2C, 10 Sq mm for Single Phase, 7.5 & 10 KVA 2C, 25 Sq mm for Single Phase, 15 KVA 2C, 35 Sq mm for Single Phase, 20 KVA 2C, 70Sq mm for Single Phase, 25 KVA 2C, 95Sq mm for Single Phase, 30 KVA 2C, 120Sq mm for Single Phase, 40 KVA 4C, 4 Sq mm for Three Phase, |
| | Scope of installation for diesel generating set when offered by the vendor - inclusive in the scope of supply (Part-3) | d) 10 KVA 4C, 6 Sq mm for Three Phase, 15 KVA 4C, 10 Sq mm for Three Phase, 20 & 25 KVA 4C, 16 Sq mm for Three Phase, 30 KVA 3.5C, 25 Sq mm for Three Phase, 40 KVA 3.5C, 35 Sq mm for Three Phase, 50 KVA 3.5C, 70 Sq mm for Three Phase, 62.5 & 75 KVA 3.5C, 95 Sq mm for Three Phase, 82.5 KVA 3.5C, 120 Sq mm for Three Phase, 100 KVA 3.5C, 185 Sq mm for Three Phase, 125 KVA 3.5C, 300 Sq mm for Three Phase, 160 KVA 3.5C, 2 Run of 120 Sq mm for Three Phase, 180 KVA 3.5C, 2 Run of 150 Sq mm for Three Phase, 200 KVA 3.5C, 2 Run of 185 Sq mm for Three Phase, 225 KVA 3.5C, 2 Run of 240 Sq mm for Three Phase, 250 & 275 KVA 3.5C, 3 Run of 185 Sq mm for Three Phase, 320 KVA 3.5C, 3 Run of 240 Sq mm for Three Phase, 380 & 400 KVA 3.5C, 4 Run of 240 Sq mm for Three Phase, 500, 600 & 750 KVA 3.5C, 6 Run of 240 Sq mm for Three Phase, 900 KVA |
| | Above Scope of Installation for the Diesel Generating Set, when offered by the vendor, has been seen, read, understood, and agreed to Comply | Yes |

| विवरण/Specification | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|---------------------|---|--|
| Warranty/Services | Warranty (in Running Hours) | 2500.0 - 5000.0 Or higher (hour) |
| | Number of Preventive Maintenance Visits Offered in an Year During Warranty Period (Supply of all consumables is the buyer's responsibility) | 2 |
| Test Reports | Type of lab which carried out test of complete product to prove the conformity of product specification | Certificates required as per CPCB |
| | Test Report Available For (Test/approval) | Type Approval Certificate for the specified rating of the Power Generator from any of the designated agency authorized by CPCB, COP Certificate for engine, Type test report for Alternator as per IS:13364 (Part-1) latest / IS:13364 (Part-2) latest to prove conformity to the specifications |

Additional Specification Parameters - Diesel Power Generator (up To 900 KVA) (1 pieces)

| Specification Parameter Name | Bid Requirement (Allowed Values) |
|------------------------------|----------------------------------|
| maximum dimension | 3500 x 1200 x 1850mm (LxWxH) |

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.N o. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|----------------|---|---|------------------|------------------------------|
| 1 | Bhagwat Singh Rajawat | 305001,RAILWAY CARRIAGE WORKSHOP AJMER,305001 | 1 | 30 |

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Scope of Supply

Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

2. Service & Support

Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.

3. **Certificates**

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

4. **Certificates**

The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

5. **Warranty**

Warranty period of the supplied products shall be 3 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

6. **Forms of EMD and PBG**

Bidders can also submit the EMD with Account Payee Demand Draft in favour of

DY.FA&CAO/W&S/All
payable at
Ajmer

Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

7. **Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

(1) Bidder will submit bid specific authorization, otherwise bid offer will not be considered.

(2) During representation only bid documents/quoted terms and conditions clarification will be accepted. No fresh documents will be accepted during representation after opening of technical bid.

(3) The tender must supplied item to Zonal railway PU COREPSU OTHER GOVT.DEPARTMENT in last three financial year and current financial year up to date of tender opening Documentary evidence i.e copies of the purchase order ,supply, installation and successfully commissioning report issued by the above organization must be furnished along with offer evidencing the execution on of the such purchase order . The offer of without documentary evidence rejected summarly . If any deviation w.r.t technical specification then same clearly specified in the offer and justification for the deviation. OEM/ authorized dealer should only participate in the tender and necessary authorization to be attached along with offer.

4.Bidder must submit performance documents along with bid. Only contract copy shall not be considered as supply proof. Bidder has to submit receipt note, delivery challan, completion certificate etc. as proof of supply along with bid.

5.Material must be supplied in 10 - 15 days after P.O. issued.

अस्वीकरण/**Disclaimer**

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and

conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc.

and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---